



ENGINEERS

Date: May 10, 2021
Ref: Permit No: 201810032148
Project Address: 8 Minerva St
San Francisco, CA

Inspection Letter #1 – Field Revision

Inspection Coordinator
Department of Building and Inspections
City of San Francisco



This letter is to address the site condition that is different from approved permit drawing dated 5/7/2019. Below are inspections we conducted at the site throughout the construction process.

Table with 3 columns: Inspection Code, Date, LD Engineers Observation and Comments. Row 1: 1, 3/31/2021, LD Engineers made site inspection with Inspector Mike Gunnell to concur site condition and made updated plan and detail to reflect the changes. Site condition is built more conservative than referenced detail 4/A2. New condition built with a key and wider footing width. Furthermore, GC provided #5 @ 12 o.c. vertical members in lieu of approved #4 @ 16" o.c. Therefore, the condition is more conservative than originally designed.

This inspection was performed under personnel under the general supervision of the undersigned Registered Professional Engineer in the State of California. Based upon structural observation and special inspection performed and recommended, it is our professional judgments that the work with the revised detail 4/A2 will meet the minimum workmanship that is in conformance with the current approved drawing and Building Code.

Distribution:
Building Owner
Contractor

Sincerely,

Handwritten signature of Brandon D. Le, P.E.64685