



***MBTA Rail Transformation  
Discontinuous Electrification Analysis  
Phase 1 & Phase 1a  
May 2022 – Final Draft***

# Contents

Phase 1: Providence Line	3
Phase 1: Stoughton Line	9
Phase 1: Fairmount Line	15
Phase 1: Eastern Line	21
Phase 1a: Worcester Line	28

© Network Rail Consulting

The contents of this presentation remains the intellectual property of Network Rail Consulting and may be used only in connection with the brief for which it was submitted. It is specifically forbidden to communicate the contents to any third party without prior permission in writing from Network Rail Consulting, and all reasonable precautions must be taken to avoid this occurring.

# Phase 1: Providence Line



# Providence Line inc. Stoughton – Service Pattern

PEAK & OFF-PEAK HOUR (REPEATING)

TYPE OF SERVICE	Wickford 60min	Stoughton 30min	Providence 30min	TOTAL PEAK HOUR TRAINS
Wickford Junction	●			1
TF Green	●			1
Providence	●		●	2
S.Attleboro	●		●	2
Mansfield	●		●	2
Sharon	●		●	2
Stoughton		● ●	●	2
Canton Center		● ●	●	2
Canton Junction	●	● ●	●	4
Route 128	●	● ●	●	4
Hyde Park	●	● ●	●	2
Back Bay	●	● ●	●	4
South Station	●	● ●	●	4
End to End time	96'	35'	68'	

- Station Stop
- Station Existing Station
- Station Existing Inner Core Station
- Station Proposed New Inner Core Station
- \* Based solely on speed profiling as part of energy modeling


**Additional Commentary:**

1. Stoughton services will be 1 tph (off-peak) and 2 tph (peak)
2. All other patterns remain the same through peak and off-peak
3. Excludes South Coast Rail Full Build services (South Station - Stoughton - New Bedford - Fall River)


*Note: Most energy-intensive Service patterns used for energy modeling*

# Energy Model – existing infrastructure

Sharon –  
Amtrak Services Only (3MVA)



Sharon –  
Amtrak & MBTA Services (17MVA)




*40MVA transformers at Sharon grid connection*

*The energy analysis shows a **significant increase** in demand at Sharon grid connection when the MBTA services are introduced.*


***A new grid connection is recommended near south station.***

# Energy Model – existing infrastructure

Warwick –  
Amtrak Services Only (2.5MVA)




Warwick –  
Amtrak & MBTA Services (9MVA)



*40MVA transformers at Warwick grid connection*

*The energy modelling shows a **manageable increase** in demand at Warwick grid connection when MBTA services are introduced. It is not anticipated this will cause a capacity issue at Warwick (subject to more detailed analysis).*

# Providence Line: Solution Utilizing OCS



- ▶ Entire MBTA Providence Line service to run OCS
- ▶ Potential new substation at Roxbury
- ▶ Maintenance Facility at Readville Yard

- == Providence Line OCS (South Station – Wickford Jcn)
- Existing HV Transmission Line network
- Proposed Substation locations (Roxbury)
- Existing Substation locations (Sharon, Warwick)

# Providence Line – Capital Scope

## OCS solution

- ▶ No additional OCS: Entire line is already wired
- ▶ Power System: 1 new incoming AC Feed at Roxbury, plus new Section Break at Readville
- ▶ Overline structures: 2 Bridge reconstructions & 17 Contact Wire adjustments
- ▶ Stations: 800ft Platforms lifted by 41” for level boarding. New passenger overbridge at South Attleboro
- ▶ Yards: New Electrified Yard at Readville with Maintenance Facility, plus upgrade of Pawtucket Yard for S&I

## Assumptions

- ▶ AC feed location at Roxbury requires feasibility study. Upgrade to include static balancing
- ▶ ‘Minimum’ structure clearance assumed, with a Maintenance tolerance of 6”
- ▶ Readville site development can be completed in time for the new fleet
- ▶ Existing Signal System assumed to be immunized; EMC study needed for new fleet
- ▶ 4th Track through Attleboro electrified under another project
- ▶ Readville – Canton New track excluded
- ▶ Level boarding is required throughout



# Phase 1: Stoughton Line



# Providence Line inc. Stoughton – Service Pattern

PEAK & OFF-PEAK HOUR (REPEATING)

TYPE OF SERVICE	Wickford 60min	Stoughton 30min	Providence 30min	TOTAL PEAK HOUR TRAINS
Wickford Junction	●			1
TF Green	●			1
Providence	●		●	2
S.Attleboro	●		●	2
Mansfield	●		●	2
Sharon	●		●	2
Stoughton		● ●	●	2
Canton Center		● ●	●	2
Canton Junction	●	● ●	●	4
Route 128	●	● ●	●	4
Hyde Park	●	● ●	●	2
Back Bay	●	● ●	●	4
South Station	●	● ●	●	4
End to End time	96'	35'	68'	


**Additional Commentary:**

1. Stoughton services will be 1 tph (off-peak) and 2 tph (peak)
2. All other patterns remain the same through peak and off-peak
3. Excludes South Coast Rail Full Build services (South Station - Stoughton - New Bedford - Fall River)

- Station Stop
- Station Existing Station
- Station Existing Inner Core Station
- Station Proposed New Inner Core Station
- \* Based solely on speed profiling as part of energy modeling

*Note: Most energy-intensive Service patterns used for energy modeling*


# Energy profile for Stoughton Line



**Theoretically possible to run a full battery service from Canton Jct to Stoughton**

- Notes:
1. Energy modelling excludes Providence Line, which is assumed to be full OCS solution
  2. For stopping patterns / service frequency – refer to Providence Line

# Stoughton Line: Clearance issues (All)




- ▶ There are 3 structures on Stoughton Line
- ▶ **No structure clearance issues identified** (based on MBTA limiting outline)

## Clearances by range

Stoughton	
<17.5'	0
17.5 - 19'	1
>19'	2

# Discontinuous Electrification Solution

- ▶ Run on existing OCS from South Station to Canton Junction.
- ▶ Run on Battery Power from Canton Junction to Stoughton and back again.
- ▶ No additional charging locations required.
  - ▶ *Assumes that the train reaches Canton Junction with sufficient battery charge as a result of Providence Line OCS.*



- == Providence Line (OCS)
- == Stoughton Line (Battery)

**Stoughton is very short and benefits from battery charging when on the Providence Line – no additional charging required**

# *Discontinuous Electrification – Scope*

## Discontinuous Electrification Solution

- ▶ High level platforms at Canton Center.

## Assumptions

- ▶ Platform modifications / relocation to be part of South Coast Rail (Full Build) scope, not this Program
- ▶ No prolonged / overnight stabling at Stoughton (battery depletion)

# Phase 1: Fairmount Line



# Fairmount Line – Service Pattern

## PEAK & OFF PEAK HOUR (REPEATING)

TYPE OF SERVICE	Fairmount	TOTAL PEAK
FREQUENCY (Min.)	15min	HOUR TRAINS
Readville	● ● ● ●	4
Fairmount	● ● ● ●	4
Blue Hill Ave	● ● ● ●	4
Morton St.	● ● ● ●	4
Talbot Ave	● ● ● ●	4
Four Corners/Geneva	● ● ● ●	4
Uphams Corner	● ● ● ●	4
Newmarket	● ● ● ●	4
South Station	● ● ● ●	4
End to End time	25'	
Modeled Travel Time *		


**Additional Commentary**  
1 4 tph to Readville all-day service

- Station Stop
- Station Existing Station
- Station Existing Inner Core Station
- Station Proposed New Inner Core Station
- \* Based solely on speed profiling as part of energy modeling

*Note: Most energy-intensive Service patterns used for energy modeling*




# Energy profile for Fairmount Line




*Theoretically possible to run a full battery service.*

# Fairmount Line: Clearance issues (All)



- ▶ Lowest bridge clearances measured at 17.3'
  - ▶ Washington St: \$30m recon
  - ▶ Harvard St: \$20m recon
- ▶ Avoiding OCS through the Fairmount Line will lead to significant capital savings on Structures

# Discontinuous Electrification Solution



- ▶ Run on Battery Power for majority of the Fairmount Line
- ▶ Use existing 1.5 miles of OCS out of South Station to charge Train batteries, Additional charging station at Readville (OCS or rigid catenary) to be fed from Providence Line
- ▶ Additional charging facilities located within Readville Yard
- ▶ Will allow replacement of 3 Trainsets
- ▶ Discontinuous Electrification including battery replacement ~\$70M-\$160M cheaper than full electrification

- Fairmount Line (Battery)
- Providence Line (OCS)
- Transmission Lines
- Existing Substations
- Charging Stations (South Station; Readville)

# Discontinuous Electrification – Scope

## Discontinuous Electrification Solution

- ▶ Power: Battery charging station at Readville (fed from upgraded Providence Line system)
- ▶ Stations: 3 Platforms upgraded to high level (Fairmount & Readville)
- ▶ 2 charging stations at Readville

## Assumptions

- ▶ Existing OCS in and around South Station will provide sufficient charging opportunity
- ▶ Battery charging station at Readville can be supplied from the upgraded Providence Line system
- ▶ 1 Platform & Track at Readville sufficient for desired service levels
- ▶ Sufficient capacity at Readville for a new fleet maintenance facility

# Phase 1: Eastern Line



# Eastern Line – Service Pattern

## PEAK HOUR (REPEATING)

TYPE OF SERVICE	Newburyport Local 30min	Rockport Local 30min	TOTAL PEAK HOUR TRAINS
Rockport		● ●	2
Gloucester		● ●	2
West Gloucester		● ●	2
Manchester		● ●	2
Beverly Farms		● ●	2
Prides Crossing		● ●	2
Montserrat		● ●	2
Newburyport	● ●		4
Rowley	● ●		2
Ipswich	● ●		2
Hamilton/Wenham	● ●		2
North Beverly	● ●		2
Beverly	● ●	● ●	4
Salem	● ●	● ●	4
Swampscott	● ●	● ●	4
Lynn	● ●	● ●	4
River Works	● ●	● ●	4
Chelsea	● ●	● ●	4
North Station	● ●	● ●	4
End to End time	62'	66'	

## OFF PEAK (REPEATING)

TYPE OF SERVICE	Newburyport Local 60min	Beverly Local 15min	Rockport Local 60min	TOTAL PEAK HOUR TRAINS
Rockport			●	2
Gloucester			●	2
West Gloucester			●	2
Manchester			●	2
Beverly Farms			●	2
Prides Crossing			●	2
Montserrat			●	2
Newburyport	●			4
Rowley	●			2
Ipswich	●			2
Hamilton/Wenham	●			2
North Beverly	●			2
Beverly	●	● ●	●	4
Salem	●	● ●	●	4
Swampscott	●	● ●	●	4
Lynn	●	● ●	●	4
River Works	●	● ●	●	4
Chelsea	●	● ●	●	4
North Station	●	● ●	●	4
End to End time	62'	35'	66'	

BI-DIRECTIONAL SERVICE


- Station
  - Station
  - Station
  - \*
  - Bold text**
- Station Stop
  - Existing Station
  - Existing Inner Core Station
  - Proposed New Inner Core Station
  - Based solely on speed profiling as part of energy modeling
  - Key station
  - Hourly Service

**Additional Commentary:**


- 2022 Climate Bill amendment calls for construction of infill stations at Everett & Revere. These are not included on existing stopping patterns. The impact on energy needs for the local services would need to be modelled and balanced with OCS / infrastructure needs, if confirmed as a valid option.

*Note: Most energy-intensive Service patterns used for energy modeling*

# Energy profile for Eastern Line



0C is with no regen  
 1C is charging rate equal to a full charge in 1hour  
 2C = 30 mins  
 3C = 20 mins  
 4C = 15 mins



*Theoretically possible to run a full battery service (assuming 2No 4 car units each with a 500kWh battery)*

# Eastern Line: Clearance issues (excl. Drawbridges)



Low complexity / cost

Medium complexity / cost

High complexity / cost

- ▶ Analysis based on available LiDAR data and MBTA Limiting Outline
- ▶ A number of potentially constraining structures identified
- ▶ Relative complexity of rebuilding indicated by color coding
- ▶ Potential for significant cost & disruption – but there is opportunity to ‘design out’
- ▶ At least one structure rebuilt since LiDAR data was taken



# Eastern Line: Clearance issues (Drawbridges)

## Systemwide Challenges (Continued)


### Drawbridges

Drawbridge	Condition	Replacement Cost	Year Built	
	Gloucester	Structurally Deficient – to be replaced	\$60M	1911
	Beverly	Structurally Deficient – to be replaced	\$56M	1885
	Saugus	Structurally Deficient – to be replaced	\$60M	1911
	Manchester	Structurally Adequate	N/A	1944
	Tower A	Structurally Deficient – to be replaced	\$121M	1931

Drawbridges have been factored into Infrastructure analysis, on the basis they are difficult / expensive to retrofit and maintain with functioning OCS

# Discontinuous Electrification Solution

- ▶ Run partial OCS from Chelsea – Beverley – Manchester and Chelsea – Beverley – Hamilton & Wenham
- ▶ Run on battery for the remainder of the route
- ▶ Additional charging station at LMF and North Station
- ▶ Allows for replacement of 10 trainsets
- ▶ OCS limits designed to avoid significant constraints (costs):
  - ▶ Washington Ave. Bridge, Chelsea
  - ▶ Tower A, Manchester & Gloucester Drawbridges
- ▶ OCS limits designed to avoid complex & costly locations:
  - ▶ Saugus & Beverly Drawbridges; Salem Tunnel
- ▶ **Discontinuous Electrification Solution including battery replacement ~\$200M cheaper than full electrification over 30 years**



# Discontinuous Electrification – Scope

## Discontinuous Electrification Solution

- ▶ 89.2 single track miles of new Overhead Line (entire Eastern Line)
- ▶ 2 new Substations
- ▶ 1 – 2 new Stations
- ▶ New Electrified Light Maintenance Facility (LMF) at South Salem
- ▶ Replace 9 overline structures; modify / replace 5 drawbridges
- ▶ Signal System Immunization

## Assumptions

- ▶ It is feasible to wire OCS and operate / maintain it through the various drawbridges and at-grade crossings
- ▶ High level platform lengths are 500ft for bi-level and 800ft for single-level
- ▶ Single level trains – no structure clearance required with OCS
- ▶ Bi-level trains require bridge work in some areas
- ▶ One Maintenance Facility to serve the North side system. Location assumed at South Salem

# Phase 1a – Worcester Line



# Worcester Line – Service Pattern

PEAK HOUR (REPEATING)

TYPE OF SERVICE	Express	Zonal Express	Urban Rail	TOTAL PEAK HOUR TRAINS
FREQUENCY (Min.)	Every 60 Min.	Every 30 Min.	Every 30 Min.	
<b>Worcester</b>	●	● ●		3
Grafton		● ●		2
Westborough		● ●		2
Southborough		● ●		2
Ashland		● ●		2
<b>Framingham</b>	●	● ●	● ●	5
West Natick			● ●	2
Natick Center			● ●	2
Wellesley Square			● ●	2
Wellesley Hills			● ●	2
Wellesley Farms			● ●	2
Riverside				
Auburndale			● ●	2
W. Newton			● ●	2
Newtonville			● ●	2
Boston Landing	●	● ●	● ●	5
West Station	●		● ●	
Landsdowne	● ●	● ●	● ●	5
Back Bay	● ●	● ●	● ●	5
South Station	●	● ●	● ●	5
End to End time	N/A	80 mins	55 mins	
Modeled Travel Time *				



- Station Stop
- Station Existing Station
- Station Existing Inner Core Station
- Station Proposed New Inner Core Station
- \* Based solely on speed profiling as part of energy modeling
- Station** Key station

**Additional Commentary:**


1. Intent is an all day, frequent repeating service to encourage modal shift
2. South Station - Worcester car minimum journey time is 45 mins
3. South Station - Worcester local stopping service minimum time currently 1hr 31 mins
4. South Station - Worcester local stopping service based on EMU speed profile
5. Layover facility required at Worcester
6. New Stations at Riverside & West Station not included in stopping patterns
7. All 3 Wellesley Stations included in the stopping patterns
8. Current travel times taken from current MBTA timetables
9. Zonal Express current travel time - based on current express to Natick, minus 2 mins (adjusted for construction work)
10. No off-peak services defined, but will not be any more energy intensive than the local stopping service

*Note: Most energy-intensive Service patterns used for energy modeling*


# Energy profile for Worcester Line









0C is with no regen  
 1C is charging rate equal to a full charge in 1hour  
 2C = 30 mins  
 3C = 20 mins  
 4C = 15 mins




# Proposal and Utility Provider Coverage









# Worcester Line Clearance Issues (All)


-  Proposed Substation
-  Low bridges – high costs for OCS
-  Battery
-  Proposed OCS
-  Transmission line
-  Proposed Charging Station





# Discontinuous Electrification Solution

-  Proposed Substation
-  Low bridges – high costs for OCS
-  Battery
-  Proposed OCS
-  Transmission line
-  Proposed Charging Station



# Discontinuous Electrification – Scope

## Discontinuous Electrification Solution

- ▶ 42 STM of discontinuous OCS
- ▶ 1 structure under proposed OCS to be rebuilt (Boden Lane MP19.88)
- ▶ 1 new substation for OCS + 1 new / upgraded substation for charging power at Worcester Station & Layover
- ▶ 1 charging facility feeding 2 lines at Worcester station (3<sup>rd</sup> line is not platformed)
- ▶ 1 charging facility (or OCS) at a suitable layover facility near Worcester Station
- ▶ 3 platform upgrades to high-level at Auburndale, West Newton & Newtonville
- ▶ Replace 1 overline structure in Natick
- ▶ Signal System Immunization

## Assumptions

- ▶ New substation needed at Worcester; may be possible to Value Engineer with a shore supply at the layover and trickle charging / bulk battery storage at the station.
- ▶ Worcester triple track project will upgrade platforms to 800ft long high level at West Natick, Wellesley Square, Wellesley Hills & Wellesley Farms. Natick Centre is also being upgraded (separate project)
- ▶ Platform upgrades only required to stations that are inaccessible – partially accessible stations through mixed boarding fleet solution
- ▶ 26 overline structure interventions avoided due to discontinuous OCS
- ▶ No Maintenance Facility on the Worcester Line – to be based at Readville

## *International Presence*

*Boston  
London  
New York  
Riyadh  
Sacramento  
San Francisco  
Sydney  
Toronto  
Washington*

