

The list was pulled by the fire marshal (Brian Dean) from an AFD report of incidents that AFD responded to and combined with the Code Abatement known failures. The list includes incidents AFD alone responded to and incidents Code Abatement alone investigated and others both agencies responded to. These occurred from Dec 2022 through April. Note 3 failures occurred prior to the Cross Fit Gym failure. I have added some notes (in yellow) to the list:

12/14/22	202 Stewart St	Carport collapse
12/26/22	5011 Arctic #B	Lucky Market, signs of roof failure - broken glu lam beam
1/11/23	1225 E. 7th Ave	dry storage bldg collapse, broken sprinkler piping
2/17/23	1101 E. 76th	Cross Fit collapse
2/25/23	1627 W. 32nd	multifamily carport collapse
3/4/23	575 Ingra St	Fashion Pact clothing store collapse roof truss failure
3/5/23	140 E. Dowling	auto shop collapse Roof truss failure
3/7/23	1307 E. 74th Ave. Ste. 001	Roof truss failure
3/7/23	2207 E. Tudor Rd.	Top chord hung truss failure This was actually nothing
3/7/23	510 E. 45th	residential carport collapse
3/10/23	6616 Rosewood	50x50 shop building collapse roof truss failure
3/15/23	3101 Penland Pkwy	Northway Mall partial collapse roof truss failure
3/20/23	2503 Arctic	Metrie decorative finishings 2x12 roof purlins failure in old metal building
3/21/23	8726 Corbin Dr.	Report of truss failure - potential truss failure – requires engineer evaluation
3/30/23	4517 San Roberto	deck collapse damaged gas meter

4/2/23 3741 Richmond multifamily truss failure resulting in partial collapse over exit stairway

4/2/23 4240 Wisconsin church entry canopy collapse roof truss failure resulting in collapse

Unknown date 11030 Chelea H2Oasis entry/exit stair roof collapse over south exit due to corrosion (we think)

Unknown date 18727 Old Glenn Hwy Door Systems of Alaska warehouse collapse Appears shed roof ledger was not properly attached to building.