

# GISBORNE WATER SUPPLY WATER SAFETY PLAN



VERSION 1-10 NOVEMBER 2022

# Introduction

#### Gisborne Water Supply Water Safety Plan

The Gisborne Water Supply Water Safety Plan is specific to the Gisborne supply. It has a thorough risk assessment and summary of the hazards, barriers, and Gisborne District Council's supporting systems.

Gisborne District Council's drinking water safety planning is structured with an overarching Organisational Water Safety Plan and individual supply specific Water Safety Plan's that incorporate individual supply specific Drinking Water Source Risk Assessments.

The Organisational Plan details aspects of water supply management that apply to all GDC supplies and includes the systems, actions, processes and documents GDC has in place. The Organisational Plan supports the individual supply plans and is read in conjunction as a hierarchy document.

This Gisborne Water Supply Water Safety Plan contributes to Gisborne District Council:

- Meeting obligations as a water supplier in the Water Services Act 2021
- Understanding the Gisborne Water Supply related risks
- Identifying and actioning improvements required for any unacceptable risks

Fourteen (14) events are identified with unacceptable risk and require improvements. These events and the corresponding improvements are in Section 6 of this plan.

# **Document Control**

|                          | Document Development Information   |                 |   |
|--------------------------|--|-----------------|---|
| Author Name(s)           | Position & Organisation  |                 |   |
| Josh Tākao               | Senior Compliance Advisor – Wai Comply   |                 |   |
| Cathy Walker             | Senior Advisor Drinking Water – Gisborne D   | istrict Council |   |
| Peer Reviewer            |  |                 |   |
| Judith Robertson         | Drinking Water Team Leader, Gisborne Dist  | rict Council    |   |
| Authorised for Release   |  |                 |   |
| David Wilson             | Lifelines Director, Community Lifelines  |                 |   |
|                          | Signature  |                 |   |
|                          | d'alla   |                 |   |
| Date:                    | 10 November 2022   | Version No:     | 1 |
| Wai Comply Filename:     | 2022-07_Gisborne_DC_Gisborne City WSP DRAFT_JJT_v0.1                                   |                 |   |
| Water Supplier Filename: | 2022 Gisborne District Council Water Supply - Water Safety Plan – Version 1 – A2584007 |                 |   |
| Header:                  | Gisborne Water Supply Water Safety Plan  |                 |   |

| VERSION<br>NO | REVISION DETAILS | AUTHORED (AND REVIEWED) BY | VERSION DATE     |
|---------------|------------------|----------------------------|------------------|
| V0.1          | Draft            | Wai Comply                 | 12 July 2022     |
| V1            | Final            | Gisborne District Council  | 10 November 2022 |

# **Table of Contents**

| WA    | TER SAFETY PLAN DEVELOPMENT                      | 1  |
|-------|--|----|
| Rela  | tionship with the Organisational WSP             | 1  |
| WSP   | Review and Audit                                 | 1  |
| Deve  | elopment Team and Details                        | 2  |
|       |  |    |
| 1     | OVERVIEW OF THE GISBORNE WATER SUPPLY            | 1  |
| 2     | CONTROL AND CRITICAL CONTROL POINTS              | 1  |
| -     |  |    |
| 3     | CATCHMENT  | 2  |
| 3.1   | Waingake WTP Catchments                          | 2  |
| Cont  | amination Barrier Management                     | 2  |
| Veri  | fication Monitoring and Performance Criteria     | 3  |
| Sum   | mary of Catchment Hazards – Waingake WTP         | 3  |
| 3.2   | Waipaoa WTP Catchment                            | 4  |
| 3.2.2 | Contamination Barrier Management                 | 4  |
| Verif | ication Monitoring                               | 4  |
| 3.2.3 | Summary of Catchment Hazards – Waipaoa WTP       | 5  |
| 4     | TREATMENT  | 6  |
| 4.1   | Waingake Water Treatment Plant                   | 6  |
| 4.1.1 | Waingake Treatment Plant Details                 | 6  |
| 4.1.2 | Barrier Management                               |    |
| 4.1.3 | Verification Monitoring                          | 10 |
| 4.1.4 | Summary of Treatment Hazards – Waingake WTP      | 11 |
| 4.2   | Waipaoa Water Treatment Plant                    | 13 |
| 4.2.1 | Waipaoa Treatment Plant Details                  | 13 |
| 4.2.2 | 2 Contamination Barrier Management               | 16 |
| 4.2.3 | Verification Monitoring and Performance Criteria |    |
| 4.2.4 | Summary of Treatment Hazards – Waipaoa           |    |
| 5     | DISTRIBUTION NETWORK                             |    |
| Gisb  | orne Supply Distribution Network                 |    |
| 5.1.1 | Distribution Network Summary                     |    |
| 5.1.2 | Water quality analysis                           | 23 |
| 5.1.3 | Barrier Management                               | 25 |
| 5.1.4 | Verification Monitoring and Performance Criteria | 25 |
| 5.1.5 | Summary of Distribution Network Hazards          |    |
| 6     | GENERAL HAZARDS                                  | 28 |
|       |  |    |
| 7     | RISK SUMMARY AND IMPROVEMENTS                    |    |
| 8     | REFERENCES                                       | 35 |

| APPENDICES                         | 36 |
|------------------------------------|----|
| Appendix A. Risk Assessment Tables | 36 |

# **Figures**

| Figure 1: Gisharne WSP hierarchy of documents | 1  |
|---|----|
| igure 1. disborne wor merarchy of documents   | т. |

# **Tables**

| Table 1: WSP Development Steps   | 2    |
|--|------|
| Table 2: Catchment Hazards for Waingake Water Treatment Plant (Mangapoike Dams and Waingake Strear | n).4 |
| Table 3: Catchment Hazards for Waipaoa Water Treatment Plant                                       | 5    |
| Table 4: Treatment Hazards for Waingake Water Treatment Plant                                      | 12   |
| Table 5: Treatment Hazards for Waipaoa Water Treatment Plant                                       | 18   |
| Table 6: Distribution Network Hazards for Gisborne Distribution Network                            | 27   |
| Table 7: General Hazards for GDC Water Supply  | 28   |
| Table 8: Unacceptable Risks and Improvements for Gisborne Water Supply                             | 33   |

# WATER SAFETY PLAN DEVELOPMENT

This Water Safety Plan (WSP) is a risk assessment for the **Gisborne Water Supply.** It identifies the potential hazards and hazardous events that could affect the drinking water supply, assesses the likelihood and consequences of these, and implements suitable controls to reduce the risk of the unwanted event occurring. By implementing this plan, GDC aims to ensure a safe and secure supply of drinking-water is provided for consumers.

The audience for this plan is multiple levels of GDC as the water supplier, customers and stakeholders, contractors, consultants, and regulators.

### **RELATIONSHIP WITH THE ORGANISATIONAL WSP**

The GDC **Organisational Water Safety Plan** contains information about water supply management that apply to all GDC supplies. This includes the systems, actions, processes and documents GDC has in place for all supplies.

The GDC Organisational WSP is a critical supporting document to the **Gisborne Supply WSP** and is referenced throughout as the source of information, to avoid duplication.



Figure 1: Gisborne WSP hierarchy of documents

### **WSP REVIEW AND AUDIT**

To ensure the accuracy and validity of the risk assessment, scheduled WSP reviews and audits are required. The review and audit processes are detailed in Section 3 of the GDC Organisational WSP.

# **DEVELOPMENT TEAM AND DETAILS**

The development of the **Gisborne Supply WSP** was done as outlined in Section 1.3 of the GDC Organisational WSP.

| Development Step          | Detail   | Personnel Involved  |
|---------------------------|--|---|
| Site Visit                | Site inspection of Mangapoike Dams,<br>Waingake Water Treatment Plant<br>(WTP), Waipaoa WTP, and Gisborne<br>Distribution Network sites on 8 <sup>th</sup> and<br>9 <sup>th</sup> December 2021.       | GDC – Brett Chisholm, Ged Brown,<br>Ralph Ogden, Paora Te Rangiita<br>Wai Comply – Josh Takao, Grant King                           |
| Online<br>workshop(s)     | Workshop 15 <sup>th</sup> December 2021 for<br>ensuring accuracy of supply details,<br>confirmation of hazards, planned<br>improvements, and status of<br>supporting systems development or<br>review. | GDC – Judith Robertson, Janine du<br>Plessis, Ralph Ogden, Paora Te Rangiita<br>Wai Comply – Josh Takao, Grant King                 |
|                           | Workshop 16 <sup>th</sup> March 2022 for<br>ensuring accuracy of supply details,<br>confirmation of hazards, planned<br>improvements, and status of<br>supporting systems development or<br>review.    | GDC – Judith Robertson, Janine Du<br>Plessis, Ralph Ogden, Peter McKay,<br>Paora Te Rangiita<br>Wai Comply – Josh Takao, Grant King |
| Risk table<br>assessment  | Risk table completion and review by GDC staff. May and June 2022.  | GDC – Cathy Walker, Peter McKay,<br>Ralph Ogden, Judith Robertson   |
| WSP review and adjustment | Draft Gisborne Water Supply Water<br>Safety Plan review by GDC staff. July<br>2022.  | GDC – Cathy Walker, Judith Robertson,<br>Ralph Ogden  |

Table 1: WSP Development Steps

# **1 OVERVIEW OF THE GISBORNE WATER SUPPLY**



# **2 CONTROL AND CRITICAL CONTROL POINTS**

# 2.1 MONITORING, ACTION AND REPORTING PROTOCOL

A Monitoring, Action and Reporting Protocol documents the control and critical control point monitoring in the supply. Monitoring covers the source water, treatment plant and distribution zones done to manage and verify the quality of the water. The monitoring parameters, frequency and sampling sites meet the requirements in the Water Quality Assurance Rules (the Rules). The response actions are in place to ensure a safe supply of water.

# **2.2 CRITICAL CONTROL POINTS:**

#### Waingake WTP:

The critical control point for bacterial disinfection is through the chlorination process. It is based on c.t. (concentration of chlorine x time water is held in a contact tank). Critical control is met by achieving a c.t. of 15 calculated using continuously monitored FAC, pH, flow and the reservoir level.

Modelling shows that at higher flows through the treatment process, the c.t critical control cannot be met. Installation of a UV disinfection facility will overcome this issue and will provide a secondary barrier treatment.

The Waingake catchment risk assessment resulted in a minimum of 3 Logs of treatment for protozal control. The critical control point for protozoal removal is through the coagulation, sedimentation and filtration process. Critical control is met by meeting turbidity level from individual filters and time requirements.

#### Waipaoa WTP:

The critical control point for bacterial disinfection is through the UV disinfection process. Critical control is met by meeting turbidity level, transmittance, UV dose and flow requirements.

The Waipaoa catchment risk assessment resulted in a minimum of 4 Logs of treatment for protozoal control. The first critical control point, for 3 log protozoal removal, is through the coagulation, sedimentation and filtration process. Critical control is met by meeting turbidity level from individual filters and time requirements.

The second critical control point, for a further 3 log protozoal removal, is through the UV disinfection process. Critical control is met by meeting turbidity level, transmittance, UV dose and flow requirements.

# **3** CATCHMENT

Barrier to contamination (Water Services Act Section 31(2)(a)): Prevent hazards entering raw water – applies to whole catchment up to the intake/abstraction point

A Drinking-Water Source Risk Assessment (**DWSRA**) was developed to provide a comprehensive understanding of the hazards within the catchments that provide source water to the Waipaoa and Waingake Water Treatment Plants (**WTP**).

The DWSRA investigates hazards and potential hazards in the three catchments that supply the Gisborne supply, the Mangapoike Dams, Waingake (Te Arai) Bush, and Waipaoa River. The DWSRA compliments this Gisborne supply Water Safety Plan (WSP) as the WSP provides a detailed risk assessment for each water source.

# **3.1 WAINGAKE WTP CATCHMENTS**

# **Catchment Summary**

See DWSRA – Description of Sources including Table 2 Waingake Supply components.

Water Quality Analysis See DWSRA – Appendix B.

### **Contamination Barrier Management**

#### SOPs and corrective actions

- MANUAL 01 Waingake\_Waipaoa WTP Quality Management System (QMS) Version 5, September 2012 (A297912)
- MANUAL 13 Mangapoike Catchment and Dam Operations Version 1, April 2002 (vA1350856)
- MANUAL 14 Water Supply Pump Station Operations Version 1, November 2004 (vA1347789)
- MANUAL 06 Waingake Plant Work Instructions Version 3, March 2011 (vA1507953)

### Inspections

Inspections are outlined in Manuals above.

### Maintenance

Inspection systems and programming are detailed in the GDC Organisational WSP (Section 7). The QMS refers to the QMS as the primary inspection and maintenance schedule. This will be supplemented by Water Outlook in future.

- Dam inspections in Manual 13.
- Dam maintenance.
- Pest control to protect dam face.
- Vegetation management.
- General pest control.
- Electric fences.

The development and implementation of a formalised Operational Maintenance Plan is an improvement item in the Organisational WSP.

# Verification Monitoring and Performance Criteria<sup>1</sup>

Monitoring and action limits are outlined in the Monitoring, Action and Reporting Protocol.

| Site <sup>2</sup>               | Parameter  | Frequency   |
|---------------------------------|--|---|
| Combined Dams<br>Waingake River | E. coli & Total Coliforms  | 2 per month   |
| Combined Dams<br>Waingake River | Iron, Manganese, Colour, Nitrate   | Monthly   |
| Combined Dams<br>Waingake River | Alkalinity, Antimony, Arsenic, Barium, Cadmium,<br>Calcium, Chloride, Chromium, Copper, Lead,<br>Magnesium, Mercury, Nickel, Sodium, Sulphate,<br>Total Phosphorus | annually as long as<br><50% of MAV<br>otherwise monthly |

# **Summary of Catchment Hazards – Waingake WTP Catchments**

The DWSRA for the Waingake catchment documents the possible sources of potential hazards. These are summarised below.

For full risk tables including risk assessment and hazardous event mitigations refer to Appendix A.

| Supply Component              | Hazardous Event   |
|-------------------------------|---|
| Waingake –<br>Mangapoike Dams | Contamination in the source water catchments from industrial practices (road transport)   |
|                               | Contamination in the source water catchments from open space activities (stormwater runoff)   |
|                               | Contamination in the source water catchment from new or unknown activities (change of land use, change in access permissions)       |
|                               | Naturally occurring contaminants present (includes cyanobacteria, chemicals, metals)  |
|                               | Contamination or loss of supply due to changes from seismic activity  |
|                               | Contamination or loss of supply due to surrounding areas highly susceptible to erosion (high solids loading)                        |
|                               | Contamination of the source water caused by ashfall from a fire or volcanic eruption  |
|                               | Loss of supply due to insufficient source water availability - extended period of dry weather or drought                            |
|                               | Loss of supply due to unsuitable raw water quality for the treatment process (Mangapoike Dam stratification causing quality issues) |
|                               | Contamination of the source water from faecal matter from feral animals within the catchment area                                   |
| Waingake –<br>Waingake River  | Contamination in the source water catchment from industrial practices (road transport)  |
|                               | Contamination in the source water catchment from open space activities (stormwater runoff)  |
|                               | Contamination in the source water catchments from conservation land practices (animal control,1080 drops)                           |

<sup>&</sup>lt;sup>1</sup> Monitoring required under the Rules

<sup>&</sup>lt;sup>2</sup> See Water Quality Programme Protocols for sampling sites (788953)

| Supply Component  | Hazardous Event   |
|---|---|
|   | Contamination of the source water catchment from new or unknown activities (change of land use, change in access permissions) |
|   | Naturally occurring contaminants present (includes cyanobacteria, chemicals, metals)  |
|   | Contamination or loss of supply due to changes from seismic activity  |
|   | Contamination or loss of supply due to surrounding areas highly susceptible to erosion (high solids loading)                  |
|   | Contamination of the source water caused by ashfall from a fire or volcanic eruption  |
| Loss of supply due to insufficient source water availability - extended perio<br>weather or drought |   |
|   | Contamination of the source water from faecal matter from feral animals within the catchment area                             |

Table 2: Catchment Hazards for Waingake Water Treatment Plant (Mangapoike Dams and Waingake Stream)

# 3.2 WAIPAOA WTP CATCHMENT

#### **Catchment Summary**

See DWSRA – Description of Sources including Table 6 Waipaoa Supply components.

#### **Water Quality Analysis**

See DWSRA – Appendix B.

#### **Contamination Barrier Management**

#### SOPs and corrective actions (non CCP)

N/A – Waipaoa Catchment is not actively managed due to the size. Risk mitigations in place further downstream (i.e., Treatment systems).

#### **Inspections and Maintenance**

N/A – The Waipaoa Catchment is not actively managed due to its size. Risk mitigation is in place further downstream (i.e., Treatment systems).

### Verification Monitoring and Performance Criteria<sup>3</sup>

Monitoring details are outlined in the GDC Monitoring, Action and Reporting Protocol.

| Site <sup>4</sup> | Parameter  | Frequency   |
|-------------------|--|---|
| Waipaoa River     | E. coli & Total Coliforms  | 2 per month   |
| Waipaoa River     | Iron, Manganese, Colour, Nitrate   | Monthly   |
| Waipaoa River     | Alkalinity, Antimony, Arsenic, Barium, Cadmium,<br>Calcium, Chloride, Chromium, Copper, Lead,<br>Magnesium, Mercury, Nickel, Sodium, Sulphate. | annually as long as<br><50% of MAV<br>otherwise monthly |

<sup>&</sup>lt;sup>3</sup> Monitoring required under the Rules

<sup>&</sup>lt;sup>4</sup> See Water Quality Programme Protocols for sampling sites (788953)

# Summary of Catchment Hazards – Waipaoa WTP

For full risk tables including hazardous event mitigations and risk assessment refer to Appendix A.

| Supply<br>Component    | Hazardous Event   |
|------------------------|---|
| Waipaoa River          | Contamination in the source water catchment from agricultural practices (includes pesticides, fertilisers, farm operations and grazing)                   |
|                        | Contamination in the source water catchment from industrial practices (road transport)  |
|                        | Contamination in the source water catchments from open space activities (stormwater runoff)   |
|                        | Contamination in the source water catchments from rural residential practices (fertilisers, pets/livestock, offsite and onsite sewage, weed/pest control) |
|                        | Contamination of the source water catchment from new or unknown activities (change of land use or 'non-notified activities')                              |
|                        | Naturally occurring contaminants present (includes cyanobacteria, chemicals, metals)  |
|                        | Contamination or loss of supply due to changes from seismic activity  |
|                        | Contamination or loss of supply due to surrounding areas highly susceptible to erosion (high solids loading)  |
|                        | Contamination of the source water caused by ashfall from a volcanic eruption  |
|                        | Loss of supply due to insufficient source water availability - extended period of dry weather or drought  |
| Tarble 2. Catabasent I | Internet for Marin and Marton Transformer Danst   |

Table 3: Catchment Hazards for Waipaoa Water Treatment Plant

# **4** Treatment

Barrier to contamination (Water Services Act Section 31(2)(b-c)): Remove particles, pathogens, chemical and radiological hazards, and kill or inactivate pathogens – *applies to the intake/abstraction points through to the WTP outlets* 

# 4.1 WAINGAKE WATER TREATMENT PLANT

#### **Waingake Treatment Plant Details**

Waingake Flow diagram



# Waingake Abstraction

| Process Step  | Detail(s)          | Description   |  |  |
|---|--------------------|---|--|--|
| Clapcott<br>(Mangapoike<br>Dam No. 1)<br>(Waingake WTP) | Description        | Lake settlement, dam intake coarse screening. Sang dam discharges into far end of Clapcott dam for additional capacity.     |  |  |
|   | Abstraction method | Intake columns within dams. Multiple points of abstraction at differing depths.   |  |  |
|   | Control            | All dams - manually operated at intake towers. Gravity flow 200-500 m <sup>3</sup> /hr pumped up to 1200 m <sup>3</sup> /h. |  |  |
|   | Online Monitoring  | Level   |  |  |
|   | Security           | Within protected catchment area and remote site. Gates locked.<br>Shared access with forestry staff only.                   |  |  |
|   | Backup power       | n/a as valves manually operated   |  |  |
| Williams  | Description        | Lake settlement, dam intake coarse screening.   |  |  |
| (Mangapoike<br>Dam No. 2)                               | Abstraction method | Intake columns within dams. Multiple points of abstraction at differing depths.   |  |  |
| (Waingake WTP)  | Control            | All dams - manually operated at intake towers. Gravity flow 200-500 m <sup>3</sup> /hr pumped up to 1200 m <sup>3</sup> /h. |  |  |
|   | Online Monitoring  | Level   |  |  |
|   | Security           | Within protected catchment area and remote site. Gates locked. Shared access with forestry staff only.                      |  |  |
|   | Backup power       | n/a as valves manually operated   |  |  |
| Waingake Intake<br>(Waingake WTP)                       | Description        | Course bar screen on concrete intake structure with screen backflush.   |  |  |
|   | Abstraction method | Full width weir to channel  |  |  |
|   | Control            | Rotork valve connected to telemetry and online control  |  |  |
|   |                    | systems. Open/close only.   |  |  |
|   | Online Monitoring  | Flow, turbidity   |  |  |
|   | Security           | Very remote site and within private property. Normal access via   |  |  |
|   |                    | several ford crossing requiring 4WD.  |  |  |
|   | Backup power       | Solar and UPS on some systems.  |  |  |

# Waingake Bulk Raw Water Mains and Pump Stations

| Process Step              | Detail(s)         | Description  |  |
|---------------------------|-------------------|--|--|
| Damline &<br>Fairview Raw | Description       | Flow booster pump stations. Two pumps in duty/standby arrangement.   |  |
| Water Pump<br>Stations.   | Control           | Rotork valve connected to telemetry and online control systems in place at both sites.   |  |
|                           | Online Monitoring | Pressure, Flow, Valve position at both sites.  |  |
|                           | Security          | Very remote site, within private property and locked buildings at both sites.  |  |
|                           | Backup power      | UPS on some systems. Generator installed. Currently manual operation with plans to add remote control.   |  |
| Raw Water Trunk<br>Main   | Description       | 450 mm CLMS. Largely buried. Many pipe bridges. Sections<br>exposed to atmosphere. Cathodic protection installed.<br>Unstable geography. Passing through forestry and grazing<br>land. Air valves and scour points in place. |  |
|                           | Control           | N/A  |  |
|                           | Online Monitoring | None   |  |
|                           | Security          | Asset location well known. Marker posts installed.   |  |

| Process Step | Detail(s)    | Description |
|--------------|--------------|-------------|
|              | Backup power | N/A         |

# Waingake Treatment Summary

| Treatment & | Storage  |   |         |          |  |  |
|-------------|--|---|---------|----------|--|--|
| Treatment   | Plant name                                     | Waingake WTP  |         |          |  |  |
| Plant       | Treatment Processes                            | Coagulation/Flocculation/Sedimentation; Filtration; Chlorination  |         |          |  |  |
|             | Treatment Processes                            | Log   | ge⁵     |          |  |  |
|             |  | Bacteria  | Viruses | Protozoa |  |  |
|             | Coagulation,<br>Flocculation,<br>sedimentation | 0.2-2   | 0.1-3.4 | 1-2      |  |  |
|             | Rapid media filtration                         | 0.2-4.4   | 0-3.5   | 0.4-3.3  |  |  |
|             | Gas chlorination                               | 2   | 2       | 0        |  |  |
|             | Design capacity                                | 31,000 m <sup>3</sup> /day  |         |          |  |  |
|             | Daily flow average                             | 15,000 m <sup>3</sup> /day  |         |          |  |  |
|             | Chemicals added                                | Polyaluminium chloride (PACl), Polydadmac L3RC (Poly), Chlorine Gas, Hydrofluorosilicic Acid  |         |          |  |  |
|             | Standby chemical<br>dosing facilities          | Lime and Sodium hexametaphosphate, PACI, Poly, Chlorine, Fluoride   |         |          |  |  |
|             | Bypasses                                       | Clarifier bypass exists and is used for clarifier clean (completed every 2 years). Note adjusted performance requirements enabled when clarifier clean is carried out (i.e., tighter turbidity requirements). Other bypasses available but not actively used. |         |          |  |  |
|             | Security                                       | WTP is completely fenced and locked, limited access keys  |         |          |  |  |
|             | Power Supply                                   | Primary – Electricity network<br>Backup/standby – Diesel generator  |         |          |  |  |
| Storage     | Reservoir name                                 | Clearwater Reservoir (CWR) (1,000 m <sup>3</sup> ), Backwash Tank (500m <sup>3</sup> )  |         |          |  |  |
| Reservoirs  | Reservoir type                                 | Treated water (excluding Fluoridation)  |         |          |  |  |
|             | Location                                       | Waingake WTP site   |         |          |  |  |
|             | Capacity                                       | Clearwater Reservoir (1,000 m <sup>3</sup> )<br>Backwash Tank (500m <sup>3</sup> )  |         |          |  |  |
|             | Sealed   | Yes   |         |          |  |  |
|             | Vermin proof                                   | Yes   |         |          |  |  |
|             | Run-off directed off roof                      | Yes   |         |          |  |  |
|             | Above/below ground                             | Both reservoirs above   | ground  |          |  |  |

<sup>&</sup>lt;sup>5</sup> LRVs based on Appendix 2 of the MoH WSP Handbook (Ministry of Health, 2019)

# Waingake Treatment Steps Detail

| Process Step                     | Detail(s)                  | Description  |  |  |
|----------------------------------|----------------------------|--|--|--|
| Coagulation and<br>Clarification | Description                | Partial coagulation, contact flocculation.<br>Duty standby dose pumps.<br>Twin dose lines. Pre and post clarifier sampling points.   |  |  |
|                                  | Control                    | Flow controlled by inlet flow meter  |  |  |
|                                  | Online Monitoring          | PACL - Pump status, speed, dosage, and stroke. Transfer pump<br>status.<br>Poly – Pump status, speed, and stroke position. Mixer status.<br>Poly make up system fault.                       |  |  |
|                                  | Under/overdose<br>controls | Day tanks for both Poly and PACI limit total volume available.<br>'Stubbe' pressure valves in place.<br>Daily checks on calculated chemical consumption.                                     |  |  |
| Rapid Gravity<br>Sand Filtration | Description                | Five Filters. 2.8 m of graded sand (1.4-2.8 mm). Backwash with combination air/water (10 mins air/water and 5 mins water only) with Backwash Reservoir water (500 m3).                       |  |  |
|                                  | Control                    | Inlet flow control by weir height, inlet valve.<br>Outlet flow control by float arm and outlet valve.<br>Backwash initiated on timer, filter head loss, or turbidity.                        |  |  |
|                                  | Online Monitoring          | Individual and combined filter turbidity.  |  |  |
| Chlorination                     | Description                | Chlorine gas 920 kg drum. 1 x duty 1 x standby 1 x spare. Drums<br>sitting on scales measured for weight.<br>Duty & standby chlorinators.<br>Duty & standby carry water pumps (inlet of CWR) |  |  |
|                                  | Contact time               | Waingake is limited to less than 15 minutes contact time for most flows; based on calculations.  |  |  |
|                                  | Control                    | Chlorine dosing is flow proportional   |  |  |
|                                  | Online Monitoring          | FAC level at the filtered Water Sump outlet (FWS) and CWR<br>outlet<br>Chlorinator status<br>Booster pump status   |  |  |
|                                  | Under/overdose<br>controls | Daily checks on calculated chemical consumption and<br>chlorinators.<br>Alarms linked to FAC analysers with automated response built in<br>('Zero flow' at Makaraka Pump Station).           |  |  |
| Fluoridation                     | Description                | Hydrofluorosilicic acid. Bulk storage tank and day tank. Day tank sitting on scales measured for weight.   |  |  |
|                                  | Control                    | Variable speed/stroke dose pumps have auto speed control governed by final water flow meter and manual stroke control adjusted by the operator.  |  |  |
|                                  | Online Monitoring          | Fluoride level analyser at the CWR outlet<br>Day tank weight<br>Dose pump status   |  |  |
|                                  | Under/overdose<br>controls | Day tank limits total volume available.<br>Fluoride dose pump stops when flow <150 m³/hr.<br>'Stubbe' pressure valves in place.  |  |  |

| Parameter                   | Site     |         | Results   |
|-----------------------------|----------|---------|-----------|
| E. coli (dataset from 2015- | Waingake | 825     | 0 samples |
| 2021)                       |          | samples |           |
| DWSNZ MAV                   |          | <1      | >1        |

# **Barrier Management**

SOPs and corrective actions

- MANUAL 01\_ Waingake\_Waipaoa WTP Quality Management System Version 5, September 2012 (A297912)
- MANUAL 05\_ Trunk Water Main Emergency Response Plan Version 4, January 2011 (vA874947)
- MANUAL 06 \_ Waingake Plant Work Instructions Version 3, March 2011 (vA1507953)
- MANUAL 07 \_ Waingake Chemical Plant Work Instructions Version 5, May 2011 (vA1475511)
- MANUAL 10 \_ Waingake & Waipaoa Laboratory Manual Version 2, September 2010 (vA875005)
- MANUAL 13 \_ Mangapoike Catchment and Dam Operations Version 1, April 2002 (vA1350856)
- MANUAL 14\_ Water Supply Pump Station Operations Version 1, November 2004 (vA1347789)

### Inspections

See inspections outlined in SOPs above.

#### Maintenance

Set out in:

- MANUAL 11 \_ Waingake and Waipaoa Calibration Work Instructions Version 2, June 2011 (vA875006)
- Development and implementation of a formalised Operational Maintenance Plan is an improvement item in the Organisational WSP.

### **Verification Monitoring and Performance Criteria**

The Monitoring, Action and Reporting Protocol sets out the limits and corresponding response actions.

| Site                     | Parameter                                     | Frequency           |
|--------------------------|---|---------------------|
| <sup>6</sup> Raw water   | Turbidity, pH, conductivity                   | Continuous          |
| Raw water                | Turbidity                                     | weekly <sup>7</sup> |
| Post PACI                | рН  | Continuous          |
| <sup>8</sup> Post filter | Individual filter turbidity                   | Continuous          |
| Post filter              | Flow, run time, combined turbidity, head loss | Continuous          |
| Pre reservoir            | pH, chlorine, flow                            | Continuous          |
| Reservoir                | level   | Continuous          |

<sup>&</sup>lt;sup>6</sup> Required by the Rules

<sup>&</sup>lt;sup>7</sup> Weekly manual sample verification unless required as part of event or issue response

<sup>&</sup>lt;sup>8</sup> Required by the Rules

| Site                         | Parameter                          | Frequency                               |
|------------------------------|------------------------------------|---|
| <sup>9</sup> Post reservoir  | FAC, pH, turbidity, flow, fluoride | Continuous                              |
| <sup>10</sup> Post reservoir | FAC, pH, turbidity, fluoride       | weekly                                  |
|                              | Aluminium                          | Based on typical<br>range <sup>11</sup> |

# Instrumentation Standardisation and verification

Set out in MANUAL 11 \_ Waingake and Waipaoa Calibration Work Instructions - Version 2, June 2011 (vA875006)

| Water Sup   | ply  | Hazardous Event   |  |  |  |
|-------------|--|---|--|--|--|
| Component   |  |   |  |  |  |
| Abstraction | Contamination at the intakes from maintenance/servicing work   |   |  |  |  |
|             |  | Contamination or loss of supply at the intakes or weir due to unintentional or intentional damage (vandalism)   |  |  |  |
|             |  | Loss of supply due to consents not being renewed or declined  |  |  |  |
|             |  | Loss of supply due to damage to the intakes or weir   |  |  |  |
|             |  | Loss of supply due to excessive build-up surrounding the intakes or weir  |  |  |  |
|             |  | Loss of supply due to loss of power at the intakes or weir  |  |  |  |
| Raw Wa      | ater   | Loss of supply due to damage to the raw water main  |  |  |  |
| Main & Pu   | ımp  | Loss of supply due to raw water main failure  |  |  |  |
| Stations    |  | Loss of supply due to damage to the pump stations   |  |  |  |
|             |  | Loss of supply due to loss of power at the pump stations  |  |  |  |
| Treatment   |  | Contamination or loss of supply due to <b>COAGULATION/FLOCCULATION</b> process failure (coagulant supply exhausted, dosing equipment failure, unsuitable quality of incoming water, incorrect dose rate, power failure)   |  |  |  |
|             |  | Contamination or loss of supply due to <b>FILTRATION</b> process failure (issue with preceding treatment process, backwash system failure, power failure, inadequate backwash reservoir level)  |  |  |  |
|             |  | Contamination due to <b>CHLORINE DISINFECTION</b> process failure - <b>inadequate chlorination</b> (issue with preceding treatment process, chlorine gas supply exhausted, dosing equipment failure, incorrect dose rate, service water issue, short contact time, power failure) |  |  |  |
|             | Contamination due to <b>CHLORINE DISINFECTION</b> process failure - <b>over chlorination</b> (issue with preceding treatment process, dosing equipment failure, incorrect dose rate, other contamination during servicing maintenance) |   |  |  |  |
|             | Contamination due to the chlorine reacting with raw water contaminants causing disinfection by-products  |   |  |  |  |
|             |  | Contamination due to <b>FLUORIDATION</b> process failure (dosing equipment failure, incorrect dose rate)  |  |  |  |
|             |  | Contamination or loss of supply due to unintentional or intentional vandalism of treatment systems  |  |  |  |
|             |  | Loss of supply due to service water system failure  |  |  |  |

# Summary of Treatment Hazards – Waingake WTP

<sup>&</sup>lt;sup>9</sup> Required by the Rules

<sup>&</sup>lt;sup>10</sup> Weekly manual sampling verification unless required as part of event or issue response

<sup>&</sup>lt;sup>11</sup> To be determined from 15 samples collected over 12 months. Frequency outlined in the Rules Table 33

| Water Supply<br>Component | Hazardous Event  |  |  |  |
|---------------------------|--|--|--|--|
|                           | Loss of supply due to compressed air system failure  |  |  |  |
| Storage                   | Contamination due to the integrity of reservoir being compromised - access by birds or vermin, or vandalism    |  |  |  |
|                           | Loss of storage capacity due to earthquake damage  |  |  |  |
|                           | Contamination or loss of supply due to a minor structural failure of reservoirs (including not being detected) |  |  |  |
|                           | Contamination from insanitary practices during inspections, observations, or maintenance of reservoir          |  |  |  |
|                           | Contamination from reservoir roof leakage  |  |  |  |

Table 4: Treatment Hazards for Waingake Water Treatment Plant

# 4.2 WAIPAOA WATER TREATMENT PLANT

# Waipaoa Treatment Plant Details

### Waipaoa Flow Diagram



# Waipaoa Abstraction

| Process Step  | Detail(s)          | Description  |
|---------------|--------------------|--|
| Waipaoa River | Description        | Two Johnson wedge wire screen 'tees' in river and<br>pumped into pre-sedimentation ponds. Three pumps<br>available for pumping. Air compressor onsite to run<br>screen cleans. |
|               | Abstraction method | In river intakes via pump  |
|               | Control            | Pump   |
|               | Online Monitoring  | Pump status and speed, flow to ponds. Intake backwash status. Pressure.  |
|               | Security           | Within private property and pump station within secure intake building.  |
|               | Backup power       | Connected to Waipaoa generator   |

# Waipaoa Treatment Summary

| Treatment &        | Storage  |  |                         |          |  |  |
|--------------------|--|--|-------------------------|----------|--|--|
| Treatment<br>Plant | Plant name                                     | Waipaoa WTP  |                         |          |  |  |
|                    | Treatment Processes                            | Presedimentation; Coagulation; Softening; Filtration; Chlorination;<br>UV Disinfection   |                         |          |  |  |
|                    | Treatment Processes                            | Log reduction value range (LRV) <sup>12</sup>  |                         |          |  |  |
|                    |  | Bacteria   | Viruses                 | Protozoa |  |  |
|                    | Presedimentation                               | 0.7-2.2  | 0                       | 1.4-2.3  |  |  |
|                    | Coagulation,<br>Flocculation,<br>Sedimentation | 0.2-2  | 0.1-3.4                 | 1-2      |  |  |
|                    | Rapid media filtration                         | 0.2-4.4  | 0-3.5                   | 0.4-3.3  |  |  |
|                    | Gas chlorination                               | 2  | 2                       | 0        |  |  |
|                    | UV Disinfection                                | 4  | 4                       | 4        |  |  |
|                    | Design capacity                                | 12,960 m³/day  |                         |          |  |  |
|                    | Daily flow average                             | 8,640 m <sup>3</sup> /day  |                         |          |  |  |
|                    | Chemicals added                                | Polyaluminium Chloride (PACl), Crystalfloc B570 (Poly), Chlorine Gas   |                         |          |  |  |
|                    | Standby chemical<br>dosing facilities          | Caustic Soda, Carbon Dioxide   |                         |          |  |  |
|                    | Bypasses                                       | WTP recirculation line is used during WTP start-up processes, but valves manually operated.<br>Other bypasses exist but are not actively used. |                         |          |  |  |
|                    | Security                                       | WTP is completely fenced and locked, limited access keys   |                         |          |  |  |
|                    | Power Supply                                   | Primary – Electricity N<br>Backup/standby – Dies   | etwork<br>sel generator |          |  |  |

<sup>&</sup>lt;sup>12</sup> LRVs based on Appendix 2 of the MoH WSP Handbook ( (Ministry of Health, 2019)

| Treatment &           | Storage                        |                                  |
|-----------------------|--------------------------------|----------------------------------|
| Storage<br>Reservoirs | Reservoir name (if applicable) | Clearwater Reservoir             |
|                       | Reservoir type                 | Treated water and backwash water |
|                       | Location                       | Waipaoa WTP Site                 |
|                       | Capacity                       | 1500m <sup>3</sup>               |
|                       | Sealed                         | Yes                              |
|                       | Vermin proof                   | Yes                              |
|                       | Run-off directed off<br>roof   | Yes                              |
|                       | Above/below ground             | Partially below ground           |

# Waipaoa Treatment Step Detail

| Process Step                                  | Detail(s)                  | Description   |
|---|----------------------------|---|
| Presedimentation<br>Ponds and Pump<br>Station | Description                | Two raw water presedimentation ponds and one<br>wastewater pond. Consent is held for supernatant from<br>wastewater pond discharges to the river and does not flow<br>into presedimentation ponds. Ponds used in parallel.<br>presedimentation Pump Station – Duty/standby pumps to<br>header.  |
|   | Control                    | Flow to and from each pond manually operated.<br>Split flow possible from Presed pump station to each<br>clarifier.   |
|   | Online Monitoring          | Ponds – Pond level, inflow.<br>Presed PS – Pond outflow, turbidity.   |
| Coagulation and<br>Clarification              | Description                | Graver and final clarifier. Used either in series or parallel depending on flow requirements. Dosed with PACI and polyelectrolyte.  |
|   | Control                    | Flow controlled by inlet flow meter. Dose rate manually adjusted.   |
|   | Online Monitoring          | PACL – Pump status, speed, dosage, and stroke. Transfer<br>pump status.<br>Poly – Pump status, speed, and stroke position. Mixer<br>status. Poly make up system fault.  |
|   | Under/overdose<br>controls | Day tanks for both Poly and PACI limit total volume<br>available.<br>'Stubbe' pressure valves in place.<br>Daily checks on calculated chemical consumption.   |
| Water softening                               | Description                | Sodium hydroxide (Caustic) and Carbon Dioxide used to<br>reduce the hardness of Waipaoa River water at times when<br>raw water levels are high. Additional option to GDC of<br>blending Waipaoa treated water with Waingake treated<br>water. Only used when required and monitored daily at<br>Venturi site. Able to be used in series or parallel depending<br>on requirements. |
|   | Control                    | Dose pre-set as per 'scenario A-F' from Chemical Operations Manual.   |

| Process Step                     | Detail(s)                  | Description  |
|----------------------------------|----------------------------|--|
|                                  | Online Monitoring          | pH level at Graver reactivator, Final Clarifier and Hydro column.  |
|                                  | Under/overdose controls    | 'Stubbe' pressure valves in place.   |
| Rapid Gravity Sand<br>Filtration | Description                | Four filters. 2.8 m of graded sand (1.4-2.8 mm). Backwash with combination air/water (10 mins air/water and 5 mins water only) with Backwash Tank water (500 m <sup>3</sup> ). |
|                                  | Control                    | Inlet flow control by hydro column, inlet valve.<br>Outlet flow control by float arm and outlet valve.<br>Backwash initiated on time, filter head loss, or turbidity.          |
|                                  | Online Monitoring          | Individual and combined filter turbidity, valve position<br>(inlet and outlet)   |
| Chlorination & pH<br>Adjustment  | Description                | Chlorine gas 920 kg drum. 1 x duty 1 x standby. Drums<br>sitting on scales measured for weight.<br>Duty & standby chlorinators.  |
|                                  | Contact time               | Minimum of 15 at 0.5mg/l FAC and 50% reservoir level.  |
|                                  | Control                    | Chlorine dosing is flow proportional   |
|                                  | Online Monitoring          | FAC level at the FWS outlet and CWR outlet<br>Chlorinator status   |
|                                  | Under/overdose<br>controls | Daily checks on calculated chemical consumption and<br>chlorinators.<br>Alarms linked to FAC level with automated response built<br>in (City Pumps shut down)                  |
| UV disinfection                  | Description                | Two UV reactors validated to dose at least 40 mJ/cm <sup>2</sup> .<br>Automatically adjusts UV intensity based on UVT levels.  |
|                                  | Control                    | UV controller.   |
|                                  | Online Monitoring          | UV Transmittance, valve position, UV Dose, UV Fault, UV flow, total hours per reactor.   |
| City Pumps                       | Description                | Flow booster pump stations. Two pumps in duty/standby arrangement.   |
|                                  | Control                    | Connected to telemetry and online control systems in place.  |
|                                  | Online Monitoring          | Pressure, flow.  |

# Water Quality Analysis

| Parameter                        | Site    | Results     |          |
|----------------------------------|---------|-------------|----------|
| DWSNZ MAV                        |         | <1          | >1       |
| E. coli (dataset from 2015-2021) | Waipaoa | 274 samples | 1 sample |

# **Contamination Barrier Management**

SOPs and corrective actions

- MANUAL 01\_ Waingake\_Waipaoa WTP Quality Management System Version 5, September 2012 (A297912)
- MANUAL 08 \_ Waipaoa Plant Work Instructions Version 3, December 2013 (vA875001)
- MANUAL 09 \_ Waipaoa Chemical Plant Work Instructions Version 2, September 2013 (vA1490869)
- MANUAL 10 \_ Waingake & Waipaoa Laboratory Manual Version 2, September 2010 (vA875005)

### Inspections

See inspections outlined in SOPs above.

#### Maintenance

Set out in:

- MANUAL 11 \_ Waingake and Waipaoa Calibration Work Instructions Version 2, June 2011 (vA875006)
- Development and implementation of a formalised Operational Maintenance Plan is an improvement item in the Organisational WSP.

#### **Verification Monitoring and Performance Criteria**

The Action & Reporting Protocol Critical Control Point & Process Control Summaries which sets out the limits and corresponding corrective actions.

| Site                      | Parameter                                   | Frequency                            |
|---------------------------|---|--------------------------------------|
| <sup>13</sup> Raw water   | Turbidity                                   | Continuous                           |
| <sup>14</sup> Post filter | Flow, run time, turbidity, head loss        | Continuous                           |
| Pre reservoir             | UV dose, UVT, pH, chlorine, flow, turbidity | Continuous                           |
| Reservoir                 | level                                       | Continuous                           |
| Post reservoir            | FAC   | Continuous                           |
|                           | рН  | Continuous                           |
|                           | Flow  | Continuous                           |
|                           | Aluminium                                   | Based on typical range <sup>15</sup> |

# Instrumentation Standardisation and Verification

Set out in MANUAL 11 \_ Waingake and Waipaoa Calibration Work Instructions - Version 2, June 2011 (vA875006)

#### Summary of Treatment Hazards – Waipaoa

| Water Supply<br>Component | Hazardous Event   |
|---------------------------|---|
| Abstraction               | Contamination at the intakes from maintenance/servicing work  |
|                           | Contamination or loss of supply at the intakes due to unintentional or intentional damage (vandalism)                 |
|                           | Loss of supply due to consents not being renewed or declined  |
|                           | Loss of supply due to damage to the intakes   |
|                           | Loss of supply due to excessive build-up surrounding the intakes  |
|                           | Loss of supply due to loss of power at the intakes  |
| Treatment                 | Contamination or loss of supply due to <b>PRESEDIMENTATION</b> process failure (unsuitable quality of incoming water) |

<sup>&</sup>lt;sup>13</sup> pH and conductivity also required under the new Rules

<sup>&</sup>lt;sup>14</sup> Turbidity, flow, UV dose & UVT is required under the Rules

<sup>&</sup>lt;sup>15</sup> To be determined from 15 samples collected over 12 months. Frequency outlined in the Rules Table 33

| Water Supp   | ly Hazardous Event  |  |  |  |
|--|---|--|--|--|
| Component  |   |  |  |  |
|  | Contamination or loss of supply due to <b>COAGULATION/FLOCCULATION</b> process failure (issue with preceding treatment process, coagulant supply exhausted, dosing equipment failure, incorrect dose rate, power failure)   |  |  |  |
|  | Contamination or loss of supply due to <b>SOFTENING</b> process failure (issue with preceding treatment process, caustic dosing equipment failure, incorrect dose rate, power failure)  |  |  |  |
|  | Contamination or loss of supply due to <b>FILTRATION</b> process failure (issue with preceding treatment process, backwash system failure, power failure, inadequate CWR level)   |  |  |  |
|  | Contamination due to <b>CHLORINE DISINFECTION</b> process failure - <b>inadequate chlorination</b> (issue with preceding treatment process, chlorine gas supply exhausted, dosing equipment failure, incorrect dose rate, service water issue, short contact time, power failure) |  |  |  |
|  | Contamination due to <b>CHLORINE DISINFECTION</b> process failure - <b>over chlorination</b> (issue with preceding treatment process, dosing equipment failure, incorrect dose rate, other contamination during servicing maintenance)  |  |  |  |
| Contamination due to the chlorine reacting with raw water contamination disinfection by-products |   |  |  |  |
|  | Contamination or loss of supply due to UV DISINFECTION process failure (issue with preceding treatment process, UV reactor failure, power failure)  |  |  |  |
|  | Contamination or loss of supply due to unintentional or intentional vandalism of treatment systems  |  |  |  |
|  | Contamination or loss of supply due to WTP bypass system failure  |  |  |  |
|  | Loss of supply due to service water system failure  |  |  |  |
|  | Loss of supply due to compressed air system failure   |  |  |  |
| Reservoirs   | Contamination due to the integrity of reservoir being compromised - access by birds or vermin, or vandalism   |  |  |  |
|  | Loss of storage capacity due to earthquake damage   |  |  |  |
|  | Contamination or loss of supply due to a minor structural failure of reservoirs (including not being detected)  |  |  |  |
|  | Contamination from insanitary practices during inspections, observations, or maintenance of reservoir   |  |  |  |
|  | Contamination from reservoir roof leakage   |  |  |  |

 Table 5: Treatment Hazards for Waipaoa Water Treatment Plant

# **5 DISTRIBUTION NETWORK**

Barrier to contamination (Water Services Act Section 31(2)(d)): Maintain the quality of water in the Distribution Network system – applies to the WTP Outlets through to the customer point of supply (Toby/Meter). This includes the trunk mains, City Storage Reservoirs, pump stations and chlorine booster.

The Gisborne supply has two zones; Gisborne Rural Zone (GIS001RU) and Gisborne City Zone (GIS001GI)

# **Rural Zone**

The Rural Zone covers the reticulated area (pipes in blue) between the Waingake WTP and the City Zone (shown in white).



# **City Zone**

The City Zone covers all of the customers within the reticulated services boundary area and the customers on Centennial Marine Parade.



- .

Land Information

Copyright under Construct Constructions 4.0 International licence May conscional associated from the LINE Data General SIGPLASS of Charloss Charles Council

# **GISBORNE SUPPLY DISTRIBUTION NETWORK**

# **Distribution Network Summary**

| Process Step  | Detail(s)              | Description  |
|---|------------------------|--|
| General   | Zone name(s)           | Gisborne City, Gisborne Rural  |
| Distribution  | Zone Population        | 39,000 (Taumata Arowai, 2022)  |
|   | Pipe materials         | 274 km pipe; AC (28%), Cast iron (22%), Polyethylene (26%),<br>Steel (17%), PVC (6%), other (1%)   |
|   | Connections            | 13,023   |
|   | Backflow<br>preventers | RPZ: 305<br>Non-testable: 4564 with installations continuing for the next 5<br>years.  |
| Treated Water<br>Trunk Main<br>(Waingake WTP to<br>Makaraka PS) | Description            | 525 mm CLMS. Largely buried. Many pipe bridges. Sections<br>exposed to atmosphere. Cathodic protection installed. Passing<br>through grazing land. Air valves and multiple scour points in<br>place.<br>Major crossing over Waingake River and Waipaoa River.            |
|   | Online Monitoring      | None   |
|   | Security               | Asset location well known. Marker posts installed.   |
| Makaraka Pump<br>Station  | Description            | Flow booster pump station. Three pumps in duty/duty/standby<br>arrangement for flows >700 m3/hr. Bermad main control valve<br>for <700 m3/hr and 'Zero at Makaraka'. Bermad works in<br>conjunction with bypass valve to pumps).<br>Minimum suction pressure is 200 kPa. |
|   | Control                | Bermad valve and pumps all connected to telemetry. VSDs on each pump and manual isolation valve.   |
|   | Online Monitoring      | Pressure (suction and delivery), Flow, valve position and pump status.   |
|   | Security               | Secure and locked building. All fragile assets within the building.  |
|   | Backup power           | None. Gravity flow up to 700 m <sup>3</sup> /hr possible.  |
| Ormond Rd Pump<br>Station                                       | Description            | Flow booster pump station. One pump to boost flow to Nob Hill Reservoir.   |
|   | Control                | Pump connected to telemetry. VSDs on pump and manual isolation valves available.   |
|   | Online Monitoring      | Pressure (suction and delivery) and pump status.   |
|   | Security               | Secure and locked cabinets and pump below ground in a suitable pit. All fragile assets adequately protected.   |
|   | Backup power           | None. Gravity flow still possible.   |
| Hillview Terrace<br>Pump Station                                | Description            | High level pump station for the area surrounding Hospital Hill Reservoir. Three pumps in duty/standby and another pumps for fire flows (assist).   |
|   | Control                | Pumps connected to telemetry. VSDs on pumps and manual isolation valves available.   |
|   | Online Monitoring      | Pressure (suction and delivery) and pump status all monitored locally (i.e., not connected to telemetry)   |

| Process Step                  | Detail(s)                  | Description   |
|-------------------------------|----------------------------|---|
|                               | Security                   | Secure and locked building. All fragile assets within the building.   |
|                               | Backup power               | Standby generator onsite and connected.   |
| High Level Pump<br>Stations   | Description                | High level pump stations for the elevated areas in the Gisborne<br>City Distribution Network (Hill Rd, Hauroa, Rd, Gaddums Hill,<br>Pah Hill). Each pump station has a single pump that boosts flow<br>to the upper reservoirs.   |
|                               | Control                    | Pumps connected to local controller only based on delivery pressure level. No telemetry.  |
|                               | Online Monitoring          | None  |
|                               | Security                   | Secure and locked buildings. All fragile assets within the building.  |
|                               | Backup power               | None  |
| Taumata Pump<br>Station       | Description                | Pump station to fill Taumata Reservoir. One old pump<br>available. One way flow is the normal setup as Taumata<br>Reservoir is for emergency supply ONLY.   |
|                               | Control                    | Pump control and valves all manually operated/initiated.  |
|                               | Online Monitoring          | None  |
|                               | Security                   | Secure and locked buildings. All fragile assets within the building.  |
|                               | Backup power               | None.   |
| Hospital Hill<br>Reservoir    | Description                | Large rectangular reservoir with two cells. Full capacity is 38,000m <sup>3</sup> (19,000m <sup>3</sup> each cell). Reservoir partially below ground with underdrains piped to a single collection point. Onsite chlorination in place to increase FAC levels of outgoing stored water (see Hospital Hill Chlorination section for further details). Operating ranges for the cells combined are 20,000 m <sup>3</sup> to full. |
|                               | Control                    | Inflow = SCADA and determined by Distribution Network   |
|                               | Online monitoring          | Level, inflow/outflow   |
|                               | Security                   | Sealed, vermin proof and locked access hatches.   |
|                               | Backup Power               | None required   |
| Hospital Hill<br>Chlorination | Description                | Chlorine gas 70 kg cylinders. 1 x duty 1 x standby. Cylinders<br>sitting on scales measured for weight.<br>Duty & standby chlorinators. High and low-rate chlorinators<br>(setpoints 1.0 and 0.8 g/m <sup>3</sup> respectively). Duty & standby carry<br>water and sample pumps.  |
|                               | Contact time               | Minimal however chlorination used to boost base chlorine level when required.   |
|                               | Control                    | Chlorine dosing is based on online monitoring FAC result  |
|                               | Online Monitoring          | FAC level at the outlet of reservoir<br>Chlorination system status  |
|                               | Under/overdose<br>controls | Weekly calibration checks on FAC level.<br>High rate and low-rate chlorinators ensure appropriate dose<br>rate is used.   |

| Process Step             | Detail(s)         | Description   |  |  |
|--------------------------|-------------------|---|--|--|
| Nob Hill Reservoir       | Description       | Large circular reservoir with a maximum capacity of 8,000m <sup>3</sup> .<br>Reservoir above ground and filled mostly by running Ormond<br>Rd Pump Station in high demand periods, and at night in low<br>demand periods. Around 620 kPa is required in the network for<br>Nob Hill to fill (measured at Birrell St, Hansen Rd and Anzac St).<br>Operating ranges are 4,000 m <sup>3</sup> to full.   |  |  |
|                          | Control           | DescriptionLarge circular reservoir with a maximum capacity of 8,000m3.<br>Reservoir above ground and filled mostly by running Ormond<br>Rd Pump Station in high demand periods, and at night in low<br>demand periods. Around 620 kPa is required in the network for<br>Nob Hill to fill (measured at Birrell St, Hansen Rd and Anzac St).<br>Operating ranges are 4,000 m3 to full.Inflow = determined by Distribution Network pressure and in<br>some cases the operation of the Ormond Rd Pump Station.<br>Level, inflow/outflowSealed, vermin proof and locked access hatches. Gate to access<br>drive is locked also.None requiredVarious 22.5m3 reservoirs in the more elevated area of the<br>Distribution Network. Some pumped and some not.<br>Sites are Hill Rd (upper tanks), Hauroa Rd (upper and lower<br>tanks), Gaddums Hill (upper tanks), Einstein (no<br>pump and upper tank), Pa Hill (upper tanks).Filled by adequate Distribution network pressure or when<br>upper tanks are at a level of <50%. |  |  |
|                          | Online monitoring | Level, inflow/outflow   |  |  |
|                          | Security          | Sealed, vermin proof and locked access hatches. Gate to access drive is locked also.  |  |  |
|                          | Backup Power      | None required   |  |  |
| High Level<br>Reservoirs | Description       | Various 22.5m <sup>3</sup> reservoirs in the more elevated area of the<br>Distribution Network. Some pumped and some not.<br>Sites are Hill Rd (upper tanks), Hauroa Rd (upper and lowe<br>tanks), Gaddums Hill (upper and lower tanks), Einstein (n<br>pump and upper tank), Pa Hill (upper tanks).  |  |  |
|                          | Control           | Filled by adequate Distribution network pressure or when upper tanks are at a level of <50%.  |  |  |
|                          | Online monitoring | None  |  |  |
|                          | Security          | Sealed, vermin proof and locked access hatches.   |  |  |
|                          | Backup Power      | None required   |  |  |
| Taumata Reservoir        | Description       | Offline emergency storage reservoir with a maximum capacity of 3,800m <sup>3</sup> . Periodically scoured to waste and refilled. EMERGENCY ONLY.  |  |  |
|                          | Control           | Pump control and valves all manually operated/initiated.  |  |  |
|                          | Online monitoring | None  |  |  |
|                          | Security          | Locked access hatches but not sealed or vermin proof.   |  |  |
|                          | Backup Power      | None required   |  |  |

# Water Quality Analysis

Summary of Watercare Laboratory Services 'Annual Chemistry Screening – Campion Venturi' results from 2018-2021.

| Test      | MAV   | GV  | 2018     | 2019     | 2020     | 2021     | 2022    |
|-----------|-------|-----|----------|----------|----------|----------|---------|
| Aluminium |       | 0.1 | 0.052    | 0.074    | 0.1      | 0.085    | 0.097   |
| Antimony  | 0.02  |     | <0.001   | <0.001   | <0.001   | <0.001   | <0.001  |
| Arsenic   | 0.01  |     | 0.0002   | 0.00018  | 0.0002   | 0.00024  | 0.00031 |
| Barium    | 0.7   |     | 0.0062   | 0.0088   | 0.01     | 0.0089   | 0.01    |
| Boron     | 1.4   |     | 0.019    | 0.031    | 0.031    | 0.027    | 0.026   |
| Bromate   | 0.01  |     | <0.005   | <0.005   | <0.005   | <0.005   | <0.005  |
| Cadmium   | 0.004 |     | <0.00005 | <0.00005 | <0.00005 | <0.00005 | <0.0005 |

| Test               | MAV   | GV         | 2018     | 2019     | 2020     | 2021     | 2022     |
|--------------------|-------|------------|----------|----------|----------|----------|----------|
| Chlorate           | 0.8   |            | <0.01    | <0.01    | <0.01    | <0.01    | <0.01    |
| Chlorite           | 0.8   |            | <0.005   | <0.005   | <0.005   | <0.005   | <0.005   |
| Chromium           | 0.05  |            | <0.0005  | <0.0005  | <0.0005  | <0.0005  | <0.0005  |
| Copper             | 2     | 1          | 0.00044  | 0.0021   | 0.00095  | 0.00092  | 0.006    |
| Cyanide            | 0.6   |            | <0.005   | <0.005   | <0.005   | <0.005   | -        |
| Fluoride           | 1.5   |            | 0.6      | 0.6      | 0.55     | 0.53     | 0.4      |
| Lead               | 0.01  |            | <0.0001  | <0.0001  | <0.0001  | <0.0001  | <0.0001  |
| Manganese          | 0.4   | 0.04 & 0.1 | 0.00077  | 0.0011   | 0.00054  | <0.0005  | 0.00096  |
| Mercury            | 0.007 |            | <0.00005 | <0.00005 | <0.00005 | <0.00005 | <0.0005  |
| Molybdenum         | 0.07  |            | <0.0003  | <0.0003  | <0.0003  | <0.0003  | <0.0003  |
| Nickel             | 0.08  |            | <0.0001  | <0.0001  | <0.0001  | 0.00025  | <0.00005 |
| Nitrate            | 50    |            | 0.025    | 0.017    | 0.013    | 0.0076   | 0.031    |
| Nitrite (long)     | 0.2   |            | <0.002   | <0.002   | <0.002   | <0.002   | <0.007   |
| Nitrite<br>(short) | 3     |            | <0.002   | <0.002   | <0.002   | <0.002   | -        |
| Selenium           | 0.01  |            | <0.0005  | <0.0005  | <0.0005  | <0.0005  | <0.0005  |
| Uranium            | 0.02  |            | <0.00001 | 0.000031 | 0.000016 | 0.000018 | 0.000021 |

Summary of Verification Venturi Monitoring from 2020-2022.

|   | Waingake blend | Waingake & Waipaoa blend |
|---|----------------|--------------------------|
| рН  | 7.58           | 7.71                     |
| Conductivity (μS/cm at 25 °C)                           | 191.5          | 359.71                   |
| Hardness (CaCO <sub>3</sub> ) (g/m <sup>3</sup> )       | 40.56          | 77.14                    |
| Total Hardness (CaCO <sub>3</sub> ) (g/m <sup>3</sup> ) | 57.2           | 105.25                   |
| FAC (g/m <sup>3</sup> )                                 | 0.96           | 0.85                     |
| Fluoride (g/m <sup>3</sup> )                            | 0.57           | 0.57                     |
| Total Alkalinity CaCO₃(g/m³)                            | 54.33          | 92.22                    |
| Temperature (°C)  | 14.79          | 19.02                    |
| Total Dissolved Solids (TDS) (g/m <sup>3</sup> )        | 124.43         | 233.76                   |
| Langelier Saturation Index (LSI)                        | -0.98          | -0.31                    |
| Turbidity (NTU)   | 0.12           | 0.11                     |

# **Barrier Management**

SOPs and corrective actions

- Fulton Hogan OMMPs Work Packages 01-17
- EW10\_02\_ Scheduled Engineering Maintenance Procedure For Water Assets (A406279)
- MANUAL 01\_ Waingake\_Waipaoa WTP Quality Management System Version 5, September 2012 (A297912)
- MANUAL 05\_ Trunk Water Main Emergency Response Plan Version 4, January 2011 (vA874947)
- MANUAL 14\_ Water Supply Pump Station Operations Version 1, November 2004 (vA1347789)

### Inspections

See inspections outlined in SOPs above.

#### Maintenance

See maintenance outlined in SOPs above. The development and implementation of a formalised Operational Maintenance Plan is an improvement item in the Organisational WSP.

### **Verification Monitoring and Performance Criteria**

See Monitoring, Action & Reporting Protocol for monitoring required under the Rules. Also see 'GDC Water Supply Water Quality Monitoring Program Protocols (A788953)' for additional information.

| Site                                 | Parameter  | Frequency                        |
|--------------------------------------|--|----------------------------------|
|                                      | pH, Total Alkalinity, Conductivity, Turbidity, Hardness (Ca and<br>Total), Temperature, FAC, TDS, Fluoride, LSI  | Monday-Friday                    |
| Venturi                              | Turbidity, FAC & pH  | Continuous                       |
|                                      | E. coli, FAC, pH, Aluminium, Temperature   | Monthly                          |
| Muriwai                              | FAC, pH  | Continuous                       |
| Dunstan Rd                           | FAC, pH  | Continuous                       |
| Hospital Hill                        | FAC, pH  | Continuous                       |
| Nob Hill                             | FAC, pH  | Continuous                       |
| Distribution Sampling<br>Points      | E. coli, FAC, pH, Temperature  | As per schedule                  |
| Reservoirs (large)                   | FAC  | Weekly                           |
| Birrell St, Hansen Rd,<br>Anzac Park | Network pressure   | Continuous                       |
| Pump stations                        | See summary tables   |                                  |
| Rural Zone <sup>16</sup>             | E.coli, Total Coliforms, FAC, Trihalomethanes: chloroform,   |                                  |
| City Zone <sup>16</sup>              | bromodichloromethane, dibromochloromethane, bromofor<br><u>acids:</u> dichloroacetic acid, trichloroacetic acid; Antimony, ca<br>chromium, copper, lead, mercury, nickel, zinc | rm, <u>Haloacetic</u><br>admium, |

<sup>&</sup>lt;sup>16</sup> Monitoring sites are in the 'GDC Water Supply Water Quality Monitoring Program Protocols (A788953)' Monitoring frequencies are in the Monitoring, Action & Reporting Protocol

# **Contractor Performance criteria**

Performance criteria for the distribution network is generally defined in Fulton Hogans 'work packages' (OMMPs), Fulton Hogan contract KPIs, and by the Department of Internal Affairs 'Non-Financial Performance Measures'.

# Instrumentation Standardisation and verification

Set out in MANUAL 11 \_ Waingake and Waipaoa Calibration Work Instructions - Version 2, June 2011 (vA875006)

### **Summary of Distribution Network Hazards**

| Water Supply<br>Component                                | Hazardous Event   |
|--|---|
| Distribution   | Contamination or loss of supply due to failure/damage to bulk treated water main  |
| Network –<br>Treated Water<br>Trunk Main<br>(Waingake to | Contamination from insanitary practices during maintenance or construction on bulk treated water mains  |
|  | Loss of supply due to inaccurate/insufficient asset information (material, location, condition, criticality, scour valves, air valves)  |
| widkalaka)   | Loss of supply due to air relief valve inoperability on the bulk treated water main   |
|  | Loss of supply due to unidentified leakage, illegal connections, unaccounted for water or high demand from the bulk treated water main  |
|  | Contamination from backflow event within bulk treated water main  |
|  | Loss of supply due to excessive demand, inadequate or excessive pressures in the bulk treated water main  |
|  | Contamination due to poor quality workmanship, inappropriate materials used or contractor damage to bulk treated water main   |
| Distribution<br>Network                                  | Contamination or loss of supply due to Distribution Network failure   |
|  | Contamination from insanitary practices during inspections, sampling, maintenance, or construction within Distribution Network system   |
|  | Loss of supply due to inaccurate/insufficient asset information (material, location, condition, criticality)  |
|  | Loss of supply due to unidentified leakage, illegal connections or unaccounted for water  |
|  | Contamination from backflow event within Distribution Network system (including change of premise use)  |
|  | Loss of supply due to excessive demand, inadequate or excessive pressures in the network or a lack of agreed allocation to large users  |
|  | Contamination due to poor quality workmanship, inappropriate materials used for Distribution Network pipes and fittings or contractor damage to pipes   |
|  | Contamination due to extent of Distribution network (pipeline to Muriwai and Patutahi)  |
| Distribution<br>Network –<br>Pump Stations               | Contamination or loss of supply due to damage to the pump stations  |
|  | Loss of supply due to loss of power at the pump stations  |
|  | Contamination from insanitary practices during maintenance or construction within pump stations   |
|  | Loss of supply due to excessive demand, inadequate or excessive pressures in the network  |
|  | Contamination due to Chlorine Disinfection process failure - inadequate chlorination (issue with stored water in reservoir, chlorine gas supply exhausted, dosing equipment failure, incorrect dose rate, service water issue, power failure) |

| Water Supply<br>Component | Hazardous Event  |
|---------------------------|--|
|                           | Contamination due to Chlorine Disinfection process failure - over chlorination (dosing equipment failure, incorrect dose rate, other contamination during servicing maintenance) |
| Distribution<br>Network – | Contamination due to the integrity of reservoir being compromised - access by birds or vermin, or vandalism  |
| Reservoirs                | Loss of storage capacity due to earthquake damage  |
|                           | Contamination or loss of supply due to a minor structural failure of reservoirs (including not being detected)   |
|                           | Contamination from insanitary practices during inspections, observations, or maintenance of reservoir  |
|                           | Contamination from reservoir roof leakage  |

Table 6: Distribution Network Hazards for Gisborne Distribution Network

# **6 GENERAL HAZARDS**

The table below summarises hazardous events that are managed across the organisation and apply to all WSPs. They have been risk assessed once and are only included in the Gisborne Water Supply WSP Risk Assessment.

| Water Supply<br>Component | Hazardous Event   |
|---------------------------|---|
| Barrier Management        | Loss of supply due to inaccurate/insufficient asset information (material, location, condition, criticality)  |
|                           | Contamination or loss of supply due to insufficient, inadequate out of date or incorrect manuals, operational procedures or Quality Management System   |
|                           | Contamination or loss of supply due to inadequate critical spare parts held or unavailable  |
|                           | Contamination or loss of supply due to inadequate training, professional development, up-skilling, or ongoing competency of water staff (Council and Contractors)   |
|                           | Contamination or loss of supply due to inadequate staff resourcing (includes subcontractors)  |
|                           | Contamination or loss of supply due to inadequate inspections, preventive maintenance or replacement of critical treatment systems and monitoring equipment causing failures  |
|                           | Contamination or loss of supply due to inadequate inspections, Preventive maintenance, or replacement of critical treatment structures (intake, dams, treatment systems, reservoirs (WTP), bulk raw/treated main, reservoirs (Distribution Network)) causing failures |
|                           | Contamination or loss of supply due to inadequate water staff performance or reliability (both Council and Contractors)   |
|                           | Contamination or loss of supply due to supply chain issues (i.e. chemicals, equipment)  |
| Verification              | Contamination is not identified due to sampling and monitoring not being sufficient   |
| Monitoring                | Contamination or loss or supply not identified due to inadequate data collection and reporting systems (includes PLC, SCADA, and communications systems)  |
|                           | Contamination not identified or loss of supply due to critical instrumentation failure  |
|                           | Contamination not identified due to incorrect setup of critical instrumentation during commissioning (span, calibration, flow rates etc.)   |
|                           | Contamination not identified due to critical instrumentation drift over time  |
|                           | Contamination or loss of supply due to inadequate reporting from observations, inspections or maintenance   |
| Other                     | Contamination due to inadequate treatment processes   |
|                           | Loss of supply due to major structural failure of critical structures (Dams, intakes, pump stations, Water Treatment Plants, Reservoirs)  |
|                           | Contamination or loss of supply due to a catastrophic natural disaster or failure including earthquake, flooding, volcanic eruption, wildfire, extreme weather events.  |
|                           | Contamination or loss of supply due to changes in legislation, standards, organisational policy, district plan changes, bylaws, codes of practices or any other activity  |
|                           | Loss of supply due to limitations in the capacity of available sources, treatment systems, and water delivery   |

Table 7: General Hazards for GDC Water Supply
# 7 RISK SUMMARY AND IMPROVEMENTS

This WSP and the risk tables have been prepared as outlined in the **Gisborne District Council Organisational WSP Section 5**.

The purpose of the risk tables is to provide detailed information to be used in managing hazards linked to the individual supply components. The hazards are identified in section 4, section 5 and section 6 of this Gisborne Supply WSP.

There are 117 hazards identified and risk assessed. Fourteen (14) carry an unacceptable risk status.

An unacceptable risk is determined if the residual risk level is classified as 'High' or 'Extreme' and comes with recommended management actions.

The risks tables are grouped by supply component and a summary of all **unacceptable** residual risk and the corresponding improvements relating to the **Gisborne Water Supply** are listed below. The list of improvements are included in the Improvement Plan - Gisborne District Council Organisational WSP Appendix A.

The full risk tables for all components for the **Gisborne Water Supply** have been included in Appendix A.

| ID | Supply<br>Component | Process Step                   | Hazardous Event  | Consideration for Residual Risk Level  | Residual<br>Risk | Improvements  |
|----|---------------------|--------------------------------|--|--|------------------|---|
| 4  | Waingake            | Catchment -<br>Mangapoike Dams | Naturally occurring<br>contaminants present -<br>includes high turbidity,<br>cyanobacteria | Sampling and inspection<br>programme to be re-established<br>and reviewed to ascertain<br>current risk level.<br>Cyanotoxin Management Plan<br>needs updating. | Unacceptable     | Review monitoring programme and align with<br>finalised Quality Assurance Rules. Update the<br>Monitoring, Actions and Reporting Protocol<br>Update Cyanobacteria Management and Response<br>Plan<br>Waingake Transformation Programme (transition to<br>70% native vegetation) |
| 13 | Waingake            | Catchment -<br>Waingake River  | Naturally occurring<br>contaminants present -<br>includes high turbidity,<br>cyanobacteria | Sampling and inspection<br>programme to be re-established<br>and reviewed to ascertain<br>current risk level.<br>Cyanotoxin Management Plan<br>needs updating. | Unacceptable     | Review monitoring programme and align with<br>finalised Quality Assurance Rules. Update the<br>Monitoring, Actions and Reporting Protocol<br>Update Cyanobacteria Management and Response<br>Plan<br>Waingake Transformation Programme (transition to<br>70% native vegetation) |

| ID | Supply<br>Component     | Process Step   | Hazardous Event   | Consideration for Residual Risk Level   | Residual<br>Risk | Improvements  |
|----|-------------------------|--|---|---|------------------|---|
| 19 | Waipaoa                 | Catchment -<br>Waipaoa River   | Contamination in the<br>source water catchment<br>from agricultural<br>practices (includes<br>pesticides, fertilisers,<br>farm operations, dairy,<br>effluent, and grazing) | Sampling and inspection<br>programme to be re-established<br>and reviewed to ascertain<br>current risk level.   | Unacceptable     | Review monitoring programme and align with<br>finalised Quality Assurance Rules. Update the<br>Monitoring, Actions and Reporting Protocol                           |
| 72 | Distribution<br>Network | Distribution<br>Network – Treated<br>Water Trunk Main<br>(Waingake to<br>Makaraka) | Contamination or loss of<br>supply due to<br>failure/damage to bulk<br>treated water main   | Pipe age, condition and<br>accessibility.<br>Level of supplier control over<br>natural events and land use<br>activity along pipeline route.                          | Unacceptable     | Trunk main refurb – includes above ground sections<br>and pipe bridges.<br>Maintain stocks of critical spares.  |
| 84 | Distribution<br>Network | Distribution<br>Network  | Contamination from<br>backflow event within<br>Distribution Network<br>system (including change<br>of premise use)  | Staff resourcing is limited to have<br>a sustained focus on this area.<br>Backflow prevention programme<br>is incomplete for commercial and<br>industrial activities. | Unacceptable     | Increase FTE for Distribution Network protection<br>Consolidate existing Backflow information, identify<br>gaps and compile programme that clearly manages<br>risk. |

| ID | Supply<br>Component     | Process Step            | Hazardous Event  | Consideration for Residual Risk Level   | Residual<br>Risk | Improvements   |
|----|-------------------------|-------------------------|--|---|------------------|--|
| 85 | Distribution<br>Network | Distribution<br>Network | Loss of supply due to<br>excessive demand,<br>inadequate or excessive<br>pressures in the network<br>or a lack of agreed<br>allocation to large users.   | Large users are not limited in<br>their use at times of higher<br>demand.<br>Loss of pressure Matawhero<br>&Makaraka during peak demand.<br>Low FAC issues in eastern area of<br>Distribution Network system. | Unacceptable     | <ul> <li>Prepare and implement a water loss strategy.</li> <li>Review water supply Bylaw for types of connections<br/>and allocation limits or levels of service.</li> <li>New trunk main for Nob Hill. Review growth<br/>scenarios requiring additional reservoir storage.</li> <li>Review pressure within the Distribution Network-</li> <li>Ormond Rd pump station use.</li> <li>Scope pressure zoning of network.</li> <li>New booster pump station at base of Nob Hill.<br/>Decommission Ormond Road pump station.</li> <li>New Papatu Rd booster Pump Station (additional<br/>to the Makaraka Pump Station).</li> <li>Remove Pa Hill reservoirs and install a pump system<br/>for the higher area.</li> <li>Implementation of universal water metering.</li> </ul> |
| 87 | Distribution<br>Network | Distribution<br>Network | Contamination or loss of<br>supply due to degrading<br>treated water supply<br>caused by the extent of<br>Distribution Network<br>network including<br>pipelines to Muriwai and<br>Patutahi, city low FAC<br>areas | Low FAC issues in eastern area of Distribution Network system.  | Unacceptable     | Increase chlorine residual in water leaving<br>treatment plant.<br>Gas chlorination facility at Nob Hill.<br>Install online FAC monitors at Nob Hill, Muriwai,<br>Dunstan Rd and Patutahi to meet new water quality<br>assurance rules.  |

| ID  | Supply<br>Component | Process Step               | Hazardous Event   | Consideration for Residual Risk Level  | Residual<br>Risk | Improvements  |
|-----|---------------------|----------------------------|---|--|------------------|---|
| 102 | General             | Barrier<br>Management      | Contamination or loss of<br>supply due to inadequate<br>training, professional<br>development, up-skilling,<br>or ongoing competency<br>of water staff (Council<br>and Contractors)         | FH retic staff turnover high and<br>new staff still learning GDCs<br>requirements  | Unacceptable     | Update the Water staff training and competency<br>framework to include continuous professional<br>development and assessment of ongoing<br>competency.<br>Complete audits of contracted services and training<br>for contracted staff.                            |
| 103 | General             | Barrier<br>Management      | Contamination or loss of<br>supply due to inadequate<br>staff resourcing (includes<br>subcontractors)   | FH retic staff turnover high<br>Increased work with WSP<br>framework and environmental<br>performance measures   | Unacceptable     | Increase FTE for treatment plant cadet/operator<br>Increase FTE for technical data management and<br>administration of WSP.   |
| 107 | General             | Verification<br>Monitoring | Contamination is not<br>identified due to<br>sampling and monitoring<br>not being sufficient  | New quality assurance rules will require more sampling and monitoring.   | Unacceptable     | Review monitoring programme and align with<br>finalised Quality Assurance Rules.<br>Install continuous monitors (pH, turbidity &<br>conductivity) for source water where required<br>Install continuous FAC meters in the distribution<br>network where required. |
| 108 | General             | Verification<br>Monitoring | Contamination or loss or<br>supply not identified due<br>to inadequate data<br>collection and reporting<br>systems (includes PLC,<br>SCADA, Water Outlook<br>and communications<br>systems) | Water Outlook setup and<br>implementation is in its mid<br>stage. Full roll out, testing and<br>assessing performance of system<br>and users and increasing use for<br>WSP management. | Unacceptable     | Water Outlook implementation and continued<br>training.<br>Process to check critical equipment and alarms to<br>be developed and incorporated into the QMS.   |
| 113 | General             | Other                      | Contamination due to<br>inadequate treatment<br>processes   | Waingake WTP high flows cannot<br>to meet new Quality Assurance<br>Rule requirement for Ct.  | Unacceptable     | Waingake UV disinfection.   |

| ID  | Supply<br>Component | Process Step | Hazardous Event   | Consideration for Residual Risk Level  | Residual<br>Risk | Improvements   |
|-----|---------------------|--------------|---|--|------------------|--|
| 116 | General             | Other        | Contamination or loss of<br>supply due to changes in<br>legislation, standards,<br>organisational policy,<br>bylaws, codes of practices | Waingake WTP high flows cannot<br>to meet new Quality Assurance<br>Rule requirement for C.t  | Unacceptable     | Waingake UV disinfection.<br>Develop and implement a Critical Document Review<br>programme using Water Outlook   |
| 117 | General             | Other        | Loss of supply linked to<br>water demand issues<br>(expansion of network,<br>pressure issues, leak<br>management)                       | Connection of new subdivision<br>areas. Planning for growth areas.<br>Muriwai & Patutahi pipelines and<br>communities connection.<br>Pressure loss upstream of<br>Makaraka Pump Station.<br>Ineffective position of Ormond<br>Rd PS. Pah Hill Reservoir land<br>subsiding. | Unacceptable     | Complete and action Water Demand and water<br>losses strategy.<br>- Papatu Rd Pump Station (booster and additional<br>Makaraka PS).<br>- New trunk mains for Nob Hill and maybe new<br>reservoir. Dedicated fill main from Wainui Rd bridge<br>to Nob Hill.<br>- Remove Pa Hill reservoirs and installation of pump<br>system for the higher area. |

Table 8: Unacceptable Risks and Improvements for Gisborne Water Supply

| Supply<br>Component     | Process Step   | Works to Reduce Risk   |
|-------------------------|--|--|
| Waingake                | Treatment  | Waingake UV disinfection facility.   |
| General                 | Barrier Management   | Water Outlook implementation and continued training.   |
| Distribution<br>Network | Distribution Network –<br>Pump Stations                                      | Papatu Rd Pump Station (booster and additional to Makaraka<br>Pump Station).   |
| Waingake                | Catchments   | Waingake Transformation Programme (transition to 70% native vegetation)  |
| Distribution<br>Network | Distribution Network   | Universal Metering and water loss reduction strategy.  |
| Waingake                | Abstraction  | Sang Dam slump remediation.  |
| General                 | Barrier Management   | Improving seismic resilience - from Seismic Assessment (WSP-<br>OPUS, 15 October 2020).  |
| Distribution<br>Network | Distribution Network   | Pressure zoning and bulk metering (associate with water loss strategy)   |
| Waingake                | Abstraction  | Clapcott Dam Face remediation.   |
| General                 | Barrier Management   | Reservoir seismic strengthening WTPs and Distribution Network. Vulnerable are Waingake and Waipaoa CWR/BW.   |
| Distribution<br>Network | Distribution Network   | New supply main from Wainui Rd bridge to Nob Hill and<br>potential for additional reservoir. Dedicated pump station at<br>base of hill.  |
| Waingake                | Treatment  | Filter 6 at Waingake and removal of Lime Silo.   |
| Distribution<br>Network | Distribution Network –<br>Treated Water Trunk Main<br>(Waingake to Makaraka) | Trunk main refurbishments of above ground sections and pipe bridges.   |
| Distribution<br>Network | Distribution Network   | Gas chlorination at Nob Hill.  |
| Distribution<br>Network | Distribution Network –<br>Reservoirs   | Remove Pa Hill reservoirs and installation of pump system for servicing the elevated area.   |
| General                 | Verification Monitoring  | Transition from Hilltop to Water Outlook (source data).  |
| General                 | Barrier Management   | Review of solar and increased application at remote sites.   |
| General                 | Verification Monitoring  | Review monitoring programme and align with finalised<br>Quality Assurance Rules.   |
| General                 | Barrier Management   | Process to check new critical equipment and alarms to be developed and incorporated into the QMS.  |
| Waipaoa                 | Treatment  | Plan for scenarios when the treatment plant/s cannot treat to<br>normal capacity and determine operational steps that<br>ensures compliance. Consider options with UV reactors in<br>treatment process for higher log removal. |

## **8 IMPROVEMENTS IDENTIFIED DURING WSP PREPARATION**

#### **9 REFERENCES**

GDC and Wai Comply. (2022). *Gisborne District Council Organisational Water Safety Plan.* Gisborne: Gisborne District Council.

Ministry of Health. (2019). Handbook for Preparing a Water Safety Plan. Wellington: Ministry of Health.

Taumata Arowai. (2022, July 12). *Hinekōrako Public Register of Drinking Water Supplies*. Retrieved from Hinekōrako: https://hinekorako.taumataarowai.govt.nz/publicregister/supplies/view/?id=86362da7-1e74-ec11-8943-00224812ea96

Wai Comply. (2022). Gisborne Drinking Water Source Risk Assessment. New Plymouth: Wai Comply.

### **APPENDICES**

#### APPENDIX A. RISK ASSESSMENT TABLES

|    |                  |                                   |   |            | Hazaro   | d Type   |              | Maximur    | n (Unmitigated R | lisk)         | Existing Preventive Measures  | Resid      | ual (Mitigated) I | Risk          |                                |
|----|------------------|-----------------------------------|---|------------|----------|----------|--------------|------------|------------------|---------------|---|------------|-------------------|---------------|--------------------------------|
| ID | Supply Component | Process Step                      | Hazardous Event   | Biological | Chemical | Physical | Radiological | Likelihood | Consequence      | Risk<br>Level | Description   | Likelihood | Consequence       | Risk<br>Level | Residual Risk<br>Acceptability |
| 1  | Waingake         | Catchment -<br>Mangapoike<br>Dams | Contamination in the source water catchments<br>from industrial practices (road transport)  | 2          | 2        | 2        |              | Rare       | Major            | Medium        | <ul> <li>Sampling programme in place and<br/>prepared/checked against current standards or<br/>rules.</li> <li>Source Water Risk Assessment completed in<br/>2022 to understand catchment area, raw water<br/>quality and catchment characteristics.</li> <li>Coagulation and clarification process in place<br/>(coagulant and Clarifier).</li> <li>Filtration process in place.</li> <li>Permanent chlorination and residual<br/>disinfection process in place.</li> <li>Sites are secure with fences, locked gates or<br/>buildings in place.</li> <li>Bulk supply available from a combination of<br/>Waingake (Including Waingake River or<br/>Mangapoike Dams) or Waipaoa WTPs.</li> </ul>  | Rare       | Major             | Medium        | Acceptable                     |
| 2  | Waingake         | Catchment -<br>Mangapoike<br>Dams | Contamination in the source water catchments<br>from open space activities (stormwater runoff)                                      | 2          | 2        | 2        | 2            | Likely     | Catastrophic     | Extreme       | <ul> <li>Sampling programme in place and<br/>prepared/checked against current standards or<br/>rules.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> <li>Source Water Risk Assessment completed in<br/>2022 to understand catchment area, raw water<br/>quality and catchment characteristics.</li> <li>Coagulation and clarification process in place<br/>(coagulant and Clarifier).</li> <li>Filtration process in place.</li> <li>Permanent chlorination and residual<br/>disinfection process in place.</li> <li>Bulk supply available from a combination of<br/>Waingake (Including Waingake River or<br/>Mangapoike Dams) or Waipaoa WTPs.</li> </ul>   | Rare       | Major             | Medium        | Acceptable                     |
| 3  | Waingake         | Catchment -<br>Mangapoike<br>Dams | Contamination in the source water catchment<br>from new or unknown activities (change of land<br>use, change in access permissions) | 2          | 2        | 2        | 2            | Unlikely   | Catastrophic     | High          | <ul> <li>Sampling programme in place and<br/>prepared/checked against current standards or<br/>rules.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> <li>Engagement with Planners to ensure that Water<br/>Team is notified of catchment activities, Consent<br/>applications, or land use changes.</li> <li>Source Water Risk Assessment completed in<br/>2022 to understand catchment area, raw water<br/>quality and catchment characteristics.</li> <li>Coagulation and clarification process in place<br/>(coagulant and Clarifier).</li> <li>Filtration process in place.</li> <li>Permanent chlorination and residual<br/>disinfection process in place.</li> <li>Sites are secure with fences, locked gates or<br/>buildings in place.</li> <li>GDC is the landowner for the full Dams</li> </ul> | Rare       | Major             | Medium        | Acceptable                     |

|    |                  |                                   |  |            | Hazar    | d Type   | e            | Maximur    | m (Unmitigated R | lisk)         | Existing Preventive Measures   | Resid      | lual (Mitigated) I | Risk          |                                |
|----|------------------|-----------------------------------|--|------------|----------|----------|--------------|------------|------------------|---------------|--|------------|--------------------|---------------|--------------------------------|
| ID | Supply Component | Process Step                      | Hazardous Event  | Biological | Chemical | Physical | Radiological | Likelihood | Consequence      | Risk<br>Level | Description  | Likelihood | Consequence        | Risk<br>Level | Residual Risk<br>Acceptability |
|    |                  |                                   |  |            |          |          |              |            |                  |               | catchment area and Waingake catchment is part  |            |                    |               |                                |
| 4  | Waingake         | Catchment -<br>Mangapoike<br>Dams | Naturally occurring contaminants present<br>(includes cyanobacteria, chemicals, metals)                            | ?          | 2        | 2        | 7            | Possible   | Major            | High          | <ul> <li>Sampling programme in place and<br/>prepared/checked against current standards or<br/>rules.</li> <li>Source Water Risk Assessment completed in<br/>2022 to understand catchment area, raw water<br/>quality and catchment characteristics.</li> <li>Coagulation and clarification process in place<br/>(coagulant and Clarifier).</li> <li>Filtration process in place.</li> <li>Permanent chlorination and residual<br/>disinfection process in place.</li> <li>Bulk supply available from a combination of<br/>Waingake (Including Waingake River or</li> </ul>  | Possible   | Major              | High          | Unacceptable                   |
| 5  | Waingake         | Catchment -<br>Mangapoike<br>Dams | Contamination or loss of supply due to changes from seismic activity   | 2          | 2        | 2        | 2            | Rare       | Catastrophic     | Medium        | Mangapoike Dams) or Waipaoa WTPs.<br>- On-line monitoring, telemetry to major sites for<br>critical aspects of supply operation.<br>- Coagulation and clarification process in place<br>(coagulant and Clarifier).<br>- Filtration process in place.<br>- Permanent chlorination and residual<br>disinfection process in place.<br>- Bulk supply available from a combination of<br>Waingake (Including Waingake River or<br>Mangapoike Dams) or Waipaoa WTPs.   | Rare       | Major              | Medium        | Acceptable                     |
| 6  | Waingake         | Catchment -<br>Mangapoike<br>Dams | Contamination or loss of supply due to<br>surrounding areas highly susceptible to erosion<br>(high solids loading) |            |          |          |              | Unlikely   | Catastrophic     | High          | <ul> <li>Sampling programme in place and<br/>prepared/checked against current standards or<br/>rules.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> <li>Source Water Risk Assessment completed in<br/>2022 to understand catchment area, raw water<br/>quality and catchment characteristics.</li> <li>Coagulation and clarification process in place<br/>(coagulant and Clarifier).</li> <li>Filtration process in place.</li> <li>Permanent chlorination and residual<br/>disinfection process in place.</li> <li>Mangapoike Dams: Two intake options from the<br/>Williams and Clapcott Dams. Both intakes have an<br/>intake column with coarse screen and manually<br/>operated valves. Online monitoring for lake level.</li> <li>Combined maximum gravity flow between 200 &amp;<br/>500 m3/hr (depending on lake levels) and 1,200<br/>m3/hr if pumped.</li> <li>Bulk supply available from a combination of<br/>Waingake (Including Waingake River or<br/>Mangapoike Dams) or Waipaoa WTPs.</li> </ul> | Rare       | Major              | Medium        | Acceptable                     |
| 7  | Waingake         | Catchment -<br>Mangapoike<br>Dams | Contamination of the source water caused by ashfall from a volcanic eruption                                       | ?          | 2        | ?        | 2            | Rare       | Major            | Medium        | <ul> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> <li>Engagement with Planners to ensure that Water Team is notified of catchment activities, Consent applications, or land use changes.</li> <li>Coagulation and clarification process in place (coagulant and Clarifier).</li> </ul>  | Rare       | Major              | Medium        | Acceptable                     |

|    |                  |                                   |   |            | Hazar    | d Type   | 9            | Maximun        | n (Unmitigated R | lisk)         | Existing Preventive Measures   | Resid      | lual (Mitigated) | Risk          |                                |
|----|------------------|-----------------------------------|---|------------|----------|----------|--------------|----------------|------------------|---------------|--|------------|------------------|---------------|--------------------------------|
| ID | Supply Component | Process Step                      | Hazardous Event   | Biological | Chemical | Physical | Radiological | Likelihood     | Consequence      | Risk<br>Level | Description  | Likelihood | Consequence      | Risk<br>Level | Residual Risk<br>Acceptability |
|    |                  |                                   |   |            |          |          |              |                |                  |               | <ul> <li>Filtration process in place.</li> <li>Permanent chlorination and residual<br/>disinfection process in place.</li> <li>Mangapoike Dams: Two intake options from the<br/>Williams and Clapcott Dams. Both intakes have an<br/>intake column with coarse screen and manually<br/>operated valves. Online monitoring for lake level.<br/>Combined maximum gravity flow between 200 &amp;<br/>500 m3/hr (depending on lake levels) and 1,200<br/>m3/hr if pumped.</li> </ul>   |            |                  |               |                                |
| 8  | Waingake         | Catchment -<br>Mangapoike<br>Dams | Loss of supply due to insufficient source water<br>availability - extended period of dry weather or<br>drought                            | 2          | 2        | 2        | 2            | Rare           | Major            | Medium        | <ul> <li>Water conservation measures (water restrictions) can be implemented. Water Demand Management Plan Developed and being implemented.</li> <li>Response plans are up to date and available.</li> <li>All consent dates and conditions are known and monitored by Water Team.</li> <li>Bulk supply available from a combination of Waingake (Including Waingake River or Mangapoike Dams) or Waipaoa WTPs.</li> </ul>   | Rare       | Major            | Medium        | Acceptable                     |
| 9  | Waingake         | Catchment -<br>Mangapoike<br>Dams | Loss of supply due to unsuitable raw water<br>quality for the treatment process (Mangapoike<br>Dam stratification causing quality issues) | 2          | 2        | 2        | 2            | Rare           | Moderate         | Low           | <ul> <li>Mangapoike Dams: Two intake options from the Williams and Clapcott Dams. Both intakes have an intake column with coarse screen and manually operated valves. Online monitoring for lake level. Combined maximum gravity flow between 200 &amp; 500 m3/hr (depending on lake levels) and 1,200 m3/hr if pumped.</li> <li>Bulk supply available from a combination of Waingake (Including Waingake River or Mangapoike Dams) or Waipaoa WTPs.</li> </ul>  | Rare       | Moderate         | Low           | Acceptable                     |
| 10 | Waingake         | Catchment -<br>Mangapoike<br>Dams | Contamination of the source water from faecal<br>matter from feral animals within the catchment<br>area                                   | 2          | 2        | 2        | 2            | Almost Certain | Catastrophic     | Extreme       | <ul> <li>Sampling programme in place and<br/>prepared/checked against current standards or<br/>rules.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> <li>Source Water Risk Assessment completed in<br/>2022 to understand catchment area, raw water<br/>quality and catchment characteristics.</li> <li>Coagulation and clarification process in place<br/>(coagulant and Clarifier).</li> <li>Filtration process in place.</li> <li>Permanent chlorination and residual<br/>disinfection process in place.</li> </ul> | Rare       | Major            | Medium        | Acceptable                     |
| 11 | Waingake         | Catchment -<br>Waingake<br>River  | Contamination in the source water catchments<br>from conservation land practices (animal<br>control,1080 drops)                           | 2          | 2        | 2        | 2            | Rare           | Major            | Medium        | <ul> <li>Sampling programme in place and<br/>prepared/checked against current standards or<br/>rules.</li> <li>Source Water Risk Assessment completed in<br/>2022 to understand catchment area, raw water<br/>quality and catchment characteristics.</li> <li>Coagulation and clarification process in place<br/>(coagulant and Clarifier).</li> <li>Filtration process in place.</li> <li>Permanent chlorination and residual<br/>disinfection process in place.</li> <li>Council works with appropriate agencies to<br/>ensure any pest control programme considers</li> </ul> | Rare       | Major            | Medium        | Acceptable                     |

|    |                  |                                  |   |            | Hazaro   | l Type   |              | Maximur    | m (Unmitigated R | lisk)         | Existing Preventive Measures   | Resid      | lual (Mitigated) | Risk          |                                |
|----|------------------|----------------------------------|---|------------|----------|----------|--------------|------------|------------------|---------------|--|------------|------------------|---------------|--------------------------------|
| ID | Supply Component | Process Step                     | Hazardous Event   | Biological | Chemical | Physical | Radiological | Likelihood | Consequence      | Risk<br>Level | Description  | Likelihood | Consequence      | Risk<br>Level | Residual Risk<br>Acceptability |
|    |                  |                                  |   |            |          |          |              |            |                  |               | drinking water related risks. Considerations<br>include the use of Vitamin K based poisons,<br>ensuring appropriate distances from tributaries,<br>and the use of non-poison pest control methods.<br>- Bulk supply available from a combination of<br>Waingake (Including Waingake River or<br>Mangapoike Dams) or Waipaoa WTPs.  |            |                  |               |                                |
| 12 | Waingake         | Catchment -<br>Waingake<br>River | Contamination of the source water catchment<br>from new or unknown activities (change of land<br>use, change in access permissions) | 2          |          |          | 2            | Unlikely   | Catastrophic     | High          | <ul> <li>Sampling programme in place and<br/>prepared/checked against current standards or<br/>rules.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> <li>Engagement with Planners to ensure that Water<br/>Team is notified of catchment activities, Consent<br/>applications, or land use changes.</li> <li>Source Water Risk Assessment completed in<br/>2022 to understand catchment area, raw water<br/>quality and catchment characteristics.</li> <li>Coagulation and clarification process in place<br/>(coagulant and Clarifier).</li> <li>Filtration process in place.</li> <li>Permanent chlorination and residual<br/>disinfection process in place.</li> <li>GDC is the landowner for the full Dams<br/>catchment area and Waingake catchment is part<br/>of the QEII trust.</li> <li>Bulk supply available from a combination of<br/>Waingake (Including Waingake River or<br/>Mangapoike Dams) or Waipaoa WTPs.</li> </ul> | Rare       | Major            | Medium        | Acceptable                     |
| 13 | Waingake         | Catchment -<br>Waingake<br>River | Naturally occurring contaminants present<br>(includes cyanobacteria, chemicals, metals)   | 2          | 2        |          | 2            | Possible   | Major            | High          | <ul> <li>Sampling programme in place and<br/>prepared/checked against current standards or<br/>rules.</li> <li>Source Water Risk Assessment completed in<br/>2022 to understand catchment area, raw water<br/>quality and catchment characteristics.</li> <li>Coagulation and clarification process in place<br/>(coagulant and Clarifier).</li> <li>Filtration process in place.</li> <li>Permanent chlorination and residual<br/>disinfection process in place.</li> <li>Bulk supply available from a combination of<br/>Waingake (Including Waingake River or<br/>Mangapoike Dams) or Waipaoa WTPs.</li> </ul>  | Possible   | Major            | High          | Unacceptable                   |
| 14 | Waingake         | Catchment -<br>Waingake<br>River | Contamination or loss of supply due to changes from seismic activity  | 2          | 2        | 2        | 2            | Rare       | Catastrophic     | Medium        | <ul> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> <li>Coagulation and clarification process in place (coagulant and Clarifier).</li> <li>Filtration process in place.</li> <li>Permanent chlorination and residual disinfection process in place.</li> <li>Bulk supply available from a combination of Waingake (Including Waingake River or Mangapoike Dams) or Waipaoa WTPs.</li> </ul>   | Rare       | Major            | Medium        | Acceptable                     |
| 15 | Waingake         | Catchment -<br>Waingake<br>River | Contamination or loss of supply due to<br>surrounding areas highly susceptible to erosion<br>(high solids loading)                  | ?          | ?        | ?        | ?            | Possible   | Catastrophic     | High          | <ul> <li>Sampling programme in place and<br/>prepared/checked against current standards or<br/>rules.</li> </ul>   | Unlikely   | Major            | Medium        | Acceptable                     |

|    |                  |                                  |  |            | Hazar    | d Type   | e            | Maximun        | n (Unmitigated R | isk)          | Existing Preventive Measures  | Resid      | lual (Mitigated) F | Risk          |                                |
|----|------------------|----------------------------------|--|------------|----------|----------|--------------|----------------|------------------|---------------|---|------------|--------------------|---------------|--------------------------------|
| ID | Supply Component | Process Step                     | Hazardous Event  | Biological | Chemical | Physical | Radiological | Likelihood     | Consequence      | Risk<br>Level | Description   | Likelihood | Consequence        | Risk<br>Level | Residual Risk<br>Acceptability |
|    |                  |                                  |  |            |          |          |              |                |                  |               | <ul> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> <li>Source Water Risk Assessment completed in 2022 to understand catchment area, raw water quality and catchment characteristics.</li> <li>Coagulation and clarification process in place (coagulant and Clarifier).</li> <li>Filtration process in place.</li> <li>Permanent chlorination and residual disinfection process in place.</li> <li>Bulk supply available from a combination of Waingake (Including Waingake River or Mangapoike Dams) or Waipaoa WTPs.</li> </ul> |            |                    |               |                                |
| 16 | Waingake         | Catchment -<br>Waingake<br>River | Contamination of the source water caused by ashfall from a volcanic eruption   | 2          | 2        | 2        | 2            | Rare           | Major            | Medium        | <ul> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> <li>Engagement with Planners to ensure that Water Team is notified of catchment activities, Consent applications, or land use changes.</li> <li>Coagulation and clarification process in place (coagulant and Clarifier).</li> <li>Filtration process in place.</li> <li>Permanent chlorination and residual disinfection process in place.</li> </ul>   | Rare       | Major              | Medium        | Acceptable                     |
| 17 | Waingake         | Catchment -<br>Waingake<br>River | Loss of supply due to insufficient source water<br>availability - extended period of dry weather or<br>drought   | 2          | 2        | 2        | 2            | Unlikely       | Major            | Medium        | <ul> <li>Water conservation measures (water<br/>restrictions) can be implemented. Water Demand<br/>Management Plan Developed and being<br/>implemented.</li> <li>Response plans are up to date and available.</li> <li>All consent dates and conditions are known and<br/>monitored by Water Team.</li> <li>Bulk supply available from a combination of<br/>Waingake (Including Waingake River or<br/>Mangapoike Dams) or Waipaoa WTPs.</li> </ul>  | Rare       | Major              | Medium        | Acceptable                     |
| 18 | Waingake         | Catchment -<br>Waingake<br>River | Contamination of the source water from faecal<br>matter from feral animals within the catchment<br>area  | 2          | 2        | 2        | 2            | Almost Certain | Catastrophic     | Extreme       | <ul> <li>Sampling programme in place and<br/>prepared/checked against current standards or<br/>rules.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> <li>Source Water Risk Assessment completed in<br/>2022 to understand catchment area, raw water<br/>quality and catchment characteristics.</li> <li>Coagulation and clarification process in place<br/>(coagulant and Clarifier).</li> <li>Filtration process in place.</li> <li>Permanent chlorination and residual<br/>disinfection process in place.</li> </ul>    | Rare       | Major              | Medium        | Acceptable                     |
| 19 | Waipaoa          | Catchment -<br>Waipaoa<br>River  | Contamination in the source water catchment<br>from agricultural practices (includes pesticides,<br>fertilisers, farm operations, dairy, effluent, and<br>grazing) | ?          | 2        | 2        | 2            | Almost Certain | Catastrophic     | Extreme       | <ul> <li>Sampling programme in place and<br/>prepared/checked against current standards or<br/>rules.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> <li>Source Water Risk Assessment completed in<br/>2022 to understand catchment area, raw water<br/>quality and catchment characteristics.</li> <li>Presedimentation process in place.</li> <li>Coagulation and clarification process in place</li> </ul>   | Possible   | Major              | High          | Unacceptable                   |

|    |                  |                                 |  |            | Hazar    | d Type   | !            | Maximur    | n (Unmitigated R | isk)          | Existing Preventive Measures  | Resid      | lual (Mitigated) I | Risk          |                                |
|----|------------------|---------------------------------|--|------------|----------|----------|--------------|------------|------------------|---------------|---|------------|--------------------|---------------|--------------------------------|
| ID | Supply Component | Process Step                    | Hazardous Event  | Biological | Chemical | Physical | Radiological | Likelihood | Consequence      | Risk<br>Level | Description   | Likelihood | Consequence        | Risk<br>Level | Residual Risk<br>Acceptability |
|    |                  |                                 |  |            |          |          |              |            |                  |               | <ul> <li>(coagulant and Clarifier).</li> <li>Filtration process in place.</li> <li>Permanent chlorination and residual<br/>disinfection process in place.</li> <li>UV disinfection process in place.</li> <li>Bulk supply available from a combination of<br/>Waingake (Including Waingake River or<br/>Mangapoike Dams) or Waipaoa WTPs.</li> </ul>  |            |                    |               |                                |
| 20 | Waipaoa          | Catchment -<br>Waipaoa<br>River | Contamination in the source water catchment<br>from industrial practices (road transport)  |            | 2        |          | 2            | Possible   | Major            | High          | <ul> <li>Sampling programme in place and<br/>prepared/checked against current standards or<br/>rules.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> <li>Source Water Risk Assessment completed in<br/>2022 to understand catchment area, raw water<br/>quality and catchment characteristics.</li> <li>Presedimentation process in place.</li> <li>Coagulation and clarification process in place<br/>(coagulant and Clarifier).</li> <li>Softening process in place.</li> <li>Permanent chlorination and residual<br/>disinfection process in place.</li> <li>UV disinfection process in place.</li> <li>Bulk supply available from a combination of<br/>Waingake (Including Waingake River or<br/>Mangapoike Dams) or Waipaoa WTPs.</li> </ul> | Unlikely   | Major              | Medium        | Acceptable                     |
| 21 | Waipaoa          | Catchment -<br>Waipaoa<br>River | Contamination in the source water catchments<br>from rural residential practices (fertilisers,<br>pets/livestock, onsite sewage, weed/pest<br>control) | 2          | 2        |          | 2            | Likely     | Catastrophic     | Extreme       | <ul> <li>Sampling programme in place and<br/>prepared/checked against current standards or<br/>rules.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> <li>Source Water Risk Assessment completed in<br/>2022 to understand catchment area, raw water<br/>quality and catchment characteristics.</li> <li>Presedimentation process in place.</li> <li>Coagulation and Clarification process in place<br/>(coagulant and Clarifier).</li> <li>Softening process in place.</li> <li>Permanent chlorination and residual<br/>disinfection process in place.</li> <li>UV disinfection process in place.</li> </ul>  | Unlikely   | Major              | Medium        | Acceptable                     |
| 22 | Waipaoa          | Catchment -<br>Waipaoa<br>River | Contamination of the source water catchment<br>from new or unknown activities (change of land<br>use or 'non-notified activities')                     | 2          | 2        | 2        | 2            | Possible   | Catastrophic     | High          | <ul> <li>Sampling programme in place and<br/>prepared/checked against current standards or<br/>rules.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> <li>Engagement with Planners to ensure that Water<br/>Team is notified of catchment activities, Consent<br/>applications, or land use changes.</li> <li>Source Water Risk Assessment completed in<br/>2022 to understand catchment area, raw water<br/>quality and catchment characteristics.</li> <li>Presedimentation process in place.</li> <li>Coagulation and clarification process in place</li> </ul>   | Rare       | Major              | Medium        | Acceptable                     |

|    |                  |                                 |  |            | Hazaro   | d Type   | !            | Maximur        | n (Unmitigated R | isk)          | Existing Preventive Measures   | Resid      | lual (Mitigated) | Risk          |                                |
|----|------------------|---------------------------------|--|------------|----------|----------|--------------|----------------|------------------|---------------|--|------------|------------------|---------------|--------------------------------|
| ID | Supply Component | Process Step                    | Hazardous Event  | Biological | Chemical | Physical | Radiological | Likelihood     | Consequence      | Risk<br>Level | Description  | Likelihood | Consequence      | Risk<br>Level | Residual Risk<br>Acceptability |
|    |                  |                                 |  |            |          |          |              |                |                  |               | <ul> <li>(coagulant and Clarifier).</li> <li>Softening process in place</li> <li>Filtration process in place.</li> <li>Permanent chlorination and residual</li> <li>disinfection process in place.</li> <li>UV disinfection process in place.</li> <li>Other PMs = Judith to determine Residual</li> </ul>   |            |                  |               |                                |
| 23 | Waipaoa          | Catchment -<br>Waipaoa<br>River | Naturally occurring contaminants present<br>(includes cyanobacteria, chemicals, metals)                            |            | 2        |          | 2            | Unlikely       | Major            | Medium        | <ul> <li>Sampling programme in place and<br/>prepared/checked against current standards or<br/>rules.</li> <li>Source Water Risk Assessment completed in<br/>2022 to understand catchment area, raw water<br/>quality and catchment characteristics.</li> <li>Cyanotoxin Management Plan in place.</li> <li>Presedimentation process in place.</li> <li>Coagulation and clarification process in place<br/>(coagulant and Clarifier).</li> <li>Softening process in place</li> <li>Filtration process in place.</li> <li>Permanent chlorination and residual<br/>disinfection process in place.</li> <li>UV disinfection process in place.</li> <li>Bulk supply available from a combination of<br/>Waingake (Including Waingake River or<br/>Mangapoike Dams) or Waipaoa WTPs.</li> </ul> | Rare       | Major            | Medium        | Acceptable                     |
| 24 | Waipaoa          | Catchment -<br>Waipaoa<br>River | Contamination or loss of supply due to changes from seismic activity   | 2          | 2        | 2        | 2            | Rare           | Catastrophic     | Medium        | <ul> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> <li>Presedimentation process in place.</li> <li>Coagulation and clarification process in place (coagulant and Clarifier).</li> <li>Softening process in place</li> <li>Filtration process in place.</li> <li>Permanent chlorination and residual disinfection process in place.</li> <li>UV disinfection process in place.</li> <li>Bulk supply available from a combination of Waingake (Including Waingake River or Mangapoike Dams) or Waipaoa WTPs.</li> </ul>  | Rare       | Major            | Medium        | Acceptable                     |
| 25 | Waipaoa          | Catchment -<br>Waipaoa<br>River | Contamination or loss of supply due to<br>surrounding areas highly susceptible to erosion<br>(high solids loading) |            |          | 2        | 2            | Almost Certain | Catastrophic     | Extreme       | <ul> <li>Sampling programme in place and<br/>prepared/checked against current standards or<br/>rules.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> <li>Presedimentation process in place.</li> <li>Coagulation and clarification process in place<br/>(coagulant and Clarifier).</li> <li>Softening process in place.</li> <li>Filtration process in place.</li> <li>Permanent chlorination and residual<br/>disinfection process in place.</li> <li>UV disinfection process in place.</li> <li>Bulk supply available from a combination of<br/>Waingake (Including Waingake River or<br/>Mangapoike Dams) or Waipaoa WTPs.</li> </ul>   | Possible   | Moderate         | Medium        | Acceptable                     |

|    |                  |                                 |   |            | Hazar    | d Type   | •            | Maximu     | m (Unmitigated R | lisk)         | Existing Preventive Measures  | Resid      | dual (Mitigated) | Risk          |                                |
|----|------------------|---------------------------------|---|------------|----------|----------|--------------|------------|------------------|---------------|---|------------|------------------|---------------|--------------------------------|
| ID | Supply Component | Process Step                    | Hazardous Event   | Biological | Chemical | Physical | Radiological | Likelihood | Consequence      | Risk<br>Level | Description   | Likelihood | Consequence      | Risk<br>Level | Residual Risk<br>Acceptability |
| 26 | Waipaoa          | Catchment -<br>Waipaoa<br>River | Contamination of the source water caused by ashfall from a volcanic eruption  | 2          | 2        | 2        | 2            | Rare       | Major            | Medium        | <ul> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> <li>Engagement with Planners to ensure that Water Team is notified of catchment activities, Consent applications, or land use changes.</li> <li>Presedimentation process in place.</li> <li>Coagulation and clarification process in place (coagulant and Clarifier).</li> <li>Softening process in place.</li> <li>Permanent chlorination and residual disinfection process in place.</li> <li>UV disinfection process in place.</li> </ul>   | Rare       | Major            | Medium        | Acceptable                     |
| 27 | Waipaoa          | Catchment -<br>Waipaoa<br>River | Loss of supply due to insufficient source water<br>availability - extended period of dry weather or<br>drought      | 2          | 2        | 2        | 2            | Rare       | Major            | Medium        | <ul> <li>Water conservation measures (water<br/>restrictions) can be implemented. Water Demand<br/>Management Plan Developed and being<br/>implemented.</li> <li>Response plans are up to date and available.</li> <li>All consent dates and conditions are known and<br/>monitored by Water Team.</li> <li>Bulk supply available from a combination of<br/>Waingake (Including Waingake River or<br/>Mangapoike Dams) or Waipaoa WTPs.</li> <li>Draft Freshwater Plan prioritises Municipal<br/>water supply takes.</li> </ul>   | Rare       | Moderate         | Low           | Acceptable                     |
| 28 | Waingake         | Abstraction                     | Contamination or loss of supply at the intakes or<br>weir due to unintentional or intentional damage<br>(vandalism) | 2          | 2        | 2        | 2            | Rare       | Catastrophic     | Medium        | <ul> <li>Mangapoike Dams: Two intake options from the Williams and Clapcott Dams. Both intakes have an intake column with coarse screen and manually operated valves. Online monitoring for lake level. Combined maximum gravity flow between 200 &amp; 500 m3/hr (depending on lake levels) and 1,200 m3/hr if pumped.</li> <li>Waingake Stream: Concrete full width weir with coarse bar screen gravity feeding raw water main. Hydraulic screen flush process with no requirement for power. Controlled by rotork connected to SCADA. Open/close valve only. Monitoring for flow and turbidity. Solar backup power.</li> <li>Adequately trained staff for operations and maintenance (includes internal and external staff and trainees).</li> </ul> | Rare       | Minor            | Low           | Acceptable                     |
| 29 | Waingake         | Abstraction                     | Loss of supply due to consents not being renewed or declined  | ?          | ?        | ?        | ?            | Unlikely   | Catastrophic     | High          | <ul> <li>All consent dates and conditions are known and<br/>monitored by Water Team.</li> <li>Draft Freshwater Plan prioritises Municipal<br/>water supply takes.</li> </ul>  | Unlikely   | Major            | Medium        | Acceptable                     |
| 30 | Waingake         | Abstraction                     | Loss of supply due to damage to the intakes or weir   | 2          | 2        | 2        | 2            | Rare       | Moderate         | Low           | <ul> <li>Mangapoike Dams: Two intake options from the Williams and Clapcott Dams. Both intakes have an intake column with coarse screen and manually operated valves. Online monitoring for lake level. Combined maximum gravity flow between 200 &amp; 500 m3/hr (depending on lake levels) and 1,200 m3/hr if pumped.</li> <li>Waingake Stream: Concrete full width weir with coarse bar screen gravity feeding raw water main. Hydraulic screen flush process with no</li> </ul>   | Rare       | Moderate         | Low           | Acceptable                     |

|    |                  |   |   |            | Hazar    | d Type   | 9            | Maximur    | n (Unmitigated R | isk)          | Existing Preventive Measures   | Resid      | lual (Mitigated) F | lisk          |                                |
|----|------------------|---|---|------------|----------|----------|--------------|------------|------------------|---------------|--|------------|--------------------|---------------|--------------------------------|
| ID | Supply Component | Process Step                            | Hazardous Event   | Biological | Chemical | Physical | Radiological | Likelihood | Consequence      | Risk<br>Level | Description  | Likelihood | Consequence        | Risk<br>Level | Residual Risk<br>Acceptability |
|    |                  |   |   |            |          |          |              |            |                  |               | requirement for power. Controlled by rotork<br>connected to SCADA. Open/close valve only.<br>Monitoring for flow and turbidity. Solar backup<br>power.<br>- Bulk supply available from a combination of<br>Waingake (Including Waingake River or<br>Mangapoike Dams) or Waipaoa WTPs.  |            |                    |               |                                |
| 31 | Waingake         | Abstraction                             | Loss of supply due to excessive build-up<br>surrounding the intakes or weir | 2          | 2        | 2        | 2            | Rare       | Moderate         | Low           | <ul> <li>Mangapoike Dams: Two intake options from the Williams and Clapcott Dams. Both intakes have an intake column with coarse screen and manually operated valves. Online monitoring for lake level. Combined maximum gravity flow between 200 &amp; 500 m3/hr (depending on lake levels) and 1,200 m3/hr if pumped.</li> <li>Waingake Stream: Concrete full width weir with coarse bar screen gravity feeding raw water main. Hydraulic screen flush process with no requirement for power. Controlled by rotork connected to SCADA. Open/close valve only. Monitoring for flow and turbidity. Solar backup power.</li> <li>Bulk supply available from a combination of Waingake (Including Waingake River or Mangapoike Dams) or Waipaoa WTPs.</li> </ul> | Rare       | Moderate           | Low           | Acceptable                     |
| 32 | Waingake         | Raw Water<br>Main &<br>Pump<br>Stations | Loss of supply due to damage to the raw water main                          | 2          | 2        | 2        | 2            | Possible   | Major            | High          | <ul> <li>Raw water trunk main: 450mm CLMS from<br/>intakes to Waingake WTP. Cathodic protection in<br/>place and some sections exposed to atmosphere.</li> <li>Regular inspection and maintenance<br/>programme in place with specialist contractors<br/>engaged where appropriate.</li> <li>Adequately trained staff for operations and<br/>maintenance (includes internal and external staff<br/>and trainees).</li> <li>Critical spares are available for bulk supply and<br/>treatment systems.</li> <li>Non-critical spare parts are held for some things<br/>and replacement spares parts are usually available<br/>overnight.</li> <li>Sites are secure with fences, locked gates or<br/>buildings in place.</li> </ul>                                 | Rare       | Moderate           | Low           | Acceptable                     |
| 33 | Waingake         | Raw Water<br>Main &<br>Pump<br>Stations | Loss of supply due to raw water main failure                                | 2          | 2        | 2        | 2            | Unlikely   | Major            | Medium        | <ul> <li>Raw water trunk main: 450mm CLMS from<br/>intakes to Waingake WTP. Cathodic protection in<br/>place and some sections exposed to atmosphere.</li> <li>Regular inspection and maintenance<br/>programme in place with specialist contractors<br/>engaged where appropriate.</li> <li>Adequately trained staff for operations and<br/>maintenance (includes internal and external staff<br/>and trainees).</li> <li>Critical spares are available for bulk supply and<br/>treatment systems.</li> <li>Non-critical spare parts are held for some things<br/>and replacement spares parts are usually available<br/>overnight.</li> <li>Sites are secure with fences, locked gates or<br/>buildings in place.</li> </ul>                                 | Rare       | Moderate           | Low           | Acceptable                     |

|    |                  |   |   |            | Hazar    | d Type   |              | Maximu     | m (Unmitigated R | isk)          | Existing Preventive Measures   | Resid      | dual (Mitigated) F | lisk          |                                |
|----|------------------|---|---|------------|----------|----------|--------------|------------|------------------|---------------|--|------------|--------------------|---------------|--------------------------------|
| ID | Supply Component | Process Step                            | Hazardous Event   | Biological | Chemical | Physical | Radiological | Likelihood | Consequence      | Risk<br>Level | Description  | Likelihood | Consequence        | Risk<br>Level | Residual Risk<br>Acceptability |
| 34 | Waingake         | Raw Water<br>Main &<br>Pump<br>Stations | Loss of supply due to damage to the pump<br>stations        |            |          |          |              | Possible   | Moderate         | Medium        | <ul> <li>Damline Pump Station: Booster pump station<br/>with two pumps. Duty/standby setup. Rotork<br/>valve connected to telemetry system and used to<br/>manage gravity flow rates. Monitoring for<br/>pressure, flow, valve position. Generator installed<br/>for backup power.</li> <li>Fairview Pump Station: Booster pump station<br/>with two pumps. Duty/standby setup. Manually<br/>operated. Monitoring for pressure, flow, valve<br/>position. No backup power options available.</li> <li>Regular inspection and maintenance<br/>programme in place with specialist contractors<br/>engaged where appropriate.</li> <li>Adequately trained staff for operations and<br/>maintenance (includes internal and external staff<br/>and trainees).</li> <li>Critical spares are available for bulk supply and<br/>treatment systems.</li> <li>Non-critical spare parts are held for some things<br/>and replacement spares parts are usually available<br/>overnight.</li> <li>Record keeping and reporting systems are<br/>available and utilised (Objective, Ozone, IPS, Plant<br/>Diary, GIS, Water Outlook, Hilltop, Vault, SCADA<br/>Notes, Maximo (FH only)).</li> <li>Sites are secure with fences, locked gates or<br/>buildings in place.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> <li>Robust and detailed alarm system is in place to<br/>notify staff of any exceedance of limit or<br/>unexpected status change (i.e., power outage).</li> </ul> | Rare       | Minor              | Low           | Acceptable                     |
| 35 | Waingake         | Raw Water<br>Main &<br>Pump<br>Stations | Loss of supply due to loss of power at the pump<br>stations |            | 2        | 2        |              | Likely     | Moderate         | High          | <ul> <li>Damline Pump Station: Booster pump station<br/>with two pumps. Duty/standby setup. Rotork<br/>valve connected to telemetry system and used to<br/>manage gravity flow rates. Monitoring for<br/>pressure, flow, valve position. Generator installed<br/>for backup power.</li> <li>Fairview Pump Station: Booster pump station<br/>with two pumps. Duty/standby setup. Manually<br/>operated. Monitoring for pressure, flow, valve<br/>position. No backup power options available.</li> <li>Regular inspection and maintenance<br/>programme in place with specialist contractors<br/>engaged where appropriate.</li> <li>Adequately trained staff for operations and<br/>maintenance (includes internal and external staff<br/>and trainees).</li> <li>Critical spares are available for bulk supply and<br/>treatment systems.</li> <li>Non-critical spare parts are held for some things<br/>and replacement spares parts are usually available<br/>overnight.</li> <li>Record keeping and reporting systems are<br/>available and utilised (Objective, Ozone, IPS, Plant<br/>Diary, GIS, Water Outlook, Hilltop, Vault, SCADA</li> </ul>   | Rare       | Minor              | Low           | Acceptable                     |

|    |                  |              |  |            | Hazar    | d Type   | 9            | Maximu     | m (Unmitigated R | isk)          | Existing Preventive Measures   | Resid      | lual (Mitigated) I | Risk          |                                |
|----|------------------|--------------|--|------------|----------|----------|--------------|------------|------------------|---------------|--|------------|--------------------|---------------|--------------------------------|
| ID | Supply Component | Process Step | Hazardous Event  | Biological | Chemical | Physical | Radiological | Likelihood | Consequence      | Risk<br>Level | Description  | Likelihood | Consequence        | Risk<br>Level | Residual Risk<br>Acceptability |
|    |                  |              |  |            |          |          |              |            |                  |               | <ul> <li>Notes, Maximo (FH only)).</li> <li>Sites are secure with fences, locked gates or<br/>buildings in place.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> <li>Robust and detailed alarm system is in place to<br/>notify staff of any exceedance of limit or<br/>unexpected status change (i.e., power outage).</li> </ul>  |            |                    |               |                                |
| 36 | Waingake         | Treatment    | Contamination or loss of supply due to<br>COAGULATION/FLOCCULATION process failure<br>(coagulant supply exhausted, dosing equipment<br>failure, unsuitable quality of incoming water,<br>incorrect dose rate, power failure)   | 2          | 2        | 2        | 2            | Possible   | Catastrophic     | High          | <ul> <li>Waingake WTP: Clarifier inlet dosed with<br/>Polyaluminium chloride and Polyelectrolyte<br/>(L3RC). Partial settlement within clarifier<br/>depending on flows. Major maintenance carried<br/>out as scheduled. Duty/standby dose pumps.<br/>Dose automatically controlled by inlet flow meter.<br/>Stubbe valves in place. Daily checks on chemical<br/>consumption rates. Poly uses service water as<br/>carry water. Day tank in place for PACI.</li> <li>Critical suppliers are communicated with<br/>regularly and updates are received when supply is<br/>expected to be low. Early ordering where<br/>possible. Shared inventory with other WTPs, GDC<br/>Pool and neighbouring Water Suppliers.</li> </ul>  | Rare       | Major              | Medium        | Acceptable                     |
| 37 | Waingake         | Treatment    | Contamination or loss of supply due to<br>FILTRATION process failure (issue with preceding<br>treatment process, backwash system failure,<br>power failure, inadequate backwash reservoir<br>level)  | 2          |          | 2        | 2            | Possible   | Catastrophic     | High          | <ul> <li>Waingake WTP: Five rapid sand Filters. Water<br/>and air backwash initiated on head loss, time,<br/>turbidity or manually (if required). Filter overflow<br/>available for unsuitable filter turbidity levels (run<br/>to waste). Monitoring for turbidity on each filter.<br/>Duty/standby backwash pumps. Backup blower<br/>kept on site. Full backwash process automated.<br/>CCP limits and actions in place.</li> <li>Critical suppliers are communicated with<br/>regularly and updates are received when supply is<br/>expected to be low. Early ordering where<br/>possible. Shared inventory with other WTPs, GDC<br/>Pool and neighbouring Water Suppliers.</li> <li>Robust and detailed alarm system is in place to<br/>notify staff of any exceedance of limit or<br/>unexpected status change (i.e., power outage).</li> <li>Verification (validation) and standardisation<br/>(calibration) of online instrumentation carried out<br/>as per manufacturers recommendations and GDC<br/>procedures.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> </ul> | Unlikely   | Moderate           | Medium        | Acceptable                     |
| 38 | Waingake         | Treatment    | Contamination due to CHLORINE DISINFECTION<br>process failure - inadequate chlorination (issue<br>with preceding treatment process, chlorine gas<br>supply exhausted, dosing equipment failure,<br>incorrect dose rate, service water issue, short<br>contact time, power failure) | 2          | 2        | 2        | 2            | Possible   | Catastrophic     | High          | <ul> <li>Waingake WTP: Two 920kg drums of chlorine<br/>gas setup. Duty standby chlorinators with flow<br/>proportional dosing. Monitoring for FAC and pH<br/>after the dose point (Filtered water sump) and at<br/>the reservoir outlet. Contact time demonstrated<br/>in compliance reporting. Duty/standby sample<br/>water pumps. CCP limits and actions in place.</li> <li>Critical suppliers are communicated with<br/>regularly and updates are received when supply is<br/>expected to be low. Early ordering where<br/>possible. Shared inventory with other WTPs, GDC<br/>Pool and neighbouring Water Suppliers.</li> </ul>   | Rare       | Moderate           | Low           | Acceptable                     |

|    |                  |              |  |            | Hazaro   | d Type   | 2            | Maximu     | m (Unmitigated R | isk)          | Existing Preventive Measures   | Resid      | lual (Mitigated) I | Risk          |                                |
|----|------------------|--------------|--|------------|----------|----------|--------------|------------|------------------|---------------|--|------------|--------------------|---------------|--------------------------------|
| ID | Supply Component | Process Step | Hazardous Event  | Biological | Chemical | Physical | Radiological | Likelihood | Consequence      | Risk<br>Level | Description  | Likelihood | Consequence        | Risk<br>Level | Residual Risk<br>Acceptability |
|    |                  |              |  |            |          |          |              |            |                  |               | <ul> <li>Robust and detailed alarm system is in place to<br/>notify staff of any exceedance of limit or<br/>unexpected status change (i.e., power outage).</li> <li>Verification (validation) and standardisation<br/>(calibration) of online instrumentation carried out<br/>as per manufacturers recommendations and GDC<br/>procedures.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> </ul>  |            |                    |               |                                |
| 39 | Waingake         | Treatment    | Contamination due to CHLORINE DISINFECTION<br>process failure - over chlorination (issue with<br>preceding treatment process, dosing equipment<br>failure, incorrect dose rate, other contamination<br>during servicing maintenance) | 2          | 2        | 2        | 2            | Possible   | Major            | High          | <ul> <li>Waingake WTP: Two 920kg drums of chlorine<br/>gas setup. Duty standby chlorinators with flow<br/>proportional dosing. Monitoring for FAC and pH<br/>after the dose point (Filtered water sump) and at<br/>the reservoir outlet. Contact time demonstrated<br/>in compliance reporting. Duty/standby sample<br/>water pumps. CCP limits and actions in place.</li> <li>Robust and detailed alarm system is in place to<br/>notify staff of any exceedance of limit or<br/>unexpected status change (i.e., power outage).</li> <li>Verification (validation) and standardisation<br/>(calibration) of online instrumentation carried out<br/>as per manufacturers recommendations and GDC<br/>procedures.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> </ul>  | Rare       | Major              | Medium        | Acceptable                     |
| 40 | Waingake         | Treatment    | Contamination due to the chlorine reacting with<br>raw water contaminants causing disinfection by-<br>products   | ?          | 2        | 2        | 2            | Possible   | Major            | High          | <ul> <li>Waingake WTP: Two 920kg drums of chlorine<br/>gas setup. Duty standby chlorinators with flow<br/>proportional dosing. Monitoring for FAC and pH<br/>after the dose point (Filtered water sump) and at<br/>the reservoir outlet. Contact time demonstrated<br/>in compliance reporting. Duty/standby sample<br/>water pumps. CCP limits and actions in place.</li> <li>Sampling programme in place and<br/>prepared/checked against current standards or<br/>rules.</li> <li>Low FAC demand, colour testing carried out.</li> </ul>  | Unlikely   | Major              | Medium        | Acceptable                     |
| 41 | Waingake         | Treatment    | Contamination due to FLUORIDATION process<br>failure (dosing equipment failure, incorrect dose<br>rate)  | 2          | 2        | 2        |              | Possible   | Major            | High          | <ul> <li>Waingake WTP: Fluoride outlet dosed with<br/>Hydrofluosilicic acid. Duty/standby dose pumps.<br/>Dose automatically controlled by outlet flow<br/>meter. Stubbe valves in place. Monitoring for<br/>fluoride downstream of the dosing point. Day tank<br/>used to limit exposure to overdosing. If flow too<br/>low, dose pump will stop. Limits and actions in<br/>place.</li> <li>Sampling programme in place and<br/>prepared/checked against current standards or<br/>rules.</li> <li>Robust and detailed alarm system is in place to<br/>notify staff of any exceedance of limit or<br/>unexpected status change (i.e. power outage).</li> <li>Verification (validation) and standardisation<br/>(calibration) of online instrumentation carried out<br/>as per manufacturers recommendations and GDC<br/>procedures.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> </ul> | Rare       | Major              | Medium        | Acceptable                     |

|    |                  |              |   |            | Hazar    | d Type   | 2            | Maximu     | m (Unmitigated R | isk)          | Existing Preventive Measures   | Resid      | lual (Mitigated) I | Risk          |                                |
|----|------------------|--------------|---|------------|----------|----------|--------------|------------|------------------|---------------|--|------------|--------------------|---------------|--------------------------------|
| ID | Supply Component | Process Step | Hazardous Event   | Biological | Chemical | Physical | Radiological | Likelihood | Consequence      | Risk<br>Level | Description  | Likelihood | Consequence        | Risk<br>Level | Residual Risk<br>Acceptability |
| 42 | Waingake         | Treatment    | Contamination or loss of supply due to<br>unintentional or intentional vandalism of<br>treatment systems          | 2          | 2        | 2        | 2            | Possible   | Catastrophic     | High          | <ul> <li>Sites are secure with fences, locked gates or<br/>buildings in place.</li> <li>Regular inspection and maintenance<br/>programme in place with specialist contractors<br/>engaged where appropriate.</li> <li>Adequately trained staff for operations and<br/>maintenance (includes internal and external staff<br/>and trainees).</li> </ul>  | Rare       | Catastrophic       | Medium        | Acceptable                     |
| 43 | Waingake         | Treatment    | Loss of supply due to service water system failure  | 2          | 2        | 2        |              | Likely     | Moderate         | High          | <ul> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> <li>Critical spares are available for bulk supply and treatment systems.</li> <li>Non-critical spare parts are held for some things and replacement spares parts are usually available overnight.</li> <li>Waingake WTP: Clarifier inlet dosed with Polyaluminium chloride and Polyelectrolyte (L3RC). Partial settlement within clarifier depending on flows. Major maintenance carried out as scheduled. Duty/standby dose pumps. Dose automatically controlled by inlet flow meter. Stubbe valves in place. Daily checks on chemical consumption rates. Poly uses service water as carry water. Day tank in place for PACI.</li> </ul> | Rare       | Moderate           | Low           | Acceptable                     |
| 44 | Waingake         | Treatment    | Loss of supply due to compressed air system failure   | 2          | 2        | 2        | 2            | Likely     | Moderate         | High          | <ul> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> <li>Critical spares are available for bulk supply and treatment systems.</li> <li>Non-critical spare parts are held for some things and replacement spares parts are usually available overnight.</li> <li>Air compressors: Duty/standby and duty/assist system. Monitored for pressure. Alarming and response actions available.</li> </ul>  | Unlikely   | Moderate           | Medium        | Acceptable                     |
| 45 | Waingake         | Storage      | Contamination due to the integrity of reservoir<br>being compromised - access by birds or vermin,<br>or vandalism | 2          | 2        | 2        | 2            | Possible   | Catastrophic     | High          | <ul> <li>Waingake WTP: Two above ground reservoirs in place (Clearwater 1000m3 and Backwash 500m3).</li> <li>All entry hatches are sealed and secure against ingress. Monitoring for level.</li> <li>Permanent chlorination and residual disinfection process in place.</li> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> <li>Regular inspection and maintenance programme in place with specialist contractors engaged where appropriate.</li> </ul>   | Rare       | Moderate           | Low           | Acceptable                     |
| 46 | Waingake         | Storage      | Loss of storage capacity due to earthquake<br>damage  | 2          | 2        | 2        | 2            | Rare       | Moderate         | Low           | <ul> <li>Waingake WTP: Two above ground reservoirs in place (Clearwater 1000m3 and Backwash 500m3).</li> <li>All entry hatches are sealed and secure against ingress. Monitoring for level.</li> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> <li>Regular inspection and maintenance programme in place with specialist contractors engaged where appropriate.</li> <li>Water conservation measures (water restrictions) can be implemented. Water Demand</li> </ul>  | Rare       | Moderate           | Low           | Acceptable                     |

|    |                  |              |  |            | Hazaro   | d Type   | !            | Maximur    | n (Unmitigated Ri | isk)          | Existing Preventive Measures   | Resid      | lual (Mitigated) F | Risk          |                                |
|----|------------------|--------------|--|------------|----------|----------|--------------|------------|-------------------|---------------|--|------------|--------------------|---------------|--------------------------------|
| ID | Supply Component | Process Step | Hazardous Event  | Biological | Chemical | Physical | Radiological | Likelihood | Consequence       | Risk<br>Level | Description  | Likelihood | Consequence        | Risk<br>Level | Residual Risk<br>Acceptability |
|    |                  |              |  |            |          |          |              |            |                   |               | Management Plan Developed and being<br>implemented.<br>- Bulk supply available from a combination of<br>Waingake (Including Waingake River or<br>Mangapoike Dams) or Waipaoa WTPs.<br>- Response plans are up to date and available.   |            |                    |               |                                |
| 47 | Waingake         | Storage      | Contamination or loss of supply due to a minor<br>structural failure of reservoirs (including not<br>being detected) |            | 2        | 2        | 2            | Possible   | Major             | High          | <ul> <li>Waingake WTP: Two above ground reservoirs in place (Clearwater 1000m3 and Backwash 500m3).</li> <li>All entry hatches are sealed and secure against ingress. Monitoring for level.</li> <li>Permanent chlorination and residual disinfection process in place.</li> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> <li>Regular inspection and maintenance programme in place with specialist contractors engaged where appropriate.</li> </ul>   | Rare       | Moderate           | Low           | Acceptable                     |
| 48 | Waingake         | Storage      | Contamination from insanitary practices during<br>inspections, observations, or maintenance of<br>reservoir          | 2          | 2        | 2        | 2            | Unlikely   | Catastrophic      | High          | <ul> <li>Waingake WTP: Two above ground reservoirs in place (Clearwater 1000m3 and Backwash 500m3). All entry hatches are sealed and secure against ingress. Monitoring for level.</li> <li>Contractors/staff required to operate in accordance with specific procedures prepared and approved for each maintenance, entry or cleaning activity</li> <li>Permanent chlorination and residual disinfection process in place.</li> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> <li>Regular inspection and maintenance programme in place with specialist contractors engaged where appropriate.</li> </ul> | Rare       | Major              | Medium        | Acceptable                     |
| 49 | Waingake         | Storage      | Contamination from reservoir roof leakage  |            | 2        | 2        | 2            | Possible   | Catastrophic      | High          | <ul> <li>Waingake WTP: Two above ground reservoirs in place (Clearwater 1000m3 and Backwash 500m3).</li> <li>All entry hatches are sealed and secure against ingress. Monitoring for level.</li> <li>Permanent chlorination and residual disinfection process in place.</li> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> <li>Regular inspection and maintenance programme in place with specialist contractors engaged where appropriate.</li> </ul>   | Rare       | Moderate           | Low           | Acceptable                     |
| 50 | Waipaoa          | Abstraction  | Contamination at the intakes from maintenance/servicing work   | 2          | 2        | 2        | 2            | Possible   | Catastrophic      | High          | <ul> <li>Waipaoa River: Two pumped intakes with<br/>Johnson wedge wire screens and three pumps<br/>available (duty/standby/standby). Controlled from<br/>SCADA system. Air compressor onsite for screen<br/>cleans carried out as scheduled. Monitoring for<br/>flow to ponds, pump speed and status, intake<br/>backwash status and pressure. Backup power<br/>from Waipaoa WTP generator.</li> <li>Adequately trained staff for operations and<br/>maintenance (includes internal and external staff<br/>and trainees).</li> </ul>   | Rare       | Minor              | Low           | Acceptable                     |

|    |                  |              |   |            | Hazar    | d Type   | :            | Maximu     | m (Unmitigated R | Risk)         | Existing Preventive Measures  | Resid      | lual (Mitigated) | Risk          |                                |
|----|------------------|--------------|---|------------|----------|----------|--------------|------------|------------------|---------------|---|------------|------------------|---------------|--------------------------------|
| ID | Supply Component | Process Step | Hazardous Event   | Biological | Chemical | Physical | Radiological | Likelihood | Consequence      | Risk<br>Level | Description   | Likelihood | Consequence      | Risk<br>Level | Residual Risk<br>Acceptability |
| 51 | Waipaoa          | Abstraction  | Contamination or loss of supply at the intakes<br>due to unintentional or intentional damage<br>(vandalism) | 2          | 2        | 2        | 2            | Likely     | Catastrophic     | Extreme       | <ul> <li>Waipaoa River: Two pumped intakes with<br/>Johnson wedge wire screens and three pumps<br/>available (duty/standby/standby). Controlled from<br/>SCADA system. Air compressor onsite for screen<br/>cleans carried out as scheduled. Monitoring for<br/>flow to ponds, pump speed and status, intake<br/>backwash status and pressure. Backup power<br/>from Waipaoa WTP generator.</li> <li>Adequately trained staff for operations and<br/>maintenance (includes internal and external staff<br/>and trainees).</li> </ul>        | Possible   | Moderate         | Medium        | Acceptable                     |
| 52 | Waipaoa          | Abstraction  | Loss of supply due to consents not being renewed or declined  | 2          | 2        | 2        | 2            | Unlikely   | Catastrophic     | High          | <ul> <li>Waipaoa River: Two pumped intakes with<br/>Johnson wedge wire screens and three pumps<br/>available (duty/standby/standby). Controlled from<br/>SCADA system. Air compressor onsite for screen<br/>cleans carried out as scheduled. Monitoring for<br/>flow to ponds, pump speed and status, intake<br/>backwash status and pressure. Backup power<br/>from Waipaoa WTP generator.</li> <li>Draft Freshwater Plan prioritises Municipal<br/>water supply takes.</li> </ul>   | Rare       | Minor            | Low           | Acceptable                     |
| 53 | Waipaoa          | Abstraction  | Loss of supply due to damage to the intakes (logs<br>and other environmental)                               | 2          | 2        | 2        | 2            | Possible   | Moderate         | Medium        | <ul> <li>Waipaoa River: Two pumped intakes with<br/>Johnson wedge wire screens and three pumps<br/>available (duty/standby/standby). Controlled from<br/>SCADA system. Air compressor onsite for screen<br/>cleans carried out as scheduled. Monitoring for<br/>flow to ponds, pump speed and status, intake<br/>backwash status and pressure. Backup power<br/>from Waipaoa WTP generator.</li> <li>Bulk supply available from a combination of<br/>Waingake (Including Waingake River or<br/>Mangapoike Dams) or Waipaoa WTPs.</li> </ul> | Rare       | Minor            | Low           | Acceptable                     |
| 54 | Waipaoa          | Abstraction  | Loss of supply due to excessive build-up<br>surrounding the intakes   | 2          | 2        | 2        | 2            | Likely     | Moderate         | High          | <ul> <li>Waipaoa River: Two pumped intakes with<br/>Johnson wedge wire screens and three pumps<br/>available (duty/standby/standby). Controlled from<br/>SCADA system. Air compressor onsite for screen<br/>cleans carried out as scheduled. Monitoring for<br/>flow to ponds, pump speed and status, intake<br/>backwash status and pressure. Backup power<br/>from Waipaoa WTP generator.</li> <li>Bulk supply available from a combination of<br/>Waingake (Including Waingake River or<br/>Mangapoike Dams) or Waipaoa WTPs.</li> </ul> | Possible   | Minor            | Medium        | Acceptable                     |
| 55 | Waipaoa          | Abstraction  | Loss of supply due to loss of power at the intakes  | 2          | 2        | 2        | 2            | Likely     | Moderate         | High          | <ul> <li>Waipaoa River: Two pumped intakes with<br/>Johnson wedge wire screens and three pumps<br/>available (duty/standby/standby). Controlled from<br/>SCADA system. Air compressor onsite for screen<br/>cleans carried out as scheduled. Monitoring for<br/>flow to ponds, pump speed and status, intake<br/>backwash status and pressure. Backup power<br/>from Waipaoa WTP generator.</li> <li>Bulk supply available from a combination of<br/>Waingake (Including Waingake River or<br/>Mangapoike Dams) or Waipaoa WTPs.</li> </ul> | Rare       | Minor            | Low           | Acceptable                     |

|    |                  |              |   |            | Hazaro   | d Type   | !            | Maximur    | m (Unmitigated Ri | isk)          | Existing Preventive Measures  | Resid      | lual (Mitigated) | Risk          |                                |
|----|------------------|--------------|---|------------|----------|----------|--------------|------------|-------------------|---------------|---|------------|------------------|---------------|--------------------------------|
| ID | Supply Component | Process Step | Hazardous Event   | Biological | Chemical | Physical | Radiological | Likelihood | Consequence       | Risk<br>Level | Description   | Likelihood | Consequence      | Risk<br>Level | Residual Risk<br>Acceptability |
| 56 | Waipaoa          | Treatment    | Contamination or loss of supply due to<br>PRESEDIMENTATION process failure (unsuitable<br>quality of incoming water)  | 2          | 2        | 2        | 2            | Possible   | Catastrophic      | High          | <ul> <li>Presed Ponds and Pump Station: Two<br/>presedimentation ponds and one wastewater<br/>pond that returns supernatant to the river. Ponds<br/>operated manually and in parallel. Monitoring<br/>includes pond level and inflow. Pump station<br/>following ponds have duty/standby pumps and<br/>pumps to header. Coagulant (PACI) dosed into<br/>header. Header can be split to each clarifier if<br/>required. Monitoring includes pond outflow and<br/>turbidity.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> </ul>   | Rare       | Minor            | Low           | Acceptable                     |
| 57 | Waipaoa          | Treatment    | Contamination or loss of supply due to<br>COAGULATION/FLOCCULATION/SEDIMENTATION<br>process failure (issue with preceding treatment<br>process, coagulant supply exhausted, dosing<br>equipment failure, incorrect dose rate, power<br>failure) | 2          |          |          | 2            | Possible   | Catastrophic      | High          | <ul> <li>Waipaoa WTP: Pump station header tank dosed<br/>with Polyaluminium chloride and centre of Graver<br/>with Polyelectrolyte (B570). Considerable<br/>settlement within clarifier when optimised.<br/>Duty/standby dose pumps. Dose rate manually<br/>controlled with daily checks on chemical<br/>consumption. Stubbe valves in place.</li> <li>Critical suppliers are communicated with<br/>regularly and updates are received when supply is<br/>expected to be low. Early ordering where<br/>possible. Shared inventory with other WTPs, GDC<br/>Pool and neighbouring Water Suppliers.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> <li>Bulk supply available from a combination of<br/>Waingake (Including Waingake River or<br/>Mangapoike Dams) or Waipaoa WTPs.</li> <li>Permanent chlorination and residual<br/>disinfection process in place.</li> <li>Distribution Reservoir storage available:<br/>Hospital Hill 38,000m3. Nob Hill 8,000m3. Several<br/>small high-level reservoirs.</li> </ul> | Unlikely   | Major            | Medium        | Acceptable                     |
| 58 | Waipaoa          | Treatment    | Contamination or loss of supply due to<br>SOFTENING process failure (issue with preceding<br>treatment process, Caustic dosing equipment<br>failure, incorrect dose rate, power failure)  | 2          | 2        | 2        | 2            | Possible   | Major             | High          | <ul> <li>Waipaoa WTP: Sodium hydroxide and Carbon<br/>Dioxide dosed for water softening. Stubbe valves<br/>in place. Dose rates available for 6 scenarios (A-F).<br/>Monitoring for pH at each clarifier and the hydro<br/>column. CCP limits and actions in place.</li> <li>Critical suppliers are communicated with<br/>regularly and updates are received when supply is<br/>expected to be low. Early ordering where<br/>possible. Shared inventory with other WTPs, GDC<br/>Pool and neighbouring Water Suppliers.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> <li>Bulk supply available from a combination of<br/>Waingake (Including Waingake River or<br/>Mangapoike Dams) or Waipaoa WTPs.</li> </ul>   | Unlikely   | Major            | Medium        | Acceptable                     |
| 59 | Waipaoa          | Treatment    | Contamination or loss of supply due to<br>FILTRATION process failure (issue with preceding<br>treatment process, backwash system failure,<br>power failure, inadequate CWR level)   | 2          | 2        | 2        | ?            | Possible   | Catastrophic      | High          | <ul> <li>Waipaoa WTP: Four rapid sand Filters. Water<br/>and air backwash initiated on head loss, time,<br/>turbidity or manually (if required). Monitoring for<br/>turbidity on each filter. CCP limits and actions in<br/>place.</li> <li>Critical suppliers are communicated with<br/>regularly and updates are received when supply is</li> </ul>   | Unlikely   | Moderate         | Medium        | Acceptable                     |

|    |                  |              |  |            | Hazaro   | d Type   | e            | Maximu     | m (Unmitigated R | isk)          | Existing Preventive Measures   | Resid      | lual (Mitigated) F | lisk          |                                |
|----|------------------|--------------|--|------------|----------|----------|--------------|------------|------------------|---------------|--|------------|--------------------|---------------|--------------------------------|
| ID | Supply Component | Process Step | Hazardous Event  | Biological | Chemical | Physical | Radiological | Likelihood | Consequence      | Risk<br>Level | Description  | Likelihood | Consequence        | Risk<br>Level | Residual Risk<br>Acceptability |
| 60 | Waipaoa          | Treatment    | Contamination due to CHLORINE DISINFECTION<br>process failure - inadeguate chlorination (issue   | 2          | 2        | 2        |              | Possible   | Catastrophic     | High          | <ul> <li>expected to be low. Early ordering where</li> <li>possible. Shared inventory with other WTPs, GDC</li> <li>Pool and neighbouring Water Suppliers.</li> <li>Robust and detailed alarm system is in place to</li> <li>notify staff of any exceedance of limit or</li> <li>unexpected status change (i.e. power outage).</li> <li>Verification (validation) and standardisation</li> <li>(calibration) of online instrumentation carried out</li> <li>as per manufacturers recommendations and GDC</li> <li>procedures.</li> <li>On-line monitoring, telemetry to major sites for</li> <li>critical aspects of supply operation.</li> <li>Bulk supply available from a combination of</li> <li>Waingake (Including Waingake River or</li> <li>Mangapoike Dams) or Waipaoa WTPs.</li> <li>Permanent chlorination and residual</li> <li>disinfection process in place.</li> <li>UV disinfection process in place.</li> <li>Waipaoa WTP: Two 920kg drums of chlorine gas</li> <li>setup. Duty standby chlorinators with flow</li> </ul> | Rare       | Moderate           | Low           | Acceptable                     |
|    |                  |              | with preceding treatment process, chlorine gas<br>supply exhausted, dosing equipment failure,<br>incorrect dose rate, service water issue, short<br>contact time, power failure)   |            |          |          |              |            |                  |               | <ul> <li>proportional dosing. Monitoring for FAC at the</li> <li>FWS and CWR outlet. Contact time demonstrated in compliance reporting. CCP limits and actions in place.</li> <li>Critical suppliers are communicated with regularly and updates are received when supply is expected to be low. Early ordering where possible. Shared inventory with other WTPs, GDC Pool and neighbouring Water Suppliers.</li> <li>Robust and detailed alarm system is in place to notify staff of any exceedance of limit or unexpected status change (i.e. power outage).</li> <li>Verification (validation) and standardisation (calibration) of online instrumentation carried out as per manufacturers recommendations and GDC procedures.</li> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> <li>UV disinfection process in place.</li> </ul>   |            |                    |               |                                |
| 61 | Waipaoa          | Treatment    | Contamination due to CHLORINE DISINFECTION<br>process failure - over chlorination (issue with<br>preceding treatment process, dosing equipment<br>failure, incorrect dose rate, other contamination<br>during servicing maintenance) | 2          | 2        | 2        | 2            | Possible   | Major            | High          | <ul> <li>Waipaoa WTP: Two 920kg drums of chlorine gas setup. Duty standby chlorinators with flow proportional dosing. Monitoring for FAC at the FWS and CWR outlet. Contact time demonstrated in compliance reporting. CCP limits and actions in place.</li> <li>Robust and detailed alarm system is in place to notify staff of any exceedance of limit or unexpected status change (i.e., power outage).</li> <li>Verification (validation) and standardisation (calibration) of online instrumentation carried out as per manufacturers recommendations and GDC procedures.</li> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> </ul>  | Rare       | Major              | Medium        | Acceptable                     |

|    |                  |              |   |            | Hazaro   | І Туре   | !            | Maximu     | m (Unmitigated R | isk)          | Existing Preventive Measures  | Resid      | lual (Mitigated) | Risk          |                                |
|----|------------------|--------------|---|------------|----------|----------|--------------|------------|------------------|---------------|---|------------|------------------|---------------|--------------------------------|
| ID | Supply Component | Process Step | Hazardous Event   | Biological | Chemical | Physical | Radiological | Likelihood | Consequence      | Risk<br>Level | Description   | Likelihood | Consequence      | Risk<br>Level | Residual Risk<br>Acceptability |
| 62 | Waipaoa          | Treatment    | Contamination due to the chlorine reacting with<br>raw water contaminants causing disinfection by-<br>products  | 2          | 2        | ?        | 2            | Possible   | Major            | High          | <ul> <li>Waipaoa WTP: Two 920kg drums of chlorine gas<br/>setup. Duty standby chlorinators with flow<br/>proportional dosing. Monitoring for FAC at the<br/>FWS and CWR outlet. Contact time demonstrated<br/>in compliance reporting. CCP limits and actions in<br/>place.</li> <li>Sampling programme in place and<br/>prepared/checked against current standards or<br/>rules.</li> <li>Low FAC demand, colour testing carried out.</li> </ul>   | Unlikely   | Major            | Medium        | Acceptable                     |
| 63 | Waipaoa          | Treatment    | Contamination or loss of supply due to UV<br>DISINFECTION process failure (issue with<br>preceding treatment process, UV reactor failure,<br>power failure) | 2          |          | 2        | 2            | Possible   | Catastrophic     | High          | <ul> <li>Waipaoa WTP: Two UV reactors validated to 40 mJ/cm2. Maintained as per manufacturers requirements. Monitoring for UVT, UVI, flow and total lamp hours. CCP limits and actions in place.</li> <li>Critical suppliers are communicated with regularly and updates are received when supply is expected to be low. Early ordering where possible. Shared inventory with other WTPs, GDC Pool and neighbouring Water Suppliers.</li> <li>Robust and detailed alarm system is in place to notify staff of any exceedance of limit or unexpected status change (i.e. power outage).</li> <li>Verification (validation) and standardisation (calibration) of online instrumentation carried out as per manufacturers recommendations and GDC procedures.</li> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> <li>Permanent chlorination and residual disinfection process in place.</li> </ul> | Rare       | Moderate         | Low           | Acceptable                     |
| 64 | Waipaoa          | Treatment    | Contamination or loss of supply due to<br>unintentional or intentional vandalism of<br>treatment systems  | 2          | 2        | 2        | 2            | Possible   | Catastrophic     | High          | <ul> <li>Sites are secure with fences, locked gates or<br/>buildings in place.</li> <li>Regular inspection and maintenance<br/>programme in place with specialist contractors<br/>engaged where appropriate.</li> <li>Adequately trained staff for operations and<br/>maintenance (includes internal and external staff<br/>and trainees).</li> </ul>   | Rare       | Catastrophic     | Medium        | Acceptable                     |
| 65 | Waipaoa          | Treatment    | Contamination or loss of supply due to WTP bypass failure   | ?          | ?        | ?        | ?            | Unlikely   | Catastrophic     | High          | <ul> <li>WTP Bypass: Manually operated main line and<br/>bypass valves to ensure final treated water meets<br/>all requirements prior to supply to Distribution<br/>Network. No valve status captured or online<br/>monitoring.</li> </ul>  | Rare       | Minor            | Low           | Acceptable                     |
| 66 | Waipaoa          | Treatment    | Loss of supply due to compressed air system failure   | 2          | 2        | 2        | 2            | Likely     | Moderate         | High          | <ul> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> <li>Critical spares are available for bulk supply and treatment systems.</li> <li>Non-critical spare parts are held for some things and replacement spares parts are usually available overnight.</li> <li>Air compressors: Duty/standby and duty/assist system. Monitored for pressure. Alarming and response actions available.</li> </ul>   | Unlikely   | Moderate         | Medium        | Acceptable                     |
| 67 | Waipaoa          | Storage      | Contamination due to the integrity of reservoir being compromised - access by birds or vermin, or vandalism   | ?          | ?        | ?        | ?            | Possible   | Catastrophic     | High          | <ul> <li>Waipaoa WTP: 1,500 m3 partially below ground<br/>reservoir in place. All entry hatches are sealed and<br/>secure against ingress. Monitoring for level.</li> </ul>   | Rare       | Moderate         | Low           | Acceptable                     |

|    |                         |                                      |  |            | Hazar    | d Type   | !            | Maximur    | n (Unmitigated R | lisk)         | Existing Preventive Measures   | Resid      | lual (Mitigated) I | Risk          |                                |
|----|-------------------------|--------------------------------------|--|------------|----------|----------|--------------|------------|------------------|---------------|--|------------|--------------------|---------------|--------------------------------|
| ID | Supply Component        | Process Step                         | Hazardous Event  | Biological | Chemical | Physical | Radiological | Likelihood | Consequence      | Risk<br>Level | Description  | Likelihood | Consequence        | Risk<br>Level | Residual Risk<br>Acceptability |
|    |                         |                                      |  |            |          |          |              |            |                  |               | <ul> <li>Permanent chlorination and residual<br/>disinfection process in place.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> <li>Regular inspection and maintenance<br/>programme in place with specialist contractors<br/>engaged where appropriate.</li> </ul>   |            |                    |               |                                |
| 68 | Waipaoa                 | Storage                              | Loss of storage capacity due to earthquake<br>damage   | 2          | 2        | 2        | 2            | Rare       | Moderate         | Low           | <ul> <li>Waipaoa WTP: 1,500 m3 partially below ground reservoir in place. All entry hatches are sealed and secure against ingress. Monitoring for level.</li> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> <li>Regular inspection and maintenance programme in place with specialist contractors engaged where appropriate.</li> <li>Water conservation measures (water restrictions) can be implemented. Water Demand Management Plan Developed and being implemented.</li> <li>Bulk supply available from a combination of Waingake (Including Waingake River or Mangapoike Dams) or Waipaoa WTPs.</li> <li>Response plans are up to date and available.</li> </ul> | Rare       | Moderate           | Low           | Acceptable                     |
| 69 | Waipaoa                 | Storage                              | Contamination or loss of supply due to a minor<br>structural failure of reservoirs (including not<br>being detected) | 2          | 2        | 2        | 2            | Possible   | Major            | High          | <ul> <li>Waipaoa WTP: 1,500 m3 partially below ground<br/>reservoir in place. All entry hatches are sealed and<br/>secure against ingress. Monitoring for level.</li> <li>Permanent chlorination and residual<br/>disinfection process in place.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> <li>Regular inspection and maintenance<br/>programme in place with specialist contractors<br/>engaged where appropriate.</li> </ul>  | Rare       | Moderate           | Low           | Acceptable                     |
| 70 | Waipaoa                 | Storage                              | Contamination from insanitary practices during<br>inspections, observations, or maintenance of<br>reservoir          | 2          | 2        | 2        | 2            | Unlikely   | Catastrophic     | High          | <ul> <li>Waipaoa WTP: 1,500 m3 partially below ground<br/>reservoir in place. All entry hatches are sealed and<br/>secure against ingress. Monitoring for level.</li> <li>Permanent chlorination and residual<br/>disinfection process in place.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> <li>Regular inspection and maintenance<br/>programme in place with specialist contractors<br/>engaged where appropriate.</li> </ul>  | Rare       | Major              | Medium        | Acceptable                     |
| 71 | Waipaoa                 | Storage                              | Contamination from reservoir roof leakage  | 2          | 2        | 2        | 2            | Likely     | Catastrophic     | Extreme       | <ul> <li>Waipaoa WTP: 1,500 m3 partially below ground<br/>reservoir in place. All entry hatches are sealed and<br/>secure against ingress. Monitoring for level.</li> <li>Permanent chlorination and residual<br/>disinfection process in place.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> <li>Regular inspection and maintenance<br/>programme in place with specialist contractors<br/>engaged where appropriate.</li> </ul>  | Rare       | Moderate           | Low           | Acceptable                     |
| 72 | Distribution<br>Network | Distribution<br>Network –<br>Treated | Contamination or loss of supply due to failure/damage to bulk treated water main                                     | ?          | ?        | ?        | ?            | Possible   | Catastrophic     | High          | <ul> <li>Waingake Trunk Main: 525 mm CLMS trunk<br/>main from Waingake CWR outlet to Makaraka<br/>Pump Station. Location is recorded on GIS.</li> </ul>  | Unlikely   | Catastrophic       | High          | Unacceptable                   |

|    |                         |  |  |            | Hazaro   | d Type   | 9            | Maximur    | n (Unmitigated R | isk)          | Existing Preventive Measures   | Resid      | ual (Mitigated) | Risk          |                                |
|----|-------------------------|--|--|------------|----------|----------|--------------|------------|------------------|---------------|--|------------|-----------------|---------------|--------------------------------|
| ID | Supply Component        | Process Step   | Hazardous Event  | Biological | Chemical | Physical | Radiological | Likelihood | Consequence      | Risk<br>Level | Description  | Likelihood | Consequence     | Risk<br>Level | Residual Risk<br>Acceptability |
|    |                         | Water Trunk<br>Main<br>(Waingake to<br>Makaraka)   |  |            |          |          |              |            |                  |               | Pressure monitoring points in place, appropriate<br>backflow devices on known connections, high<br>hazard backflow devices tested annually, backflow<br>requirements outlined in Water Bylaw. Cathodic<br>protection and repairs recently carried out on<br>areas exposed to atmosphere and requiring<br>repair. Air valves and scour points in place. Major<br>crossings over Waingake and Waipaoa Rivers.<br>- Permanent chlorination and residual<br>disinfection process in place.<br>- On-line monitoring, telemetry to major sites for<br>critical aspects of supply operation.<br>- Regular inspection and maintenance<br>programme in place with specialist contractors<br>engaged where appropriate.<br>- FH: Operational procedures exist and driven by<br>OMMPs. Project specific procedures developed<br>when required. ISO 9001 accreditation in place.<br>Reviews and audits conducted as per quality<br>system.<br>- Critical spares are available for bulk supply and<br>treatment systems.  |            |                 |               |                                |
| 73 | Distribution<br>Network | Distribution<br>Network –<br>Treated<br>Water Trunk<br>Main<br>(Waingake to<br>Makaraka) | Contamination from insanitary practices during<br>maintenance or construction on bulk treated<br>water mains                                 | 2          | 2        | 2        | 2            | Unlikely   | Major            | Medium        | <ul> <li>Waingake Trunk Main: 525 mm CLMS trunk main from Waingake CWR outlet to Makaraka Pump Station. Location is recorded on GIS.</li> <li>Pressure monitoring points in place, appropriate backflow devices on known connections, high hazard backflow devices tested annually, backflow requirements outlined in Water Bylaw. Cathodic protection and repairs recently carried out on areas exposed to atmosphere and requiring repair. Air valves and scour points in place. Major crossings over Waingake and Waipaoa Rivers.</li> <li>Permanent chlorination and residual disinfection process in place.</li> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> <li>Regular inspection and maintenance programme in place with specialist contractors engaged where appropriate.</li> <li>Adequately trained staff for operations and maintenance (includes internal and external staff and trainees).</li> <li>FH: Operational procedures exist and driven by OMMPs. Project specific procedures developed when required. ISO 9001 accreditation in place. Reviews and audits conducted as per quality system.</li> <li>SOME major Distribution Network or civil works given oversight from GDC Staff regarding hygiene processes and testing.</li> </ul> | rare       | Major           | Medium        | Acceptable                     |
| 74 | Distribution<br>Network | Distribution<br>Network –<br>Treated<br>Water Trunk<br>Main                              | Loss of supply due to inaccurate/insufficient<br>asset information (material, location, condition,<br>criticality, scour valves, air valves) | ?          | ?        | ?        | 2            | Possible   | Moderate         | Medium        | - Waingake Trunk Main: 525 mm CLMS trunk<br>main from Waingake CWR outlet to Makaraka<br>Pump Station. Location is recorded on GIS.<br>Pressure monitoring points in place, appropriate<br>backflow devices on known connections, high   | Unlikely   | Moderate        | Medium        | Acceptable                     |

|    |                         |  |  |            | Hazaro   | і Туре   | !            | Maximu     | m (Unmitigated R | isk)          | Existing Preventive Measures   | Resid      | ual (Mitigated) I | Risk          |                                |
|----|-------------------------|--|--|------------|----------|----------|--------------|------------|------------------|---------------|--|------------|-------------------|---------------|--------------------------------|
| ID | Supply Component        | Process Step   | Hazardous Event  | Biological | Chemical | Physical | Radiological | Likelihood | Consequence      | Risk<br>Level | Description  | Likelihood | Consequence       | Risk<br>Level | Residual Risk<br>Acceptability |
|    |                         | (Waingake to<br>Makaraka)  |  |            |          |          |              |            |                  |               | hazard backflow devices tested annually, backflow<br>requirements outlined in Water Bylaw. Cathodic<br>protection and repairs recently carried out on<br>areas exposed to atmosphere and requiring<br>repair. Air valves and scour points in place. Major<br>crossings over Waingake and Waipaoa Rivers.<br>- Record keeping and reporting systems are<br>available and utilised (Objective, Ozone, IPS, Plant<br>Diary, GIS, Water Outlook, Hilltop, Vault, SCADA<br>Notes, Maximo (FH only)).  |            |                   |               |                                |
| 75 | Distribution<br>Network | Distribution<br>Network –<br>Treated<br>Water Trunk<br>Main<br>(Waingake to<br>Makaraka) | Loss of supply due to air relief valve inoperability<br>on the bulk treated water main   | 2          | 2        | 2        | 2            | Possible   | Moderate         | Medium        | <ul> <li>Waingake Trunk Main: 525 mm CLMS trunk<br/>main from Waingake CWR outlet to Makaraka<br/>Pump Station. Location is recorded on GIS.</li> <li>Pressure monitoring points in place, appropriate<br/>backflow devices on known connections, high<br/>hazard backflow devices tested annually, backflow<br/>requirements outlined in Water Bylaw. Cathodic<br/>protection and repairs recently carried out on<br/>areas exposed to atmosphere and requiring<br/>repair. Air valves and scour points in place. Major<br/>crossings over Waingake and Waipaoa Rivers.</li> <li>Regular inspection and maintenance<br/>programme in place with specialist contractors<br/>engaged where appropriate.</li> <li>Record keeping and reporting systems are<br/>available and utilised (Objective, Ozone, IPS, Plant<br/>Diary, GIS, Water Outlook, Hilltop, Vault, SCADA<br/>Notes, Maximo (FH only)).</li> </ul>      | Possible   | Moderate          | Medium        | Acceptable                     |
| 76 | Distribution<br>Network | Distribution<br>Network –<br>Treated<br>Water Trunk<br>Main<br>(Waingake to<br>Makaraka) | Loss of supply due to unidentified leakage, illegal<br>connections, unaccounted for water or high<br>demand from the bulk treated water main | 2          | 2        |          | 2            | Possible   | Moderate         | Medium        | <ul> <li>Waingake Trunk Main: 525 mm CLMS trunk<br/>main from Waingake CWR outlet to Makaraka</li> <li>Pump Station. Location is recorded on GIS.</li> <li>Pressure monitoring points in place, appropriate<br/>backflow devices on known connections, high<br/>hazard backflow devices tested annually, backflow<br/>requirements outlined in Water Bylaw. Cathodic<br/>protection and repairs recently carried out on<br/>areas exposed to atmosphere and requiring<br/>repair. Air valves and scour points in place. Major<br/>crossings over Waingake and Waipaoa Rivers.</li> <li>Regular inspection and maintenance<br/>programme in place with specialist contractors<br/>engaged where appropriate.</li> <li>Record keeping and reporting systems are<br/>available and utilised (Objective, Ozone, IPS, Plant<br/>Diary, GIS, Water Outlook, Hilltop, Vault, SCADA<br/>Notes, Maximo (FH only)).</li> </ul> | Possible   | Moderate          | Medium        | Acceptable                     |
| 77 | Distribution<br>Network | Distribution<br>Network –<br>Treated<br>Water Trunk<br>Main<br>(Waingake to<br>Makaraka) | Contamination from backflow event within bulk treated water main   | 2          | 2        | 2        | 2            | Likely     | Catastrophic     | Extreme       | - Waingake Trunk Main: 525 mm CLMS trunk<br>main from Waingake CWR outlet to Makaraka<br>Pump Station. Location is recorded on GIS.<br>Pressure monitoring points in place, appropriate<br>backflow devices on known connections, high<br>hazard backflow devices tested annually, backflow<br>requirements outlined in Water Bylaw. Cathodic<br>protection and repairs recently carried out on<br>areas exposed to atmosphere and requiring<br>repair. Air valves and scour points in place. Major  | Rare       | Catastrophic      | Medium        | Acceptable                     |

|    |                         |  |  |            | Hazar    | d Type   | 2            | Maximu     | m (Unmitigated R | Risk)         | Existing Preventive Measures  | Resid      | ual (Mitigated) | Risk          |                                |
|----|-------------------------|--|--|------------|----------|----------|--------------|------------|------------------|---------------|---|------------|-----------------|---------------|--------------------------------|
| ID | Supply Component        | Process Step   | Hazardous Event  | Biological | Chemical | Physical | Radiological | Likelihood | Consequence      | Risk<br>Level | Description   | Likelihood | Consequence     | Risk<br>Level | Residual Risk<br>Acceptability |
|    |                         |  |  |            |          |          |              |            |                  |               | <ul> <li>crossings over Waingake and Waipaoa Rivers.</li> <li>Regular inspection and maintenance</li> <li>programme in place with specialist contractors</li> <li>engaged where appropriate.</li> <li>Record keeping and reporting systems are</li> <li>available and utilised (Objective, Ozone, IPS, Plant</li> <li>Diary, GIS, Water Outlook, Hilltop, Vault, SCADA</li> <li>Notes, Maximo (FH only)).</li> </ul>  |            |                 |               |                                |
| 78 | Distribution<br>Network | Distribution<br>Network –<br>Treated<br>Water Trunk<br>Main<br>(Waingake to<br>Makaraka) | Loss of supply due to excessive demand,<br>inadequate or excessive pressures in the bulk<br>treated water main   | 2          | 2        | 2        | 2            | Likely     | Moderate         | High          | <ul> <li>Waingake Trunk Main: 525 mm CLMS trunk<br/>main from Waingake CWR outlet to Makaraka</li> <li>Pump Station. Location is recorded on GIS.</li> <li>Pressure monitoring points in place, appropriate<br/>backflow devices on known connections, high<br/>hazard backflow devices tested annually, backflow<br/>requirements outlined in Water Bylaw. Cathodic<br/>protection and repairs recently carried out on<br/>areas exposed to atmosphere and requiring<br/>repair. Air valves and scour points in place. Major<br/>crossings over Waingake and Waipaoa Rivers.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> </ul>  | Possible   | Moderate        | Medium        | Acceptable                     |
| 79 | Distribution<br>Network | Distribution<br>Network –<br>Treated<br>Water Trunk<br>Main<br>(Waingake to<br>Makaraka) | Contamination or loss of supply due to poor<br>quality workmanship, inappropriate materials<br>used or contractor damage to bulk treated water<br>main during construction (repair or renewal) |            | 2        |          |              | Possible   | Major            | High          | <ul> <li>Waingake Trunk Main: 525 mm CLMS trunk<br/>main from Waingake CWR outlet to Makaraka<br/>Pump Station. Location is recorded on GIS.</li> <li>Pressure monitoring points in place, appropriate<br/>backflow devices on known connections, high<br/>hazard backflow devices tested annually, backflow<br/>requirements outlined in Water Bylaw. Cathodic<br/>protection and repairs recently carried out on<br/>areas exposed to atmosphere and requiring<br/>repair. Air valves and scour points in place. Major<br/>crossings over Waingake and Waipaoa Rivers.</li> <li>Maintenance and replacement work are<br/>undertaken by Fulton Hogan or authorised<br/>contracting companies.</li> <li>GDC requires all work and materials used in<br/>Distribution Network to meet the Engineering<br/>Code of Practice.</li> <li>Project planning across capital and operations<br/>team.</li> </ul> | Unlikely   | Major           | Medium        | Acceptable                     |
| 80 | Distribution<br>Network | Distribution<br>Network  | Contamination or loss of supply due to<br>Distribution Network failure   | 2          | 2        | 2        | 2            | Likely     | Catastrophic     | Extreme       | <ul> <li>Additional supply options available including operating valves, supplying from alternative reservoirs and the use of Ormond Rd pump station.</li> <li>Maintenance and replacement work are undertaken by Fulton Hogan or authorised contracting companies.</li> <li>24/7 request for service system available for observations made by the public (i.e. mains break, loss of water, loss of pressure, quality complaints).</li> <li>Repairs and replacements identified as necessary during testing are followed up on promptly.</li> <li>Permanent chlorination and residual disinfection process in place.</li> </ul>  | Rare       | Catastrophic    | Medium        | Acceptable                     |

|    |                         |                         |   |            | Hazaro   | d Type   |              | Maximu     | m (Unmitigated R | tisk)         | Existing Preventive Measures  | Resid      | lual (Mitigated) I | Risk          |                                |
|----|-------------------------|-------------------------|---|------------|----------|----------|--------------|------------|------------------|---------------|---|------------|--------------------|---------------|--------------------------------|
| ID | Supply Component        | Process Step            | Hazardous Event   | Biological | Chemical | Physical | Radiological | Likelihood | Consequence      | Risk<br>Level | Description   | Likelihood | Consequence        | Risk<br>Level | Residual Risk<br>Acceptability |
| 81 | Distribution<br>Network | Distribution<br>Network | Contamination from insanitary practices during<br>inspections, sampling, maintenance, or<br>construction within Distribution Network system     | 2          | 2        | 2        | 2            | Possible   | Major            | High          | <ul> <li>Maintenance and replacement work are<br/>undertaken by Fulton Hogan or authorised<br/>contracting companies.</li> <li>Sampling points and locations have been<br/>upgraded/amended to allow minimal<br/>contamination to occur during sampling.</li> <li>Adequately trained staff for operations and<br/>maintenance (includes internal and external staff<br/>and trainees).</li> <li>Permanent chlorination and residual<br/>disinfection process in place.</li> </ul>   | Unlikely   | Major              | Medium        | Acceptable                     |
| 82 | Distribution<br>Network | Distribution<br>Network | Loss of supply due to inaccurate/insufficient<br>asset information (material, location, condition,<br>criticality)                              | 2          | 2        | 2        | 2            | Likely     | Moderate         | High          | <ul> <li>Record keeping and reporting systems are<br/>available and utilised (Objective, Ozone, IPS, Plant<br/>Diary, GIS, Water Outlook, Hilltop, Vault, SCADA<br/>Notes, Maximo (FH only)).</li> <li>Pipe and reservoir condition assessments<br/>conducted.</li> <li>GDC is a member of the 'BeforeUdig' system<br/>used to manage contractors and the public<br/>excavating within road reserve</li> </ul>  | Unlikely   | Moderate           | Medium        | Acceptable                     |
| 83 | Distribution<br>Network | Distribution<br>Network | Loss of supply due to unidentified leakage, illegal connections or unaccounted for water  | 2          | 2        |          | 2            | Possible   | Moderate         | Medium        | <ul> <li>Regular inspection and maintenance<br/>programme in place with specialist contractors<br/>engaged where appropriate.</li> <li>Record keeping and reporting systems are<br/>available and utilised (Objective, Ozone, IPS, Plant<br/>Diary, GIS, Water Outlook, Hilltop, Vault, SCADA<br/>Notes, Maximo (FH only)).</li> <li>Council wide Distribution Network renewals<br/>programme is in place.</li> <li>GDC requires all work and materials used in<br/>Distribution Network to meet the Engineering<br/>Code of Practice.</li> <li>Hydraulic Model is in place for Gisborne Water<br/>Supply.</li> </ul> | Rare       | Moderate           | Low           | Acceptable                     |
| 84 | Distribution<br>Network | Distribution<br>Network | Contamination from backflow event within<br>Distribution Network system (including change of<br>premise use)                                    | 2          | 2        | 2        | 2            | Likely     | Catastrophic     | Extreme       | <ul> <li>Regular inspection and maintenance<br/>programme in place with specialist contractors<br/>engaged where appropriate.</li> <li>Record keeping and reporting systems are<br/>available and utilised (Objective, Ozone, IPS, Plant<br/>Diary, GIS, Water Outlook, Hilltop, Vault, SCADA<br/>Notes, Maximo (FH only)).</li> <li>Council wide Distribution Network renewals<br/>programme is in place.</li> <li>GDC requires all work and materials used in<br/>Distribution Network to meet the Engineering<br/>Code of Practice.</li> </ul>   | Unlikely   | Catastrophic       | High          | Unacceptable                   |
| 85 | Distribution<br>Network | Distribution<br>Network | Loss of supply due to excessive demand,<br>inadequate or excessive pressures in the<br>network or a lack of agreed allocation to large<br>users | 2          | 2        | 2        | 2            | Likely     | Catastrophic     | Extreme       | <ul> <li>Hydraulic Model is in place for Gisborne Water<br/>Supply.</li> <li>Makaraka Pump Station: Three booster pumps<br/>in duty/duty/standby arrangement. Main pump<br/>station governing flow from Waingake WTP.</li> <li>Gravity flow through Bermad up to 700 m3 and<br/>pumped when &gt;700m3. high lift pumps controlled<br/>by SCADA setpoint. Monitoring for flow, pressure,<br/>bermad valve position and pump status. No<br/>backup power options available but can continue</li> </ul>  | Unlikely   | Catastrophic       | High          | Unacceptable                   |

|    |                         |   |   |            | Hazaro   | l Type   | :            | Maximu     | n (Unmitigated Ri | isk)          | Existing Preventive Measures   | Resid      | lual (Mitigated) I | Risk          |                                |
|----|-------------------------|---|---|------------|----------|----------|--------------|------------|-------------------|---------------|--|------------|--------------------|---------------|--------------------------------|
| ID | Supply Component        | Process Step                                  | Hazardous Event   | Biological | Chemical | Physical | Radiological | Likelihood | Consequence       | Risk<br>Level | Description  | Likelihood | Consequence        | Risk<br>Level | Residual Risk<br>Acceptability |
|    |                         |   |   |            |          |          |              |            |                   |               | <ul> <li>to operate under gravity.</li> <li>Distribution Reservoir storage available:</li> <li>Hospital Hill 38,000m3. Nob Hill 8,000m3. Several small high-level reservoirs.</li> <li>Ormond Rd Pump Station: Single booster pump in place to boost flow to Nob Hill Reservoir and the eastern side of the city Distribution Network. Monitoring for pressure and pump status. No backup power options available.</li> </ul>  |            |                    |               |                                |
| 86 | Distribution<br>Network | Distribution<br>Network                       | Contamination due to poor quality workmanship,<br>inappropriate materials used for Distribution<br>Network pipes and fittings or contractor damage<br>to pipes                        | 2          | 2        | 2        | 2            | Possible   | Major             | High          | <ul> <li>Maintenance and replacement work are<br/>undertaken by Fulton Hogan or authorised<br/>contracting companies.</li> <li>GDC requires all work and materials used in<br/>Distribution Network to meet the Engineering<br/>Code of Practice.</li> <li>SOME major Distribution Network or civil works<br/>given oversight from GDC Staff regarding hygiene<br/>processes and testing.</li> <li>GDC is a member of the 'BeforeUdig' system<br/>used to manage contractors and the public<br/>excavating within road reserve</li> </ul>  | Rare       | Major              | Medium        | Acceptable                     |
| 87 | Distribution<br>Network | Distribution<br>Network                       | Contamination or loss of supply due to degrading<br>treated water supply caused by the extent of<br>Distribution Network network (pipeline to<br>Muriwai and Patutahi, low FAC areas) | 2          | 2        | 2        | 2            | Possible   | Catastrophic      | High          | <ul> <li>Hospital Hill Chlorination: Two 70 kg cylinders of<br/>chlorine gas setup. Duty standby chlorinators<br/>with high rate and low rate setpoint dosing.<br/>Monitoring for FAC at the reservoir outlet.<br/>Duty/standby carry water and sample pumps.<br/>Reservoir outflow is dosed to achieve a fixed<br/>setpoint. PLC setup to ensure that overdosing.</li> <li>Regular inspection and maintenance<br/>programme in place with specialist contractors<br/>engaged where appropriate.</li> <li>Hydraulic Model is in place for Gisborne Water<br/>Supply.</li> </ul>  | Unlikely   | Catastrophic       | High          | Unacceptable                   |
| 88 | Distribution<br>Network | Distribution<br>Network –<br>Pump<br>Stations | Contamination or loss of supply due to damage<br>to the pump stations   | 2          | 2        |          | 2            | Possible   | Major             | High          | <ul> <li>Regular inspection and maintenance<br/>programme in place with specialist contractors<br/>engaged where appropriate.</li> <li>PLCs are setup to allow plants to continue<br/>operating in its last status if comms are lost.</li> <li>Sites are secure with fences, locked gates or<br/>buildings in place.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> <li>Makaraka Pump Station: Three booster pumps<br/>in duty/duty/standby arrangement. Main pump<br/>station governing flow from Waingake WTP.</li> <li>Gravity flow through Bermad up to 700 m3 and<br/>pumped when &gt;700m3. high lift pumps controlled<br/>by SCADA setpoint. Monitoring for flow, pressure,<br/>bermad valve position and pump status. No<br/>backup power options available but can continue<br/>to operate under gravity.</li> <li>Ormond Rd Pump Station: Single booster pump<br/>in place to boost flow to Nob Hill Reservoir and<br/>the eastern side of the city Distribution Network.<br/>Monitoring for pressure and pump status. No<br/>backup power options available.</li> </ul> | Rare       | Major              | Medium        | Acceptable                     |

|    |                         |   |   |            | Hazar    | d Type   | e            | Maximur    | n (Unmitigated Ri | isk)          | Existing Preventive Measures  | Resid      | lual (Mitigated) I | Risk          |                                |
|----|-------------------------|---|---|------------|----------|----------|--------------|------------|-------------------|---------------|---|------------|--------------------|---------------|--------------------------------|
| ID | Supply Component        | Process Step                                  | Hazardous Event   | Biological | Chemical | Physical | Radiological | Likelihood | Consequence       | Risk<br>Level | Description   | Likelihood | Consequence        | Risk<br>Level | Residual Risk<br>Acceptability |
|    |                         |   |   |            |          |          |              |            |                   |               | <ul> <li>Hillview Terrace Pump Station: Three booster<br/>pumps in duty/assist/standby arrangement.</li> <li>Monitoring for pressure and pump status but<br/>does not feed into SCADA system. Standby<br/>generator onsite and permanently connected.</li> </ul>  |            |                    |               |                                |
| 89 | Distribution<br>Network | Distribution<br>Network –<br>Pump<br>Stations | Loss of supply due to loss of power at the pump<br>stations   | 2          | 2        | 2        | 2            | Likely     | Major             | High          | <ul> <li>PLCs are setup to allow plants to continue operating in its last status if comms are lost.</li> <li>Generator connection available.</li> <li>Makaraka Pump Station: Three booster pumps in duty/duty/standby arrangement. Main pump station governing flow from Waingake WTP.</li> <li>Gravity flow through Bermad up to 700 m3 and pumped when &gt;700m3. high lift pumps controlled by SCADA setpoint. Monitoring for flow, pressure, bermad valve position and pump status. No backup power options available but can continue to operate under gravity.</li> <li>Ormond Rd Pump Station: Single booster pump in place to boost flow to Nob Hill Reservoir and the eastern side of the city Distribution Network. Monitoring for pressure and pump status. No backup power options available.</li> <li>Hillview Terrace Pump Station: Three booster pumps in duty/assist/standby arrangement. Monitoring for pressure and pump status but does not feed into SCADA system. Standby generator onsite and permanently connected.</li> </ul> | Unlikely   | Major              | Medium        | Acceptable                     |
| 90 | Distribution<br>Network | Distribution<br>Network –<br>Pump<br>Stations | Contamination from insanitary practices during<br>maintenance or construction within pump<br>stations | 2          | 2        | 2        | 2            | Possible   | Major             | High          | <ul> <li>Maintenance and replacement work are<br/>undertaken by Fulton Hogan or authorised<br/>contracting companies.</li> <li>Sampling points and locations have been<br/>upgraded/amended to allow minimal<br/>contamination to occur during sampling.</li> <li>Adequately trained staff for operations and<br/>maintenance (includes internal and external staff<br/>and trainees).</li> <li>Permanent chlorination and residual<br/>disinfection process in place.</li> </ul>   | Rare       | Major              | Medium        | Acceptable                     |
| 91 | Distribution<br>Network | Distribution<br>Network –<br>Pump<br>Stations | Loss of supply due to excessive demand,<br>inadequate or excessive pressures in the<br>network        | 2          |          | 2        | 2            | Likely     | Moderate          | High          | <ul> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> <li>Makaraka Pump Station: Three booster pumps in duty/duty/standby arrangement. Main pump station governing flow from Waingake WTP.</li> <li>Gravity flow through Bermad up to 700 m3 and pumped when &gt;700m3. high lift pumps controlled by SCADA setpoint. Monitoring for flow, pressure, bermad valve position and pump status. No backup power options available but can continue to operate under gravity.</li> <li>Ormond Rd Pump Station: Single booster pump in place to boost flow to Nob Hill Reservoir and the eastern side of the city Distribution Network. Monitoring for pressure and pump status. No backup power options available.</li> <li>Hillview Terrace Pump Station: Three booster pumps in duty/assist/standby arrangement.</li> </ul>   | Rare       | Major              | Medium        | Acceptable                     |

|    |                         |   |  |            | Hazar    | d Type   | l            | Maximur    | n (Unmitigated R | isk)          | Existing Preventive Measures   | Resid      | ual (Mitigated) | Risk          |                                |
|----|-------------------------|---|--|------------|----------|----------|--------------|------------|------------------|---------------|--|------------|-----------------|---------------|--------------------------------|
| ID | Supply Component        | Process Step                                  | Hazardous Event  | Biological | Chemical | Physical | Radiological | Likelihood | Consequence      | Risk<br>Level | Description  | Likelihood | Consequence     | Risk<br>Level | Residual Risk<br>Acceptability |
| 92 | Distribution<br>Network | Distribution<br>Network –<br>Pump<br>Stations | Contamination due to Chlorine Disinfection<br>process failure - inadequate chlorination (issue<br>with stored water in reservoir, chlorine gas<br>supply exhausted, dosing equipment failure,<br>incorrect dose rate, service water issue, power<br>failure) | 2          | 2        | 2        | 2            | Possible   | Major            | High          | Monitoring for pressure and pump status but<br>does not feed into SCADA system. Standby<br>generator onsite and permanently connected.<br>- Hospital Hill Chlorination: Two 70 kg cylinders of<br>chlorine gas setup. Duty standby chlorinators<br>with high rate and low rate setpoint dosing.<br>Monitoring for FAC at the reservoir outlet.<br>Duty/standby carry water and sample pumps.<br>Reservoir outflow is dosed to achieve a fixed<br>setpoint. PLC setup to ensure that overdosing.<br>- On-line monitoring, telemetry to major sites for<br>critical aspects of supply operation.<br>- Regular inspection and maintenance<br>programme in place with specialist contractors<br>engaged where appropriate.<br>- Sampling programme in place and<br>prepared/checked against current standards or<br>rules. | Unlikely   | Moderate        | Medium        | Acceptable                     |
| 93 | Distribution<br>Network | Distribution<br>Network –<br>Pump<br>Stations | Contamination due to Chlorine Disinfection<br>process failure - over chlorination (dosing<br>equipment failure, incorrect dose rate, other<br>contamination during servicing maintenance)  | 2          | 2        | 2        | 2            | Possible   | Major            | High          | <ul> <li>Hospital Hill Chlorination: Two 70 kg cylinders of chlorine gas setup. Duty standby chlorinators with high rate and low rate setpoint dosing. Monitoring for FAC at the reservoir outlet. Duty/standby carry water and sample pumps. Reservoir outflow is dosed to achieve a fixed setpoint. PLC setup to ensure that overdosing.</li> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> <li>Regular inspection and maintenance programme in place with specialist contractors engaged where appropriate.</li> <li>Sampling programme in place and prepared/checked against current standards or rules.</li> </ul>  | Rare       | Moderate        | Low           | Acceptable                     |
| 94 | Distribution<br>Network | Distribution<br>Network –<br>Reservoirs       | Contamination due to the integrity of reservoir<br>being compromised - access by birds or vermin,<br>or vandalism  | 2          | 2        | 2        | 2            | Likely     | Catastrophic     | Extreme       | <ul> <li>Distribution Reservoir storage available:</li> <li>Hospital Hill 38,000m3. Nob Hill 8,000m3. Several small high-level reservoirs.</li> <li>Permanent chlorination and residual disinfection process in place.</li> <li>Regular inspection and maintenance programme in place with specialist contractors engaged where appropriate.</li> <li>Hospital Hill Chlorination: Two 70 kg cylinders of chlorine gas setup. Duty standby chlorinators with high rate and low rate setpoint dosing. Monitoring for FAC at the reservoir outlet. Duty/standby carry water and sample pumps. Reservoir outflow is dosed to achieve a fixed setpoint. PLC setup to ensure that overdosing.</li> </ul>   | Rare       | Catastrophic    | Medium        | Acceptable                     |
| 95 | Distribution<br>Network | Distribution<br>Network –<br>Reservoirs       | Loss of storage capacity due to earthquake<br>damage   | 2          | 2        | 2        | 2            | Rare       | Major            | Medium        | <ul> <li>Distribution Reservoir storage available:</li> <li>Hospital Hill 38,000m3. Nob Hill 8,000m3. Several small high-level reservoirs.</li> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> <li>Regular inspection and maintenance programme in place with specialist contractors engaged where appropriate.</li> </ul>  | Unlikely   | Major           | Medium        | Acceptable                     |

|     |                         |   |  |            | Hazar    | d Type   | ļ            | Maximur    | n (Unmitigated R | isk)          | Existing Preventive Measures   | Resid      | lual (Mitigated) | Risk          |                                |
|-----|-------------------------|---|--|------------|----------|----------|--------------|------------|------------------|---------------|--|------------|------------------|---------------|--------------------------------|
| ID  | Supply Component        | Process Step                            | Hazardous Event  | Biological | Chemical | Physical | Radiological | Likelihood | Consequence      | Risk<br>Level | Description  | Likelihood | Consequence      | Risk<br>Level | Residual Risk<br>Acceptability |
|     |                         |   |  |            |          |          |              |            |                  |               | <ul> <li>Water conservation measures (water restrictions) can be implemented. Water Demand Management Plan Developed and being implemented.</li> <li>Bulk supply available from a combination of Waingake (Including Waingake River or Mangapoike Dams) or Waipaoa WTPs.</li> <li>Response plans are up to date and available.</li> </ul>  |            |                  |               |                                |
| 96  | Distribution<br>Network | Distribution<br>Network –<br>Reservoirs | Contamination or loss of supply due to a minor<br>structural failure of reservoirs (including not<br>being detected)   | 2          | 2        | 2        | 2            | Possible   | Major            | High          | <ul> <li>Distribution Reservoir storage available:</li> <li>Hospital Hill 38,000m3. Nob Hill 8,000m3. Several small high-level reservoirs.</li> <li>Permanent chlorination and residual disinfection process in place.</li> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> <li>Regular inspection and maintenance programme in place with specialist contractors engaged where appropriate.</li> </ul>  | Rare       | Major            | Medium        | Acceptable                     |
| 97  | Distribution<br>Network | Distribution<br>Network –<br>Reservoirs | Contamination from insanitary practices during<br>inspections, observations, or maintenance of<br>reservoir  | 2          | 2        | 2        | 2            | Possible   | Catastrophic     | High          | <ul> <li>Distribution Reservoir storage available:</li> <li>Hospital Hill 38,000m3. Nob Hill 8,000m3. Several small high-level reservoirs.</li> <li>Contractors/staff required to operate in accordance with specific procedures prepared and approved for each maintenance, entry or cleaning activity</li> <li>Permanent chlorination and residual disinfection process in place.</li> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> <li>Regular inspection and maintenance programme in place with specialist contractors engaged where appropriate.</li> </ul> | Rare       | Catastrophic     | Medium        | Acceptable                     |
| 98  | Distribution<br>Network | Distribution<br>Network –<br>Reservoirs | Contamination from reservoir roof leakage  | 2          | 2        | 2        | 2            | Likely     | Catastrophic     | Extreme       | <ul> <li>Distribution Reservoir storage available:</li> <li>Hospital Hill 38,000m3. Nob Hill 8,000m3. Several small high-level reservoirs.</li> <li>Permanent chlorination and residual disinfection process in place.</li> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> <li>Regular inspection and maintenance programme in place with specialist contractors engaged where appropriate.</li> </ul>  | Rare       | Catastrophic     | Medium        | Acceptable                     |
| 99  | General                 | Barrier<br>Management                   | Loss of supply due to inaccurate/insufficient asset information (material, location, condition, criticality)   | ?          | ?        | ?        | ?            | Possible   | Major            | High          | <ul> <li>Record keeping and reporting systems are<br/>available and utilised (Objective, Ozone, IPS, Plant<br/>Diary, GIS, Water Outlook, Hilltop, Vault, SCADA<br/>Notes, Maximo (FH only)).</li> </ul>   | Rare       | Major            | Medium        | Acceptable                     |
| 100 | General                 | Barrier<br>Management                   | Contamination or loss of supply due to<br>insufficient, inadequate out of date or incorrect<br>manuals, operational procedures or Quality<br>Management System | 2          | 2        | 2        | 2            | Likely     | Moderate         | High          | <ul> <li>GDC: Operational procedures exist in QMS for<br/>water treatment staff and SOPs for<br/>sampling/monitoring staff. These documents<br/>continue to be reviewed and updated. Reviews<br/>and audits as per quality system.</li> <li>FH: Operational procedures exist and driven by<br/>OMMPs. Project specific procedures developed<br/>when required. ISO 9001 accreditation in place.<br/>Reviews and audits conducted as per quality<br/>system.</li> </ul>   | Rare       | Moderate         | Low           | Acceptable                     |

|     |                  |                            |  |            | Hazar    | d Type   | 9            | Maximur        | n (Unmitigated R | lisk)         | Existing Preventive Measures  | Resid      | lual (Mitigated) I | Risk          |                                |
|-----|------------------|----------------------------|--|------------|----------|----------|--------------|----------------|------------------|---------------|---|------------|--------------------|---------------|--------------------------------|
| ID  | Supply Component | Process Step               | Hazardous Event  | Biological | Chemical | Physical | Radiological | Likelihood     | Consequence      | Risk<br>Level | Description   | Likelihood | Consequence        | Risk<br>Level | Residual Risk<br>Acceptability |
|     |                  |                            |  |            |          |          |              |                |                  |               | - Commissioning planning and commissioning  |            |                    |               |                                |
| 101 | General          | Barrier<br>Management      | Contamination or loss of supply due to<br>inadequate critical spare parts held or<br>unavailable   | 2          | 2        | 2        | 2            | Possible       | Moderate         | Medium        | <ul> <li>Critical spares are available for bulk supply and treatment systems.</li> <li>Non-critical spare parts are held for some things and replacement spares parts are usually available overnight.</li> <li>Standardisation of assets where possible.</li> <li>Some preferred supplier arrangements are in place, contractor ensures inventory of high use stock, and critical spare lists held by GDC and contractor.</li> </ul>   | Rare       | Minor              | Low           | Acceptable                     |
| 102 | General          | Barrier<br>Management      | Contamination or loss of supply due to<br>inadequate training, professional development,<br>up-skilling, or ongoing competency of water staff<br>(Council and Contractors)   | 2          | 2        | 2        | ?            | Almost Certain | Major            | Extreme       | <ul> <li>External staff competency assessment for<br/>crucial support roles that contractors perform.</li> <li>On-going training and up-skilling are provided<br/>for operators and the maintenance staff.</li> <li>Contracts/service level agreements in place for<br/>specialised but critical aspects of the water supply<br/>operation (includes sampling, lab testing,<br/>chemical supply, I&amp;E services, equipment<br/>servicing and maintenance).</li> </ul>   | Possible   | Major              | High          | Unacceptable                   |
| 103 | General          | Barrier<br>Management      | Contamination or loss of supply due to<br>inadequate staff resourcing (includes<br>subcontractors)   | ?          | ?        | ?        | ?            | Possible       | Major            | High          | - Adequately trained staff for operations and maintenance (includes internal and external staff and trainees).  | Possible   | Major              | High          | Unacceptable                   |
| 104 | General          | Barrier<br>Management      | Contamination or loss of supply due to<br>inadequate inspections, preventive maintenance<br>or replacement of critical treatment systems and<br>monitoring equipment causing failures  | 2          | 2        | 2        | 2            | Likely         | Major            | High          | <ul> <li>Regular inspection and maintenance<br/>programme in place with specialist contractors<br/>engaged where appropriate.</li> <li>Verification (validation) and standardisation<br/>(calibration) of online instrumentation carried out<br/>as per manufacturers recommendations and GDC<br/>procedures.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> <li>Robust and detailed alarm system is in place to<br/>notify staff of any exceedance of limit or<br/>unexpected status change (i.e., power outage).</li> </ul> | Unlikely   | Major              | Medium        | Acceptable                     |
| 105 | General          | Barrier<br>Management      | Contamination or loss of supply due to<br>inadequate inspections, Preventive maintenance,<br>or replacement of critical treatment structures<br>(intake, dams, treatment systems, reservoirs<br>(WTP), bulk raw/treated main, pump stations,<br>reservoirs (Distribution Network)) causing<br>failures | 2          | 2        | 2        | ?            | Unlikely       | Moderate         | Medium        | <ul> <li>Regular inspection and maintenance<br/>programme in place with specialist contractors<br/>engaged where appropriate.</li> <li>Condition assessments of critical infrastructure<br/>carried out as per schedule.</li> </ul>   | Unlikely   | Major              | Medium        | Acceptable                     |
| 106 | General          | Barrier<br>Management      | Contamination or loss of supply due to supply chain issues (i.e., Chemicals, equipment)  | 2          | 2        | 2        | ?            | Possible       | Major            | High          | <ul> <li>Critical suppliers are communicated with<br/>regularly and updates are received when supply is<br/>expected to be low. Early ordering where<br/>possible. Shared inventory with other WTPs, GDC<br/>Pool and neighbouring Water Suppliers.</li> <li>Bulk supply available from a combination of<br/>Waingake (Including Waingake River or<br/>Mangapoike Dams) or Waipaoa WTPs.</li> </ul>   | Unlikely   | Major              | Medium        | Acceptable                     |
| 107 | General          | Verification<br>Monitoring | Contamination is not identified due to sampling and monitoring not being sufficient  | 2          | 2        | 2        | ?            | Likely         | Major            | High          | <ul> <li>Sampling programme in place and<br/>prepared/checked against current standards or<br/>rules.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> </ul>  | Possible   | Major              | High          | Unacceptable                   |

|     |                  |                            |   |            | Hazar    | d Type   | :            | Maximu     | m (Unmitigated F | Risk)         | Existing Preventive Measures   | Resid      | lual (Mitigated) | Risk          |                                |
|-----|------------------|----------------------------|---|------------|----------|----------|--------------|------------|------------------|---------------|--|------------|------------------|---------------|--------------------------------|
| ID  | Supply Component | Process Step               | Hazardous Event   | Biological | Chemical | Physical | Radiological | Likelihood | Consequence      | Risk<br>Level | Description  | Likelihood | Consequence      | Risk<br>Level | Residual Risk<br>Acceptability |
| 108 | General          | Verification<br>Monitoring | Contamination or loss or supply not identified<br>due to inadequate data collection and reporting<br>systems (includes PLC, SCADA, Water Outlook<br>and communications systems) | 2          | 2        | 2        | 2            | Likely     | Major            | High          | <ul> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> <li>Instrumentation and SCADA system supported and maintained by competent specialist contractor.</li> <li>Critical I&amp;E changes (i.e., PLC) are limited to selected staff only and hardcoding has been setup on critical setpoints.</li> <li>Robust and detailed alarm system is in place to notify staff of any exceedance of limit or unexpected status change (i.e., power outage).</li> </ul>   | Possible   | Major            | High          | Unacceptable                   |
| 109 | General          | Verification<br>Monitoring | Contamination not identified or loss of supply<br>due to critical instrumentation failure (normal<br>calibration)   | 2          | 2        | 2        | 2            | Likely     | Moderate         | High          | <ul> <li>Verification (validation) and standardisation<br/>(calibration) of online instrumentation carried out<br/>as per manufacturers recommendations and GDC<br/>procedures.</li> <li>On-line monitoring, telemetry to major sites for<br/>critical aspects of supply operation.</li> <li>Instrumentation and SCADA system supported<br/>and maintained by competent specialist<br/>contractor.</li> <li>Critical I&amp;E changes (i.e. PLC) are limited to<br/>selected staff only and hardcoding has been setup<br/>on critical setpoints.</li> <li>Robust and detailed alarm system is in place to<br/>notify staff of any exceedance of limit or<br/>unexpected status change (i.e. power outage).</li> <li>Regular inspection and maintenance<br/>programme in place with specialist contractors<br/>engaged where appropriate.</li> </ul> | Unlikely   | Moderate         | Medium        | Acceptable                     |
| 110 | General          | Verification<br>Monitoring | Contamination not identified due to incorrect<br>setup of critical instrumentation during<br>commissioning (span, calibration, flow rates etc.)                                 | ?          | 2        | 2        | ?            | Unlikely   | Moderate         | Medium        | <ul> <li>Commissioning planning and commissioning<br/>offline undertaken where possible</li> <li>Verification (validation) and standardisation<br/>(calibration) of online instrumentation carried out<br/>as per manufacturers recommendations and GDC<br/>procedures.</li> </ul>   | Unlikely   | Moderate         | Medium        | Acceptable                     |
| 111 | General          | Verification<br>Monitoring | Contamination not identified due to critical<br>instrumentation drift over time   | ?          | ?        | ?        | ?            | Possible   | Moderate         | Medium        | <ul> <li>Verification (validation) and standardisation<br/>(calibration) of online instrumentation carried out<br/>as per manufacturers recommendations and GDC<br/>procedures.</li> </ul>   | Unlikely   | Moderate         | Medium        | Acceptable                     |
| 112 | General          | Verification<br>Monitoring | Contamination or loss of supply due to inadequate reporting from observations, inspections or maintenance   | ?          | ?        | ?        | ?            | Likely     | Moderate         | High          | <ul> <li>Record keeping and reporting systems are<br/>available and utilised (Objective, Ozone, IPS, Plant<br/>Diary, GIS, Water Outlook, Hilltop, Vault, SCADA<br/>Notes, Maximo (FH only)).</li> </ul>   | Unlikely   | Moderate         | Medium        | Acceptable                     |
| 113 | General          | Other                      | Contamination due to inadequate treatment processes   | ?          | ?        | ?        | ?            | Likely     | Catastrophic     | Extreme       | <ul> <li>Council reviews legislation, standards, policies,<br/>bylaws and service requirements during the 3<br/>yearly development of the Water Asset<br/>Management Plan and Long Term Plan.</li> </ul>   | Possible   | Major            | High          | Unacceptable                   |
| 114 | General          | Other                      | Loss of supply due to major structural failure of<br>critical structures (Dams, intakes, pump stations,<br>Water Treatment Plants, Reservoirs)                                  | ?          | 2        | 2        | ?            | Rare       | Major            | Medium        | <ul> <li>Condition assessments of critical infrastructure carried out as per schedule.</li> <li>On-line monitoring, telemetry to major sites for critical aspects of supply operation.</li> <li>Robust and detailed alarm system is in place to notify staff of any exceedance of limit or unexpected status change (i.e., power outage).</li> </ul>   | Rare       | Major            | Medium        | Acceptable                     |
|     |                  |              |   | Hazard 1   |          | lazard Type |              | Maximum (Unmitigated Risk) |              | Risk)         | Existing Preventive Measures   |            | Residual (Mitigated) Risk |               |                                |
|-----|------------------|--------------|---|------------|----------|-------------|--------------|----------------------------|--------------|---------------|--|------------|---------------------------|---------------|--------------------------------|
| ID  | Supply Component | Process Step | Hazardous Event   | Biological | Chemical | Physical    | Radiological | Likelihood                 | Consequence  | Risk<br>Level | Description  | Likelihood | Consequence               | Risk<br>Level | Residual Risk<br>Acceptability |
| 115 | General          | Other        | Contamination or loss of supply due to a<br>catastrophic natural disaster or failure including<br>earthquake, flooding, volcanic eruption, wildfire | ?          | 2        | 2           | 2            | Rare                       | Catastrophic | Medium        | <ul> <li>Water conservation measures (water restrictions) can be implemented. Water Demand Management Plan Developed and being implemented.</li> <li>Bulk supply available from a combination of Waingake (Including Waingake River or Mangapoike Dams) or Waipaoa WTPs.</li> <li>Response plans are up to date and available.</li> <li>Actively engaged with emergency response organisations.</li> </ul> | Rare       | Catastrophic              | Medium        | Acceptable                     |
| 116 | General          | Other        | Contamination or loss of supply due to changes<br>in legislation, standards, organisational policy,<br>bylaws, codes of practices or any other      | ?          | ?        | ?           | ?            | Likely                     | Catastrophic | Extreme       | <ul> <li>Council reviews legislation, standards, policies,<br/>bylaws and service requirements during the 3<br/>yearly development of the Water Asset<br/>Management Plan and Long Term Plan.</li> </ul>   | Possible   | Major                     | High          | Unacceptable                   |
| 117 | General          | Other        | Loss of supply linked to water demand issues<br>(expansion of network, pressure issues, leak<br>management)   | ?          | ?        | ?           | ?            | Likely                     | Major        | High          | <ul> <li>Bulk supply available from a combination of<br/>Waingake (Including Waingake River or<br/>Mangapoike Dams) or Waipaoa WTPs.</li> <li>Water conservation measures (water<br/>restrictions) can be implemented. Water Demand<br/>Management Plan Developed and being<br/>implemented.</li> </ul>  | Possible   | Major                     | High          | Unacceptable                   |

| Variable   | Units     | MAV (GV)           | 2022     | 2019 | 2017 |
|--|-----------|--------------------|----------|------|------|
| Chloride   |           |                    | 12.7     |      |      |
| Nitrate (as N)   |           |                    | 0.0071   |      |      |
| Nitrite (as N)   |           |                    | <0.002   |      |      |
| Sulphate   |           |                    | 4.9      |      |      |
| Bromate  |           |                    | <0.005   |      |      |
| Bromide  |           |                    | 0.012    |      |      |
| Chlorate   |           |                    | <0.01    |      |      |
| Chlorite   |           |                    | <0.005   |      |      |
| Ammoniacal Nitrogen (as N)   | mg/L      | n/a                | <0.005   |      |      |
| Conductivity (@25°)  | mS/m      | n/a                | 20.0     |      |      |
| Dissolved Oxygen   |           |                    | 11.0     |      |      |
| Dissolved Reactive Phosphorus (as P)                                       |           |                    | 0.004    |      |      |
| Fluoride   | mg/L      | 1.5                | 0.4      |      |      |
| Molybdate Reactive Silica (as SiO2)  | mg/L      | n/a                | 10.2     |      |      |
| Nitrate (as NO3) + Nitrite (as NO2)  |           |                    | 0.031    |      |      |
| Nitrate (as NO3)   |           |                    | 0.031    |      |      |
| Nitrate (as N) + Nitrate (as N)  |           |                    | 0.007    |      |      |
| Nitrite (as NO2)   |           | <0.007             |          |      |      |
| pH (at room temp c. 20 °C)   | pH unit   | (7.0-8.5)          | 7.6      |      |      |
| Total Alkalinity (as CaCO3)  | mg/L      | (100-300)          | 48       |      |      |
| Total Cyanide  | mg/L      | 0.6                | <0.005   |      |      |
| Total Dissolved Alkalinity (as CaCO3)                                      |           |                    | 42       |      |      |
| Turbidity  | NTU       | (4)                | 0.25     |      |      |
| UVT at 254 nm  | abs units | n/a                | 66.3     |      |      |
| Metals (Total)   | mg/L      |                    | ND       | ND   | ND   |
| Antimony, Beryllium, Cadmium, Chromium, Lead, Mercury, Molybdenum, Nickel, |           |                    |          |      |      |
| Selenium, Silver, Tin, Zinc  |           |                    |          |      |      |
| Aluminium  |           |                    | 0.097    |      |      |
| Arsenic  | mg/L      | 0.01               | 0.00031  |      |      |
| Barium   | mg/L      | 1.5                | 0.01     |      |      |
| Boron  | mg/L      | 2.4                | 0.026    |      |      |
| Calcium  | mg/L      | See total hardness | 18       |      |      |
| Calcium (as CaCO3)   |           |                    | -        |      |      |
| Copper   | mg/L      | (2)                | 0.006    |      |      |
| Iron   | mg/L      | (0.3)              | 0.0027   |      |      |
| Lithium  | mg/L      | n/a                | 0.0031   |      |      |
| Magnesium  | mg/L      | See total hardness | 1.7      |      |      |
| Magnesium Hardness (as CaCO3)  |           |                    | -        |      |      |
| Manganese  | mg/L      | 0.4 (0.10)         | 0.00096  |      |      |
| Potassium  |           |                    | 0.84     |      |      |
| Sodium   |           |                    | 9.9      |      |      |
| Total Hardness (as CaCO3)  |           |                    | 51       |      |      |
| Uranium  |           |                    | 0.000021 |      |      |