



State of Louisiana  
DEPARTMENT OF ENVIRONMENTAL QUALITY  
OFFICE OF ENVIRONMENTAL COMPLIANCE

Southeast Regional Office  
Hazardous Waste Compliance Inspection Report

Inspection Date: 04/12/2023; 04/24/2023 Incident No.: T213615; T213760; T213972; T214194

AI No.: 5673 Alt. ID/ Permit No.: LAD981511850

Facility Name: Sewerage & Water Board of New Orleans – Carrollton Water Purification Plant

Physical Location: 8800 S. Claiborne Avenue

New Orleans LA Parish: Orleans  
(City) (State)

Mailing Address: 8800 S. Claiborne Avenue New Orleans LA 70118  
(Address) (City) (State) (Zip)

Facility Representative/Title: Anita Williams / Environmental Enforcement Tech.; Scott Finney / Senior MS4 Manager

Facility Representative Telephone No.: 504-865-0662

LDEQ Lead Inspector: Von A. Magee

Other Inspectors: Daniel Cristina

Report By:  6/19/23  
Von A. Magee, Environmental Scientist IV (Date)

Reviewed By:  6/28/23  
Dionne Magness, Environmental Scientist Supervisor (Date)



AI No.: 5673

AI Name: Sewerage & Water Board of New Orleans – Carrollton Water Purification Plant

Alt. ID/Permit No.: LAD981511850

Date of Inspection: 04/12/2023; 04/24/2023

## INTRODUCTION

Between 04/09/2023 through 05/19/2023, LDEQ received multiple complaints (T213615; T213760; T214194) regarding a release of oil from the Turbine 5 exhaust stack at the Sewerage and Water Board of New Orleans (SWBNO) Carrollton Water Purification Plant. According to the complaints, oil droplets are spraying from the exhaust stack and impacting adjacent homes, cars, and property along Spruce Street.

Additionally, the SWBNO self-reported a release which occurred on 05/01/2023 at approximately 11:00:00. Among other information, this notification also indicates the possibility of remedial action achieved via wiping and/or washing of surfaces.

Reported discharge dates and times provided with the complaints/notifications are as follows:

<u>Complaint Number</u>	<u>Discharge Date</u>	<u>Noticed Time Began</u>	<u>Noticed Time Ended</u>	<u>Notes:</u>
T213615	04/09/2023	09:00:00	05:00:00	Reported by complainant ( <b>Attachment 1</b> )
T213760	04/18/2023	06:30:00	07:45:00	Reported by complainant ( <b>Attachment 1</b> )
Complaint to EPA-ECHO	04/30/2023	Sometime overnight		Reported by complainant ( <b>Attachment 1</b> )
T213972	05/01/2023	11:00:00	Not Provided	Reported by SWBNO ( <b>Attachment 1</b> )
T214194	05/17/2023	05:00:00	08:00:00	Reported by complainant ( <b>Attachment 1</b> )

## FACILITY INFORMATION

This facility is owned and operated by Sewerage and Water Board of New Orleans (SWBNO). The facility is located at 8800 S. Claiborne Avenue, New Orleans, Orleans Parish and treats raw river intake water for treatment into drinking water via a coagulation, flocculation, disinfection, and filtration treatment process.

Additionally, the onsite power plant produces power via boilers to drive steam turbines which generate electricity. Power generated supplies some of the potable water inlet pumps and most of the drainage pumping station system for the City of New Orleans.

Turbines T4 and T5 are required to produce 25 cycle power to the equipment/pumps utilized for drainage. Currently turbine T4 is not operational and T5 is being utilized.

### Compliance History

The following Enforcement Actions were issued:

- Compliance Order WE-C-18-00624 on 05/03/2019 (EDMS Document ID# 11651815);
- Compliance Order AE-C-19-00536 on 10/08/2020 (EDMS Document ID# 12389659);
- Compliance Order WE-C-21-00834 on 04/13/2022 (EDMS Document ID# 13225854);
- Warning Letter AE-L-22-00365 on 04/25/2022 (EDMS Document ID# 13263624);
- Compliance Order HE-C-22-00472 on 07/20/2022 (EDMS Document ID# 13386667); and
- Notice of Potential Penalty WE-PP-23-00163 on 03/15/2023 (EDMS Document ID# 13734857).

Compliance Order HE-C-22-00472 is also relevant to oil releases from turbine T5.



AI No.: 5673

AI Name: Sewerage & Water Board of New Orleans – Carrollton Water Purification Plant

Alt. ID/Permit No.: LAD981511850

Date of Inspection: 04/12/2023; 04/24/2023

## AREAS EVALUATED

This inspection was conducted to document observations following the afore mentioned series of complaints with regard to oil discharges from the turbine T5 exhaust and also to obtain relevant information as follow-up to the conditions and responses in-line with previously issued Compliance Order HE-C-22-00472. I conducted a file review of the EDMS database to review the relevant compliance order and associated facility responses. LDEQ Enforcement Division was consulted with regard to obtaining specific follow-up information relevant to the previously mentioned compliance order.

The inspection included a review of the facility response to Compliance Order HE-C-22-00472 (EDMS Document ID# 13449186); observations of vehicles and residences along Spruce Street; an on-site discussion with Ms. Anita Williams; and email correspondences with facility personnel to request relevant records and information.

## OBSERVATIONS

On 04/12/2023, Mr. Cristina and I travelled along Spruce Street which is adjacent to and in a Southwest general direct with regard to the SWBNO turbine T5 exhaust stack. At the time of this visit, Mr. Cristina and I observed droplet/staining on vehicles parked along Spruce Street (**Attachment 2 and Attachment 3: Photographs 1-5, 04/12/2023**). This material is visually consistent with that depicted by Photographs 4-11 within the 03/04/2022 inspection report (INS20220003) (**Attachment 4**).

On 04/12/2023 and 04/21/2023, I requested additional information and records from Mr. Scott Finney, Senior MS4 Storm Water Manager with SWBNO. These items were requested as follow-up information to the reports of oil being discharged from the Turbine T5 exhaust stack and also to corrective actions following issuance of Compliance Order HE-C-22-00472. The responses and supporting documents/records I received on 04/14/2023 and 04/26/2023 (**Attachment 5**) were forwarded to LDEQ Enforcement Division on 05/02/2023 for further review and evaluation against the information and details discussed within, as well as response provided subsequently to the issuance of, Compliance Order HE-C-22-00472. Please note, both the 09/07/2022 and 09/08/2022 #5 turbine logs do not include second pages. It is not known if the date input on one or both of these forms is in error, if the second pages were omitted, or if the second pages were not completed.

On 04/24/2023, I met with the complainant at their residence. The complainant directed me to staining on the entry railing, bicycle seat cover, and lawn furniture at this location (**Attachment 3: Photographs 1-3, 04/24/2023**). The complainant stated the material observed was droplet staining and is the result of material emitted from turbine T5. Please note, there was a rain event beginning at the time of these observations.

On 05/09/2023, I conducted a full Compliance Evaluation Inspection at this facility location. This inspection was conducted to evaluate compliance with the facility's LPDES discharge permit and LAC 33:IX regulations. During this site visit, I observed droplet/staining on a blue hose and also on a red building wall near the turbine T5 exhaust stack (**Attachment 3: Photograph 1, 05/09/2023**). This observation is visually consistent with those made of material on the vehicles along Spruce Street during the 04/12/2023 observations, and those depicted by Photograph 3 within the 03/04/2022 inspection report (INS20220003) (**Attachment 4**).



AI No.: 5673

AI Name: Sewerage & Water Board of New Orleans – Carrollton Water Purification Plant

Alt. ID/Permit No.: LAD981511850

Date of Inspection: 04/12/2023; 04/24/2023

## SUMMARY

1. **LAC 33:V.4013.E.3 – The owner/operator failed to clean up and/or properly manage released used oil, in violation of LAC 33:V.4013.E.3. Specifically, the facility experienced spills of used oil (MOBIL DTE 732) from the Turbine T5 exhaust onto facility grounds and the adjacent residential neighborhood on Spruce Street.**

The information obtained was forwarded to LDEQ Enforcement Division on 05/02/2023 for further review and evaluation against the information and details discussed within, as well as response provided subsequently to issuance of, Compliance order HE-C-22-00472.



AI No.: 5673

AI Name: Sewerage & Water Board of New Orleans – Carrollton Water Purification Plant

Alt. ID/Permit No.: LAD981511850

Date of Inspection: 04/12/2023; 04/24/2023

## **LIST OF ATTACHMENTS**

- |                     |  |
|---------------------|--|
| <b>ATTACHMENT 1</b> | <b>Incident/Complaint Reports (EPA-ECHO; T213615; T213760; T213972; T214194)</b> |
| <b>ATTACHMENT 2</b> | <b>Field Interview Form (FIF)</b>  |
| <b>ATTACHMENT 3</b> | <b>Photographs</b>   |
| <b>ATTACHMENT 4</b> | <b>03/02/2022 Inspection Report, INS20220003 (Relevant Pages)</b>                |
| <b>ATTACHMENT 5</b> | <b>Email Correspondences (Provided Information/Records)</b>                      |
| <b>ATTACHMENT 6</b> | <b>Safety Data Sheet (MOBIL DTE 732)</b>   |



AI No.: 5673

AI Name: Sewerage & Water Board of New Orleans – Carrollton Water Purification Plant

Alt. ID/Permit No.: LAD981511850

Date of Inspection: 04/12/2023; 04/24/2023

## **ATTACHMENT 1**

**Incident/Complaint Reports (EPA-ECHO; T213615;  
T213760; T213972; T214194)**



[Login](#) [Contact Us](#)

Your report has been successfully sent. Your confirmation is below.

## Report Environmental Violations - Submitted

Thank you for submitting information on a possible environmental violation. The information will be reviewed by EPA enforcement personnel.

This notice will be the only response you will receive regarding your submission. Due to the sensitive manner in which enforcement information must be managed by EPA, we cannot provide status reports or updates regarding any submission we receive through the Report Environmental Violations form.

[Back to Report Environmental Violations page](#)

## Report Confirmation

Received	May 3, 2023 at 5:09pm EDT
Your Name	Ariane Livaudais
Your Email	arianelivaudais@gmail.com
Your Phone Number	985-807-3566
Suspected Violator's Name *	Sewerage and Water Board New Orleans
Suspected Violation Location *	8800 S Claiborne

Suspected Violation City *	New Orleans
Suspected Violation State *	Louisiana
Suspected Violation ZIP Code *	70118
Responsible Party	Government/Military
Is the suspected violation still occurring?	Yes
Date of Incident	
Characterized incident as:	
Intention *	Accidental
Violation Method *	Spray
Affected Subject(s)	Land, Air



Violation Description *	The SWBNO's Turbine 5 (T5) is in use and spraying turbine oil onto property/vehicles/homes located on Spruce Street from General Ogden to Leonidas. This was first reported to the LDEQ and the EPA back in March 2022. T5 recently came back online and the first day the oil spray was noticed this time was on 4/9/23 then again on 4/18/23 and again on 4/30/23. These recent incidents have all been reported to the LDEQ and the assigned officer is Von.Magee@LA.GOV. My name is Ariane Livaudais and the resident/owner of 8608 Spruce Street. Photos attached of my property which evidence the oil droplets. My number is 985.807.3566 and my email is arianelivaudais@gmail.com.
File(s) Uploaded	<ol style="list-style-type: none"><li>1. IMG_9319.jpeg (image/jpeg)</li><li>2. IMG_9311.jpeg (image/jpeg)</li><li>3. IMG_9305.jpeg (image/jpeg)</li></ol>

LAST UPDATED ON OCTOBER 3, 2022

[DATA REFRESH INFORMATION](#)

## INCIDENT REPORT

Incident:213615

**Incident Description**

**Incident Type:** Complaint, Oil Sheen Sighting  
**Incident Date:** 04/09/2023 09:00:00  
**Parish:** Orleans  
**Municipality:** New Orleans  
**Location:** 8800 S Carrollton - New Orleans

**Lat/Lon:** /

**Basin/Segment:**

**Substance(s):**

**Media Impacted:** Soil/Air

**Incident Desc:** COMPLAINT T5 has been running and it seems it's leaking oil/diesel again. This is the second documents occurrence. I first reported to LQEQ in March 2022 and an inspection was done on 3/4/22. I took photos of my home (8608 Spruce) and some neighbors' cars parked on Spruce between Monroe and Leonidas. I emailed these photos directly to the SWBNO today. col (see T 207469 for previous complaint)

**Incident Status**

**Lead Investigator:** Von Magee  
**Incident Region:** Southeast  
**Incident Status:** Closed  
**Followup Status:** Closed  
**As Of:** 06/19/2023 13:58:05

**Incident Reporter 1**

**Received By:** Spo Contact  
**Received Date:** 04/09/2023 16:24:00  
**Dispatch Number(s):** OC5243, OC5244  
**Reported By:** Ariane Livaudais  
**Phone:** 504-264-2750 (Cellular phone number)  
**Reporter Title:**  
**Organization:**  
**Address:** 8608 Spruce St  
  
**Municipality:** New Orleans  
**State:** LA  
**Zip Code:** 70118  
**Comments:** OC5244 duplicate



## INCIDENT REPORT

Incident:213615

**Incident Source 1**

**Source Name:** Sewerage & Water Board of New Orleans -  
Carrollton Water Purification Plant  
**Address:** 8800 S Claiborne Ave

**Municipality:** New Orleans

**State:** LA

**Phone:** 5049423856(Work phone number)

**Parish:**

**AI #:** 5673

**Related Permits:**

**Comments:** Between 04/09/2023 through 05/19/2023, LDEQ received multiple complaints (T213615; T213760; T214194) regarding a release of oil from the Turbine 5 exhaust stack at the Sewerage and Water Board of New Orleans (SWBNO) Carrollton Water Purification Plant. According to the complaints, oil droplets are spraying from the exhaust stack and impacting adjacent homes, cars, and property along Spruce Street. Additionally, the SWBNO self-reported a release which occurred on 05/01/2023 at approximately 11:00:00. Among other information, this notification also indicates the possibility of remedial action achieved via wiping and/or washing of surfaces. This response included a review of the facility response to Compliance Order HE-C-22-00472 (EDMS Document ID# 13449186); observations of vehicles and residences along Spruce Street; an on-site discussion with Ms. Anita Williams; and email correspondences with facility personnel to request relevant records and information. Information and findings obtained were forwarded to LDEQ Enforcement Division on 05/02/2023 for further review and evaluation against the information and details discussed within, as well as response provided subsequently to issuance of, Compliance order HE-C-22-00472. Please refer to INS20230005 for additional details. On 06/28/2023, I contacted the complainant to inform of this path forward; I left a voice message requested a return call for further discussion. vam

## Von Magee

---

**From:** Holly Herrmann  
**Sent:** Tuesday, April 11, 2023 2:48 PM  
**To:** Von Magee  
**Cc:** Daniel Cristina; Jeffrey Leonick; Dionne Magness; Jeffrey Parham; Joe Carruth; Jodi Holewka; Holly Herrmann  
**Subject:** RE: SERO Complaint T 213615 OrleansParish oil-diesel OC5243

Von – assigned to you.

Daniel will need to go out with you for this one.  
AI# 5673

Joe- disregard the previous email.

*Holly Herrmann*  
*LA DEQ - Southeast Regional Office*  
*Office: 504-736-7749*  
*[holly.herrmann@la.gov](mailto:holly.herrmann@la.gov)*

---

**From:** SPOC <[SinglePointof.Contact@LA.GOV](mailto:SinglePointof.Contact@LA.GOV)>  
**Sent:** Tuesday, April 11, 2023 11:07 AM  
**To:** \_DEQ-SEROAdmin <[DEQ-SEROAdmin@LA.GOV](mailto:DEQ-SEROAdmin@LA.GOV)>  
**Subject:** SERO Complaint T 213615 OrleansParish oil-diesel OC5243

SERO Complaint T 213615 OrleansParish oil-diesel OC5243

<http://advantagerm.swe.la.gov/Pages/Incidents/IncidentDetailPage.aspx?IncidentID=213615&State=EDIT&WholeUpdate=Y>

---

**From:** EML-SVC-DEQ-Intranet  
**Sent:** Sunday, April 9, 2023 4:24 PM  
**To:** SPOC  
**Cc:** [arianelivaudais@gmail.com](mailto:arianelivaudais@gmail.com)  
**Subject:** Online Citizen Complaint: Confirmation: OC5243 - 4/9/2023 4:24:55 PM

Caller Information	
* First Name:	Ariane
* Last Name:	Livaudais
* Phone Number:	504-264-2750
Mailing Address:	8608 Spruce Street
City:	NEW ORLEANS
State:	Louisiana
Email:	<a href="mailto:arianelivaudais@gmail.com">arianelivaudais@gmail.com</a>
Zip:	70118
I request a follow-up on inspector findings:	Yes
Site Information	



Alleged Violator:	SWNBO Carrollton
* Physical Location/Address:	8800 S Carrollton
* City:	NEW ORLEANS
* State:	Louisiana
Zip:	70118
Date of Discharge:	04/09/2023
Noticed Time Began:	09:00:00
Noticed Time Ended:	05:00:00
* Parish of Occurrence:	Orleans Parish
Media Affected:	soil/air
If water, name the nearest water body:	
Description of complaint:	T5 has been running and it seems it's leaking oil/diesel again. This is the second documents occurrence. I first reported to LQEQ in March 2022 and an inspection was done on 3/4/22. I took photos of my home (8608 Spruce) and some neighbors' cars parked on Spruce between Monroe and Leonidas. I emailed these photos directly to the SWBNO today.
Directions for reaching the site:	

## INCIDENT REPORT

Incident:213760

**Incident Description**

**Incident Type:** Complaint, Miscellaneous  
**Incident Date:** 04/18/2023 06:30:00  
**Parish:** Orleans  
**Municipality:** New Orleans  
**Location:** 8800 S Claiborne - New Orleans, LA

**Lat/Lon:** /  
**Basin/Segment:**  
**Substance(s):**  
**Media Impacted:** Soil/Air  
**Incident Desc:** Complaint SWBNO has been running T5 since 4/3/23 and oil droplets continue to spray the homes, cars and property on Spruce Street residents. LB

**Incident Status**

**Lead Investigator:** Von Magee  
**Incident Region:** Southeast  
**Incident Status:** Closed  
**Followup Status:** Closed  
**As Of:** 06/19/2023 14:06:46

**Incident Reporter 1**

**Received By:** Spo Contact  
**Received Date:** 04/19/2023 08:57:00  
**Dispatch Number(s):** OC5283  
**Reported By:** Ariane Livaudais  
**Phone:** 985-897-3566 (Home phone number)  
**Reporter Title:**  
**Organization:**  
**Address:** 8608 Spruce St.

**Municipality:** New Orleans  
**State:** LA  
**Zip Code:** 70118  
**Comments:**



## INCIDENT REPORT

Incident:213760

**Incident Source 1**

**Source Name:** Sewerage & Water Board of New Orleans -  
Carrollton Water Purification Plant  
**Address:** 8800 S Claiborne Ave

**Municipality:** New Orleans

**State:** LA

**Phone:** 5049423856(Work phone number)

**Parish:**

**AI #:** 5673

**Related Permits:**

**Comments:** Between 04/09/2023 through 05/19/2023, LDEQ received multiple complaints (T213615; T213760; T214194) regarding a release of oil from the Turbine 5 exhaust stack at the Sewerage and Water Board of New Orleans (SWBNO) Carrollton Water Purification Plant. According to the complaints, oil droplets are spraying from the exhaust stack and impacting adjacent homes, cars, and property along Spruce Street. Additionally, the SWBNO self-reported a release which occurred on 05/01/2023 at approximately 11:00:00. Among other information, this notification also indicates the possibility of remedial action achieved via wiping and/or washing of surfaces. This response included a review of the facility response to Compliance Order HE-C-22-00472 (EDMS Document ID# 13449186); observations of vehicles and residences along Spruce Street; an on-site discussion with Ms. Anita Williams; and email correspondences with facility personnel to request relevant records and information. Information and findings obtained were forwarded to LDEQ Enforcement Division on 05/02/2023 for further review and evaluation against the information and details discussed within, as well as response provided subsequently to issuance of, Compliance order HE-C-22-00472. Please refer to INS20230005 for additional details. On 06/28/2023, I contacted the complainant to inform of this path forward; I left a voice message requested a return call for further discussion. vam

## Von Magee

---

**From:** Jeffrey Parham  
**Sent:** Wednesday, April 19, 2023 2:24 PM  
**To:** Von Magee  
**Cc:** Dionne Magness; Holly Herrmann  
**Subject:** FW: SERO Complaint T 213760 Oil Orleans OC5283

Von – assigned to you

Jeff Parham  
(504) 736-7754

---

**From:** SPOC <SinglePointof.Contact@LA.GOV>  
**Sent:** Wednesday, April 19, 2023 9:38 AM  
**To:** \_DEQ-SEROAdmin <\_DEQ-SEROAdmin@LA.GOV>  
**Cc:** SPOC <SinglePointof.Contact@LA.GOV>  
**Subject:** SERO Complaint T 213760 Oil Orleans OC5283

SERO Complaint T 213760 Oil Orleans OC5283

<http://advantagerm.swe.la.gov/Pages/Incidents/IncidentListPage.aspx?IncidentID=213760>

---

**From:** EML-SVC-DEQ-Intranet  
**Sent:** Wednesday, April 19, 2023 8:57 AM  
**To:** SPOC  
**Cc:** [arianelivaudais@gmail.com](mailto:arianelivaudais@gmail.com)  
**Subject:** Online Citizen Complaint: Confirmation: OC5283 - 4/19/2023 8:57:21 AM

<b>Caller Information</b>	
* First Name:	Ariane
* Last Name:	Livaudais
* Phone Number:	985-897-3566
Mailing Address:	8608 Spruce St
City:	New Orleans
State:	Louisiana
Email:	<a href="mailto:arianelivaudais@gmail.com">arianelivaudais@gmail.com</a>
Zip:	70118
I request a follow-up on inspector findings:	Yes
<b>Site Information</b>	
Alleged Violator:	SWBNO Carrollton Plant
* Physical Location/Address:	8800 S Claiborne
* City:	New Orleans
* State:	Louisiana
Zip:	70118
Date of Discharge:	04/18/2023
Noticed Time Began:	06:30:00
Noticed Time Ended:	07:45:00



* Parish of Occurrence:	Orleans Parish
Media Affected:	soil/air
If water, name the nearest water body:	
* Description of complaint:	SWBNO has been running T5 since 4/3/23 and oil droplets continue to spray the homes, cars and property on Spruce Street residents. See 4/18/23 article below. <a href="https://thelensnola.org/2023/04/18/oil-sprayed-on-neighborhood-from-swb-plant-for-second-time/">https://thelensnola.org/2023/04/18/oil-sprayed-on-neighborhood-from-swb-plant-for-second-time/</a>
Directions for reaching the site:	All of Spruce Street home and cars from Eagle to Leonidas

## INCIDENT REPORT

Incident:213972

**Incident Description**

**Incident Type:** Release/Spill, Miscellaneous  
**Incident Date:** 05/01/2023 11:00:00  
**Parish:** Orleans  
**Municipality:** New Orleans  
**Location:** 8800 South Claiborne Avenue - New Orleans

**Lat/Lon:** /  
**Basin/Segment:**  
**Substance(s):** Petroleum Based Product unknown quantity  
**Media Impacted:** Soil/Air  
**Incident Desc:** SPILL Release of petroleum based product from a leaking turbine CML

**Incident Status**

**Lead Investigator:** Von Magee  
**Incident Region:** Southeast  
**Incident Status:** Closed  
**Followup Status:** Closed  
**As Of:** 06/19/2023 14:11:40

**Incident Reporter 1**

**Received By:** Spo Contact  
**Received Date:** 05/02/2023 23:13:00  
**Dispatch Number(s):** OS2205  
**Reported By:** Corwin Washington  
**Phone:** 504-930-7250 (Work phone number)  
**Reporter Title:**  
**Organization:** Sewerage and Water Board of New Orleans  
**Address:**

**Municipality:**  
**State:** LA  
**Zip Code:**  
**Comments:**



## INCIDENT REPORT

Incident:213972

**Incident Source 1**

**Source Name:** Sewerage & Water Board of New Orleans -  
Carrollton Water Purification Plant

**Address:** 8800 S Claiborne Ave

**Municipality:** New Orleans

**State:** LA

**Phone:** 5049423856(Work phone number)

**Parish:**

**AI #:** 5673

**Related Permits:**

**Comments:** On 05/02/2023, LDEQ received a self-reported notification from the Sewerage and Water Board of New Orleans (SWBNO) regarding a Turbine T5 oil release which migrated offsite and impacted the 8600 block of Spruce Street.

Between 04/09/2023 through 05/19/2023, LDEQ also received multiple complaints (T213615; T213760; T214194) regarding a release of oil from the Turbine 5 exhaust stack at the SWBNO Carrollton Water Purification Plant. According to the complaints, oil droplets are spraying from the exhaust stack and impacting adjacent homes, cars, and property along Spruce Street. Additionally, the SWBNO self-reported a release which occurred on 05/01/2023 at approximately 11:00:00. Among other information, this notification also indicates the possibility of remedial action achieved via wiping and/or washing of surfaces. This response included a review of the facility response to Compliance Order HE-C-22-00472 (EDMS Document ID# 13449186); observations of vehicles and residences along Spruce Street; an on-site discussion with Ms. Anita Williams; and email correspondences with facility personnel to request relevant records and information. Information and findings obtained were forwarded to LDEQ Enforcement Division on 05/02/2023 for further review and evaluation against the information and details discussed within, as well as response provided subsequently to issuance of, Compliance order HE-C-22-00472.  
vam

## Von Magee

---

**From:** Jeffrey Parham  
**Sent:** Wednesday, May 3, 2023 1:04 PM  
**To:** Von Magee  
**Cc:** Dionne Magness; Holly Herrmann  
**Subject:** FW: SERO SPILL T 213972 Orleans OS2205

Von – assigned to you

Jeff Parham  
(504) 736-7754

---

**From:** SPOC <SinglePointof.Contact@LA.GOV>  
**Sent:** Wednesday, May 3, 2023 10:50 AM  
**To:** \_DEQ-SEROAdmin <\_DEQ-SEROAdmin@LA.GOV>  
**Cc:** SPOC <SinglePointof.Contact@LA.GOV>  
**Subject:** SERO SPILL T 213972 Orleans OS2205

SERO SPILL T 213972 Orleans OS2205

<http://advantagerm.swe.la.gov/Pages/Incidents/IncidentDetailPage.aspx?IncidentID=213972&State=EDIT&WholeUpdate=Y>

**Sent:** Tuesday, May 2, 2023 11:13 PM  
**Subject:** Online Spill Report: Confirmation: OS2205 - 5/2/2023 11:13:26 PM

Reference Information	
Louisiana State Police HazMat Hotline Report Number (if applicable):	Louisiana
National Response Center Number (if applicable):	
AI Number:	5673
Permit Number:	2140-00128-V3
Reporter Information	
* First Name:	Corwin
* Last Name:	Washington
Title:	
* Company:	Sewerage and Water Board of New Orleans
* Phone Number:	504-930-7250
Mailing Address:	8800 South Claiborne Avenue
City:	New Orleans
State:	Louisiana
Zip:	70118
Email:	cwashington3@swbno.org
Responsible Party Information	
* Responsible Party Company name:	Sewerage and Water Board of New Orleans
Mailing address (if different from above):	
City:	
State:	
Zip:	
Physical Location of Incident	



* Address:	8800 South Claiborne Avenue
* City:	New Orleans
* State:	Louisiana
* Parish of Occurrence:	Orleans Parish
<b>Incident Details</b>	
* Date of Discharge:	05/01/2023
* Noticed Time Began:	11:00:00
Noticed Time Ended:	
* Media Affected:	soil/air
If water, name the nearest water body:	
If air, note wind direction and weather conditions:	Approximately a 14 mph, southwest wind was recorded during a clear sky at approximately 72 degrees Fahrenheit.
* Product / Material release and quantity:	Petroleum-based product
* Description of release:	An unknown amount of a petroleum-based product was unintentionally discharged via Turbine No. 5, which migrated offsite and observed near the 8600 Block of Spruce Street. No individual was outside when the discharged occurred. Evidence of a release was observed by the droplets appearing on inanimate objects. The exact time of the release and direct cause has yet to be determined at this time.
How was the spill contained?	The release appears to be intermittent since the Sewerage and Water Board of New Orleans went over a year from the initial incident that was investigated by the LDEQ on or about March 4, 2022.
How was the spill cleaned?	The material can be remediated by wiping and/or washing of surfaces. Some areas are stained and there is no means to remediate, i.e., the street.
Directions for reaching the site:	8600 Block of Spruce Street at Leonidas Street with is adjacent to the Turbine No. 5.
Password:	upFsL4HqMw <a href="#">Click here</a> to <b>update</b> the incident.

## INCIDENT REPORT

Incident:214194

**Incident Description**

**Incident Type:** Complaint, Miscellaneous  
**Incident Date:** 05/17/2023 05:00:00  
**Parish:** Orleans  
**Municipality:** New Orleans  
**Location:** 8608 Spruce St. - New Orleans, LA

**Lat/Lon:** /  
**Basin/Segment:**  
**Substance(s):**  
**Media Impacted:** Soil/Air  
**Incident Desc:** Complaint SWBNO has been running on and off T5 since 4/3/23 and oil droplets continue to spray the homes, cars and property on Spruce Street residents. This is my 3rd incident report in the last 5 weeks. Von Magee currently assigned. LB

**Incident Status**

**Lead Investigator:** Von Magee  
**Incident Region:** Southeast  
**Incident Status:** Closed  
**Followup Status:** Closed  
**As Of:** 06/19/2023 14:18:55

**Incident Reporter 1**

**Received By:** Spo Contact  
**Received Date:** 05/19/2023 20:09:00  
**Dispatch Number(s):** OC5352  
**Reported By:** Ariane Livaudais  
**Phone:** 504-264-2750 (Home phone number)  
**Reporter Title:**  
**Organization:**  
**Address:** 8608 Spruce St.

**Municipality:** New Orleans  
**State:** LA  
**Zip Code:** 70118  
**Comments:**



## INCIDENT REPORT

Incident:214194

**Incident Source 1**

**Source Name:** Sewerage & Water Board of New Orleans -  
Carrollton Water Purification Plant  
**Address:** 8800 S Claiborne Ave

**Municipality:** New Orleans  
**State:** LA  
**Phone:** 5049423856(Work phone number)  
**Parish:**  
**AI #:** 5673

**Related Permits:**

**Comments:** Between 04/09/2023 through 05/19/2023, LDEQ received multiple complaints (T213615; T213760; T214194) regarding a release of oil from the Turbine 5 exhaust stack at the Sewerage and Water Board of New Orleans (SWBNO) Carrollton Water Purification Plant. According to the complaints, oil droplets are spraying from the exhaust stack and impacting adjacent homes, cars, and property along Spruce Street. Additionally, the SWBNO self-reported a release which occurred on 05/01/2023 at approximately 11:00:00. Among other information, this notification also indicates the possibility of remedial action achieved via wiping and/or washing of surfaces. This response included a review of the facility response to Compliance Order HE-C-22-00472 (EDMS Document ID# 13449186); observations of vehicles and residences along Spruce Street; an on-site discussion with Ms. Anita Williams; and email correspondences with facility personnel to request relevant records and information. Information and findings obtained were forwarded to LDEQ Enforcement Division on 05/02/2023 for further review and evaluation against the information and details discussed within, as well as response provided subsequently to issuance of, Compliance order HE-C-22-00472. Please refer to INS20230005 for additional details. On 06/28/2023, I contacted the complainant to inform of this path forward; I left a voice message requested a return call for further discussion. vam

## Von Magee

---

**From:** Dionne Magness  
**Sent:** Monday, May 22, 2023 11:42 AM  
**To:** Von Magee  
**Cc:** Holly Herrmann; Jeffrey Parham  
**Subject:** FW: SERO Complaint T 214194 Oil Orleans OC5352

Von, assigned to you.

---

**From:** SPOC <SinglePointof.Contact@LA.GOV>  
**Sent:** Monday, May 22, 2023 11:27 AM  
**To:** \_DEQ-SEROAdmin <\_DEQ-SEROAdmin@LA.GOV>  
**Cc:** SPOC <SinglePointof.Contact@LA.GOV>  
**Subject:** SERO Complaint T 214194 Oil Orleans OC5352

SERO Complaint T 214194 Oil Orleans OC5352

<http://advantagerm.swe.la.gov/Pages/Incidents/IncidentListPage.aspx?IncidentID=214194>

---

**From:** EML-SVC-DEQ-Intranet  
**Sent:** Friday, May 19, 2023 8:09 PM  
**To:** SPOC  
**Cc:** [arianelivaudais@gmail.com](mailto:arianelivaudais@gmail.com)  
**Subject:** Online Citizen Complaint: Confirmation: OC5352 - 5/19/2023 8:09:33 PM

<b>Caller Information</b>	
* First Name:	Ariane
* Last Name:	Livaudais
* Phone Number:	504-264-2750
Mailing Address:	8608 Spruce Street
City:	NEW ORLEANS
State:	Louisiana
Email:	<a href="mailto:arianelivaudais@gmail.com">arianelivaudais@gmail.com</a>
Zip:	70118
I request a follow-up on inspector findings:	Yes
<b>Site Information</b>	
Alleged Violator:	SWNBO Carrollton
* Physical Location/Address:	8608 Spruce Street
* City:	NEW ORLEANS
* State:	Louisiana
Zip:	70118
Date of Discharge:	05/17/2023
Noticed Time Began:	05:00:00
Noticed Time Ended:	08:00:00
* Parish of Occurrence:	Orleans Parish
Media Affected:	soil/air
If water, name the nearest water body:	



* Description of complaint:	SWBNO has been running on and off T5 since 4/3/23 and oil droplets continue to spray the homes, cars and property on Spruce Street residents. This is my 3rd incident report in the last 5 weeks. Von Magee currently assigned.
Directions for reaching the site:	Oil droplets evident on cars, homes and property along Spruce Street between Eagle and Leonidas.

AI No.: 5673

AI Name: Sewerage & Water Board of New Orleans – Carrollton Water Purification Plant

Alt. ID/Permit No.: LAD981511850

Date of Inspection: 04/12/2023; 04/24/2023

## **ATTACHMENT 2**

### **Field Interview Form (FIF)**







**LOUISIANA DEPARTMENT OF ENVIRONMENTAL QUALITY  
FIELD INTERVIEW FORM**

\* Revision, corrected date to 4/12/23 (vw)

AGENCY INTEREST#: 5673 INSPECTION DATE: 4/12/23 TIME OF ARRIVAL: 1330

ALTERNATE ID#: T213615 DEPARTURE DATE: 4/12/23 TIME OF DEPARTURE: 1400  
(ID Type/Number)

FACILITY NAME: Carrollton Water Plant PHONE #: (504) 628 7549

LOCATION: 8800 S. Claiborne  
New Orleans, LA 70118 PARISH: Orleans

RECEIVING STREAM (BASIN/SUBSEGMENT): \_\_\_\_\_

MAILING ADDRESS: Same as physical  
(Street/P.O. Box) (City) (State) (Zip)

FACILITY REPRESENTATIVE: Anita Williams TITLE: Env. Enforcement Tech.

FACILITY REPRESENTATIVE PHONE NUMBER: Same as above

NAME, TITLE, ADDRESS and TELEPHONE of RESPONSIBLE OFFICIAL (if different from above): \_\_\_\_\_

INSPECTION TYPE: Complaint PROGRAM INVOLVED: AIR  WASTE  WATER  OTHER: \_\_\_\_\_

INSPECTOR'S OBSERVATIONS: (e.g. AREAS AND EQUIPMENT INSPECTED, PROBLEMS, DEFICIENCIES, REMARKS, VERBAL COMMITMENTS FROM FACILITY REPRESENTATIVES)

- Ms. Williams stated the SWBNO is aware of an occurrence w/ turbine 5 & exhaust stack occurring but does not know specific details; directed me to Mr. Scott Finney for answers to specific questions;  
- Observed droplets/staining on some cars parked along Spruce Street.

**AREAS OF CONCERN:**

REGULATION	EXPLANATION	CORRECTED?
_____	_____	YES <input type="checkbox"/> NO <input type="checkbox"/>
_____	_____	YES <input type="checkbox"/> NO <input type="checkbox"/>

PHOTOS TAKEN: YES  NO  SAMPLES TAKEN: YES  NO  (Attach Chain-of-Custody)

RECEIVED BY SIGNATURE: Anita Williams

PRINT NAME: Anita Williams  
(NOTE: SIGNATURE DOES NOT INDICATE AGREEMENT WITH INSPECTOR'S NOTES)

INSPECTOR(S): Von A. Magee / V-M CROSS REFERENCE: \_\_\_\_\_

504-736-7731; Daniel Cristina ATTACHMENTS: \_\_\_\_\_

REVIEWER: [Signature]

**NOTE:** The information contained on this form reflects only the preliminary observations of the inspector(s). It should not be interpreted as a final determination by the Department of Environmental Quality or any of its officers or personnel as to any matter, including, but not limited to, a determination of compliance or lack thereof by the facility operator with any requirements of statutes regulations or permits. Each day of non-compliance constitutes a separate violation of the regulations and/or the Louisiana Environmental Quality Act.



AI No.: 5673

AI Name: Sewerage & Water Board of New Orleans – Carrollton Water Purification Plant

Alt. ID/Permit No.: LAD981511850

Date of Inspection: 04/12/2023; 04/24/2023

## **ATTACHMENT 3**

### **Photographs**



Facility Name: Spruce Street – near SWBNO Carrollton Water Plant AI: 5673  
City: New Orleans Parish: Orleans Photographer: Von A. Magee  
Date: 04/12/2023 Reason: Complaint Other ID #: T213615; T213760



Photo #: 1 of 5 Time: Approx. 1:21 PM  
Description: Representation photograph of vehicles parked along Spruce Street, near the Carrollton Water Plant facility. Observed droplet staining visually consistent with observation description and photographs collected on 03/04/2022.



Photo #: 2 of 5 Time: Approx. 1:22 PM  
Description: Representation photograph of vehicles parked along Spruce Street, near the Carrollton Water Plant facility. Observed droplet staining visually consistent with observation description and photographs collected on 03/04/2022.



Facility Name: Spruce Street – near SWBNO Carrollton Water Plant AI: 5673  
City: New Orleans Parish: Orleans Photographer: Von A. Magee  
Date: 04/12/2023 Reason: Complaint Other ID #: T213615; T213760



Photo #: 3 of 5 Time: Approx. 1:23 PM  
Description: Representation photograph of vehicles parked along Spruce Street, near the Carrollton Water Plant facility. Observed droplet staining visually consistent with observation description and photographs collected on 03/04/2022.



Photo #: 4 of 5 Time: Approx. 1:23 PM  
Description: Representation photograph of vehicles parked along Spruce Street, near the Carrollton Water Plant facility. Observed droplet staining visually consistent with observation description and photographs collected on 03/04/2022.



Facility Name: Spruce Street – near SWBNO Carrollton Water Plant AI: 5673  
City: New Orleans Parish: Orleans Photographer: Von A. Magee  
Date: 04/12/2023 Reason: Complaint Other ID #: T213615; T213760



Photo #: 5 of 5 Time: Approx. 1:24 PM  
Description: Representation photograph of vehicles parked along Spruce Street, near the Carrollton Water Plant facility. Observed droplet staining visually consistent with observation description and photographs collected on 03/04/2022.



Facility Name: 8608 Spruce St., near Carrollton Water Plant

AI: 5673

City: New Orleans

Parish: Orleans

Photographer: Von A. Magee

Other ID #: T213615; T213760

Date: 04/24/2023

Reason: Complaint



Photo #: 1 of 3 Time: Approx. 7:25 AM

Description: Complainant described and stated droplet staining present on hand railing is result of material emitted from Turbine 5 at the SWBNO Carrollton Water Treatment Plant. Please note, light rain was on-going at the time of collecting this photograph.



Photo #: 2 of 3 Time: Approx. 7:25 AM

Description: Complainant stated the more dull droplet staining on the bicycle seat cover is result of material emitted from Turbine 5 at the SWBNO Carrollton Water Treatment Facility. Please note, light rain was on-going at the time of collecting this photograph.



Facility Name: 8608 Spruce St., near Carrollton Water Plant

AI: 5673

City: New Orleans

Parish: Orleans

Photographer: Von A. Magee

Date: 04/24/2023 Reason: Complaint

Other ID #: T213615; T213760



Photo #: 3 of 3 Time: Approx. 7:26 AM

Description: Complainant stated the more dull droplet staining on this lawn furniture is result of material emitted from Turbine 5 at the SWBNO Carrollton Water Treatment Facility. Please note, light rain was on-going at the time of collecting this photograph.



Facility Name: Carrollton Water Treatment Plant  
City: New Orleans Parish: Orleans  
Date: 05/09/2023 Reason: Complaint/CEI

AI: 5673  
Photographer: Von A. Magee  
Other ID #: T213615; T213760;  
T213972




Photo #: 1 of 1 Time: Approx. 9:57 AM

Description: Observed staining/droplets on equipment and a building near the T5 turbine exhaust stack. This material is visually consistent with that observed on vehicles along Spruce St. and at the complainant's home. This observation is also visually consistent with on-site observations noted during the 03/04/2022 LDEQ site visit, Photograph 3.

AI No.: 5673

AI Name: Sewerage & Water Board of New Orleans – Carrollton Water Purification Plant

Alt. ID/Permit No.: LAD981511850

Date of Inspection: 04/12/2023; 04/24/2023

## **ATTACHMENT 4**

**03/04/2022 Inspection Report, INS20220003 (Relevant  
Pages)**





## Louisiana Department of Environmental Quality Southeast Regional Office

### Incident Report

Inspection Date: 3/04/2022 Incident No.: T-207469

AI No.: 5673 Alt. ID/Permit No: LAD9815-1850; INS20220003

Sewerage & Water Board of New Orleans – Carrollton Water Purification  
Company Name: Plant

Physical Location: 8800 S. Claiborne Ave.

New Orleans LA Parish: Orleans  
(City) (State)

Mailing Address: 8800 S. Claiborne Ave. New Orleans LA 70118  
(Address) (City) (State) (Zip)

Facility Representative/Title: Corwin Washington / Environmental Project Manager

Facility Representative Telephone No.: 504-930-7250

LDEQ Lead Inspector: Jodi Holewka

Other Inspectors: Tom Aepelbacher

Report By: Jodi Holewka 4/4/2022  
Jodi Holewka, Environmental Scientist (Date)

Reviewed By: Holly Herrmann 04/14/2022  
Holly Herrmann, Environmental Scientist Supervisor (Date)



AI No: 5673

AI Name: Sewerage & Water Board of New Orleans – Carrollton Water Purification Plant

Alt ID No: Incident #: T-207469

Date of Inspection: 3/04/2022

## **INTRODUCTION**

A partial compliance evaluation inspection was conducted in response to a citizen complaint (T-207469) alleging the violator, Sewerage & Water Board of New Orleans – Carrollton Water Purification Plant, is flinging a material that appears to be diesel from a turbine, which is damaging nearby properties. (See Attachment 2) The facility representatives were Corwin Washington (SWBNO Environmental Project Manager), Sam Lewis (SWBNO Turbine Operator), and Ms. Ann Wilson (SWBNO Chief of Environmental Affairs). The LDEQ representatives conducting the inspection were Thomas Aepelbacher (Environmental Scientist III, Southeast Regional Office), and Jodi Holeyka (Environmental Scientist III, Southeast Regional Office). A signed Field Interview Form (FIF) was left with the facility. (See Attachment 1)

## **FACILITY INFORMATION**

### General Information

The facility, the Main Water Treatment Plant (MWTP), also known as the Main Water Purification Plant (MWPP), is owned and operated by Sewerage and Water Board of New Orleans (SWBNO). The facility is located at 8800 S. Claiborne Avenue, New Orleans, Orleans Parish.

### Process Description

The facility is responsible for purifying the drinking water for the portion of New Orleans that lies on the East Bank of the Mississippi River and for providing 25 cycle electric power to the City's drainage pump stations.

The facility uses six steam boilers to drive the three steam turbines and generate electricity. This power drives some of the potable water inlet pumps and most of the drainage pumping stations for the City of New Orleans. Two or three boilers are normally in operation at one time. The MWTP also utilizes natural gas-fired turbines to provide backup power for major weather events such as heavy rainstorms and hurricanes. All the boilers and turbines use natural gas as their primary fuel source with fuel oil used as a backup fuel source if natural gas is curtailed or not available. Turbine #6 can run on diesel.

## **FACILITY HISTORY**

- The facility has had an EPA Hazardous Waste Generator number since 1986.
- On 3/06/2013, a citizen complaint was submitted to LDEQ (T-147162) for a diesel generator smoking and depositing soot all over cars, homes, and vegetable gardens. This incident was investigated by Surveillance Staff of the Southeast Regional Office. The review of this incident, and its associated report, revealed Turbine 5 was running due to repairs, and that the engine was stopped when the repairs were completed.

## **AREAS EVALUATED**

This inspection was in response to a citizen complaint (T-207469) alleging the violator, Sewerage & Water Board of New Orleans – Carrollton Water Purification Plant, is flinging a



AI No: 5673

AI Name: Sewerage & Water Board of New Orleans – Carrollton Water Purification Plant

Alt ID No: Incident #: T-207469

Date of Inspection: 3/04/2022

material that appears to be diesel from a turbine, which is damaging nearby properties. (See Attachment 2) A partial compliance evaluation inspection was conducted in order to determine the degree of compliance with applicable regulations. The investigation included a tour of the facility, a review of the facility's operations, associated recordkeeping requirements, and interviews with facility personnel.

#### Facility Tour

As part of the partial compliance evaluation, a facility tour was conducted in which the facility's turbines, facility grounds, and nearby residential neighborhood areas were inspected. Mr. Washington and Mr. Lewis were present during the facility tour. During the facility tour and interview with SWBNO personnel, it was noted that Turbine 6 (EQT 0020) is the only turbine on site that has the ability to run on diesel. It was not operational at the time of inspection, and according to Mr. Washington, the last time Turbine 6 operated was 2/28/2022.

Turbine 5 (EQT 0012) is natural gas operated and was operational at the time of the inspection. According to Mr. Lewis, it is not diesel that is being flung from Turbine 5, it is oil. Mr. Lewis stated, "Turbine 5 has an oil leak that is causing oil to be released from Turbine 5's stack (See Photo 1, Attachment 3) and it has been happening for weeks". At the time of inspection, we did not observe oil being actively released from Turbine 5. According to Mr. Lewis, SWBNO staff have been unsuccessful in their ongoing search for the source of the leak.

A clear, oily (when touched) material was observed splattered on concrete and metal surfaces on the facility's property near Turbine 5. (See Photos 2-3, Attachment 3) This clear, oily (when touched) material was also observed splattered on off-site surfaces including roads, and individually owned vehicles parked on Spruce St. between Eagle St. and Leonidas St. (See Photos 4-13, Attachment 3). Due to the nature of the material, even though it was observed to have leaked on items in the area, including the ground, it was unable to be observed and was not visible when photographed on the soil. **The owner/operator failed to clean up and/or properly manage released used oil, in violation of LAC 33:V.4013.E.3. Specifically, the facility failed to clean up used oil (MOBIL DTE 732) that, according to Mr. Lewis, had been releasing for weeks due to a leak from Turbine 5. The affected area where used oil was spilled and/or released from the faulty equipment included facility grounds, and a residential neighborhood on Spruce Street between Eagle Street and Leonidas Street. The affected surrounding properties include, but are not limited to roadways, vehicles, lawns, and residential homes. According to an email from Ms. Wilson on 4/01/2022, Turbine 5 will continue to be operated as needed.**

#### Records Review

Prior to the completion of the inspection, a list of records was requested for review, and to be provided at a later date. Records requested included: Turbine run time hours, Turbine maintenance records, and additional information pertaining to the oil leak including repair time. The Field Interview Form left with Mr. Corwin on 3/04/2022, documented Turbine 6 has an oil leak, this was an error on the Inspector's behalf. Turbine 6 does not have an oil leak; Turbine 5 does.



AI No: 5673

AI Name: Sewerage & Water Board of New Orleans – Carrollton Water Purification Plant

Alt ID No: Incident #: T-207469

Date of Inspection: 3/04/2022

On 3/08/2022, I emailed Ms. Ann Wilson, SWBNO Chief of Environmental Affairs, informing her of the citizen complaint, and our inspection observations and findings. A formal action plan for the cleanup of the released used oil was requested to be provided by the close of business on 3/18/2022. (See Attachment 4)

On 3/17/2022, I contacted Mr. Washington and requested a copy of the Safety Data Sheet (SDS) for the oil used in Turbine 5. On 3/22/2022, Mr. Washington provided an SDS for MOBIL DTE 732 via email. (See Attachment 5)

On 3/18/2022, Ms. Wilson provided a response and action plan via email. (See Attachment 4). Ms. Wilson's response states, "In an effort to comply with the Department's request to submit a formal action plan for remediation, SWBNO contacted its emergency response & remediation vendor, OMI Environmental Solutions to evaluate the impact of remnants of the oily residual. Specifically, the vendor stated that the standard method of cleanup using industrial soaps and chemicals would not be effective. The cleanup procedure would be ineffective because the oily residual was dried into the concrete and metal. The remnants are tantamount to stains, similar to an automobile leaking oil, it adhered to the concrete and will fade over time. Furthermore, it was stated by OMI that the industrial soaps and chemicals if applied to the automobiles that were impacted by the oily residual would strip the coating and paint off the automobiles causing significant damage to private property."

"SWBNO's Department of Risk Management deployed investigators to speak with the residents impacted and it was stated by the residents that the oily residual observed on their automobiles washes off when the automobiles are washed and detailed. In addition, two (2) claims have already been submitted to SWBNO. SWBNO's Management intends to schedule a meeting to discuss the incident with the impacted residents in the near future."

"The Department requested the following items related to Turbine 5: run-time hours, maintenance records, safety data sheet for the oil product utilized that was emitted via the stack and the anticipated repair completion date. At this time, SWBNO is working on gathering that information and will provide the information available in a separate notification letter on or before March 31, 2022. Any information not available by this date, will be noted in the response."

On 3/25/2022, I emailed Ms. Wilson informing her that LDEQ has reviewed SWBNO's response and action plan and deemed it inefficient, and requested additional information. (See Attachment

4) The information requested included:

1. An evaluation of the amount of used oil released.
2. Was a Reportable Quantity exceeded?
3. A delineation of the area affected.
4. A determination of the area requiring remediation.
5. A Root Cause Analysis.
6. Has the equipment been fixed? Is it still being used (if not fixed)?
7. SWBNO plans for preventing this issue in the future. Based on an EDMS records review this appears to be a reoccurring issue.



AI No: 5673

AI Name: Sewerage & Water Board of New Orleans – Carrollton Water Purification Plant

Alt ID No: Incident #: T-207469

Date of Inspection: 3/04/2022

8. Having residents contact SWBNO to file a claim, is not an acceptable response or avenue for remediation.

On 4/01/2022, Ms. Wilson emailed a response to the 3/25/2022 request. According to the response, Turbine 5 will continue to be operated as needed. No activities have been taken to clean the released oil; as Ms. Wilson's response claims there is no substance or area requiring remediation.

As of 4/04/2022, the facility has not provided Turbine 5 runtime hours or maintenance records that were requested during the 3/04/2022 site visit to determine when the release began.

#### **COMPLIANCE ASSISTANCE**

Not provided to this facility.

#### **SUMMARY OF OBSERVATIONS**

##### **Violations**

- **The owner/operator failed to clean up and/or properly manage released used oil, in violation of LAC 33:V.4013.E.3. Specifically, the facility failed to clean up used oil (MOBIL DTE 732) that, according to Mr. Lewis, had been releasing for weeks due to a leak from Turbine 5. The affected area where used oil was spilled and/or released from the faulty equipment included facility grounds, and a residential neighborhood on Spruce Street between Eagle Street and Leonidas Street. The affected surrounding properties include, but are not limited to roadways, vehicles, lawns, and residential homes. According to an email from Ms. Wilson on 4/01/2022, Turbine 5 will continue to be operated as needed.**

A Notice of Deficiency will be issued.

AI No: 5673

AI Name: Sewerage & Water Board of New Orleans – Carrollton Water Purification Plant

Alt ID No: Incident #: T-207469

Date of Inspection: 3/04/2022

## **LIST OF ATTACHMENTS**

- |                     |   |
|---------------------|---|
| <b>ATTACHMENT 1</b> | <b>Field Interview Form</b>             |
| <b>ATTACHMENT 2</b> | <b>Incident T-207469</b>                |
| <b>ATTACHMENT 3</b> | <b>Photographs</b>                      |
| <b>ATTACHMENT 4</b> | <b>Action Plan/Email Correspondence</b> |
| <b>ATTACHMENT 5</b> | <b>Safety Data Sheet</b>                |



AI No: 5673

AI Name: Sewerage & Water Board of New Orleans – Carrollton Water Purification Plant

Alt ID No: Incident #: T-207469

Date of Inspection: 3/04/2022

## **ATTACHMENT 1**

### **Field Interview Form (2 Pages)**

**LOUISIANA DEPARTMENT OF ENVIRONMENTAL QUALITY  
FIELD INTERVIEW FORM**

AGENCY INTEREST#: 5673 INSPECTION DATE: 3/04/2011 TIME OF ARRIVAL: 10:00am  
 ALTERNATE ID#: T-207469 DEPARTURE DATE: 3/04/2011 TIME OF DEPARTURE: 11:15am  
(ID Type/Number)

FACILITY NAME: SubNO-Carrallton Water Plant PHONE #: 50418650550  
 LOCATION: 8800 S Chibrocot Ave. New Orleans, LA 70118  
 PARISH: Orleans

RECEIVING STREAM (BASIN/SUBSEGMENT): \_\_\_\_\_  
 MAILING ADDRESS: 8800 S Chibrocot Ave. New Orleans LA 70118  
(Street/P.O. Box) (City) (State) (Zip)

FACILITY REPRESENTATIVE: Corwin L Washington TITLE: Environmental P.m.  
 FACILITY REPRESENTATIVE PHONE NUMBER: 504 930 7050  
 NAME, TITLE, ADDRESS and TELEPHONE OF RESPONSIBLE OFFICIAL (if different from above): \_\_\_\_\_

INSPECTION TYPE: PCE Incident PROGRAM INVOLVED: AIR  WASTE  WATER  OTHER: \_\_\_\_\_

INSPECTOR'S OBSERVATIONS: (e.g. AREAS AND EQUIPMENT INSPECTED, PROBLEMS, DEFICIENCIES, REMARKS, VERBAL COMMITMENTS FROM FACILITY REPRESENTATIVES)

Site visit in response to citizen complaint (T-207469) regarding turbines malfunctioning and "flying" diesel in nearby neighborhood. Facility tour & walk around nearby properties conducted. Turbine # 6 is Diesel operated, currently not operating. last date of operation for T#6 was 2/20/2011. Turbine #5 is Natural gas operated & currently in operation. According to Sam Lewis, Turbine Operator, T#6 has an oil leak in the unit that is causing small amounts of oil to be released via the stack. Slime/splatter of an oily substance was observed on the facility ground, nearby vehicles parked along Spruce St. between Eagle St.

**AREAS OF CONCERN:**

REGULATION	EXPLANATION	CORRECTED?
_____	_____	YES <input type="checkbox"/> NO <input type="checkbox"/>
_____	_____	YES <input type="checkbox"/> NO <input type="checkbox"/>

PHOTOS TAKEN: YES  NO  SAMPLES TAKEN: YES  NO  (Attach Chain-of-Custody)

RECEIVED BY SIGNATURE: Corwin L Washington

PRINT NAME: Corwin L Washington  
(NOTE: SIGNATURE DOES NOT INDICATE AGREEMENT WITH INSPECTOR'S NOTES)

INSPECTOR(S): Jodi Hester, John Alford CROSS REFERENCE: \_\_\_\_\_

REVIEWER: Tom Appelbacher, Holly Hermann ATTACHMENTS: \_\_\_\_\_

NOTE: The information contained on this form reflects only the preliminary observations of the inspector(s). It should not be interpreted as a final determination by the Department of Environmental Quality or any of its officers or personnel as to any matter, including, but not limited to, a determination of compliance or lack thereof by the facility operator with any requirements of statutes regulations or permits. Each day of non-compliance constitutes a separate violation of the regulations and/or the Louisiana Environmental Quality Act.



LOUISIANA DEPARTMENT OF ENVIRONMENTAL QUALITY  
INSPECTOR OBSERVATIONS (cont'd)

AGENCY INTEREST#: 5673 ALTERNATE ID#: T-207469 INSPECTION DATE: 3/04/2002

FACILITY NAME: St. 2800 - Carrollton

INSPECTOR OBSERVATIONS CONT'D:

and Leonidas St., on the ground (street) on Spruce St.

Run time hours, maintenance records, and additional information  
pertaining to the leak including repair time was requested.

JA  
3/4/2002

INITIALS OF RECEIPT DLW

AI No: 5673

AI Name: Sewerage & Water Board of New Orleans – Carrollton Water Purification Plant

Alt ID No: Incident #: T-207469

Date of Inspection: 3/04/2022

## **ATTACHMENT 2**

**Incident T-207469  
(4 Pages)**



## INCIDENT REPORT

Incident:207469

**Incident Description**

**Incident Type:** Complaint, Facility Air Release  
**Incident Date:** 03/03/2022 08:48:00  
**Parish:** Orleans  
**Municipality:** New Orleans  
**Location:** 8800 S Claiborne - New Orleans, LA

**Lat/Lon:** /


**Basin/Segment:**

**Substance(s):**

**Media Impacted:** Soil/Air

**Incident Desc:** Complaint One of the turbines at the facility has been malfunctioning. The facility has been operating a lot louder than normal and the turbine is flinging material, that seems to be diesel, all over the surrounding neighborhood. This material is damaging property and making it unsafe to sit outside. The sewage and water board said that the issue could not be addressed until 2023 at the earliest. LB

**Incident Status**

**Lead Investigator:** Jodi Holewka   
**Incident Region:** Southeast  
**Incident Status:** Closed  
**Followup Status:** Closed  
**As Of:** 03/29/2022 14:44:51

**Incident Reporter 1**

**Received By:** Louis Berner  
**Received Date:** 03/03/2022 08:48:00  
**Dispatch Number(s):** 241464, C5020  
**Reported By:** Ariane Livaudais  
**Phone:** 985-807-3566 (Home phone number)

**Reporter Title:**

**Organization:**

**Address:**

**Municipality:**

**State:** LA

**Zip Code:**

**Comments:**

## INCIDENT REPORT

Incident:207469

**Incident Source 1**

**Source Name:** Sewerage & Water Board of New Orleans -  
Carrollton Water Purification Plant  
**Address:** 8800 S Claiborne Ave

**Municipality:** New Orleans  
**State:** LA  
**Phone:** 5049423856(Work phone number)  
**Parish:**  
**AI #:** 5673

**Related Permits:**

**Comments:** An inspection was conducted on 3/04/2022 in response to a citizen complaint (T-207469) alleging the violator, Sewerage & Water Board of New Orleans – Carrollton Water Purification Plant, is flinging a material that appears to be diesel from a turbine, which is damaging nearby properties.

As part of the inspection, a facility tour was conducted in which the facility's turbines, facility grounds, and nearby residential neighborhood areas were inspected. Turbine 5 is natural gas operated and was operational at the time of the inspection. According to Mr. Lewis, it is not diesel that is being flung from Turbine 5, it is oil. Mr. Lewis stated, "Turbine 5 has an oil leak that is causing oil to be released from Turbine 5's stack and it has been happening for weeks". At the time of inspection, we did not observe oil being actively released from Turbine 5.

A clear, oily (when touched) material was observed splattered on concrete and metal surfaces on the facility's property near Turbine 5. This clear, oily (when touched) material was also observed splattered on off-site surfaces including roads, and individually owned vehicles parked on Spruce St. between Eagle St. and Leonidas St. Due to the nature of the material, even though it was observed to have leaked on items in the area, including the ground, it was unable to be observed and was not visible when photographed on the soil.



## INCIDENT REPORT

Incident:207469

**Incident Source 2**

**Source Name:** Sewerage & Water Board of New Orleans -  
Carrollton Water Purification Plant  
**Address:** 8800 S Claiborne Ave

**Municipality:** New Orleans  
**State:** LA  
**Phone:** 5049423856(Work phone number)  
**Parish:**  
**AI #:** 5673

**Related Permits:**

**Comments:** Summary  
The owner/operator failed to clean up and/or properly manage released used oil, in violation of LAC 33:V.4013.E.3. Specifically, the facility failed to clean up used oil (MOBI - DTE 732) that, according to Mr. Lewis, had been releasing for weeks due to a leak from Turbine 5. The affected area where used oil was spilled and/or released from the faulty equipment included facility grounds, and a residential neighborhood on Spruce Street between Eagle Street and Leonidas Street. The affected surrounding properties include, but are not limited to roadways, vehicles, lawns, and residential homes. According to an email from Ms. Wilson on 4/01/2022, Turbine 5 will continue to be operated as needed.

The complainant was contacted.

The violation found during this inspection will be forwarded for further review in a separate report (INS20220003) and this incident will be closed. JKH

**Jodi Holewka**

**Subject:** SERO Complaint T 207469 Diesel Orleans C5020

SERO Complaint T 207469 Diesel Orleans C5020

**Sent:** Thursday, March 3, 2022 9:35 AM

**Subject:** Intranet Citizen Complaint: Confirmation: C5020 - 3/3/2022 9:35:07 AM

<b>Internal Receiver Information</b>	
* Date and Time Received:	03/03/22 08:48:00
* Received By (DEQ staff):	Louis Berner
Email (Email must be provided to receive confirmation email):	
Anonymous Complaint:	No
<b>Caller Information</b>	
* First Name:	Ariane
* Last Name:	Livaudais
* Phone Number:	985-807-3566
Mailing Address:	
City:	
State:	
Email:	
Zip:	
I request a follow-up on inspector findings:	Yes
<b>Site Information</b>	
Alleged Violator:	NO Sewer and Water Board
* Physical Location/Address:	8800 S Claiborne
* City:	New Orleans
* State:	Louisiana
Zip:	
Date of Discharge:	
Noticed Time Began:	
Noticed Time Ended:	
* Parish of Occurrence:	Orleans Parish
Media Affected:	air
If water, name the nearest water body:	
Description of complaint:	One of the turbines at the facility has been malfunctioning. The facility has been operating a lot louder than normal and the turbine is flinging material, that seems to be diesel, all over the surrounding neighborhood. This material is damaging property and making it unsafe to sit outside. The sewage and water board said that the issue could not be addressed until 2023 at the earliest.
Directions for reaching the site:	

3/05/2022 11:14am voicemail left  
3/3/2022 8:22am voicemail left



AI No: 5673

AI Name: Sewerage & Water Board of New Orleans – Carrollton Water Purification Plant

Alt ID No: Incident #: T-207469

Date of Inspection: 3/04/2022

## **ATTACHMENT 3**

**Photographs  
(7 Pages)**

**ATTACHMENT**

Facility Name: Sewerage & Water Board of New Orleans – Carrollton AI: 5673  
Water Purification Plant

City: New Orleans Parish: Orleans Photographer: Jc Ji Holeyka  
Date: 3/04/2022 Reason: Incident Other ID #: T-207469




Photo #: 1 of 13 Time: 10:14AM  
Description: Turbine 5 stack, and residential homes on Spruce St. in the distance.



**ATTACHMENT**

Facility Name: Sewerage & Water Board of New Orleans – Carrollton AI: 5673  
Water Purification Plant

City: New Orleans Parish: Orleans Photographer: Jodi Holewka  
Date: 3/04/2022 Reason: Incident Other ID # T-207469




Photo #: 2 of 13 Time: 10:09AM  
Description: Clear, oily (when touched) material observed splattered on concrete and metal surfaces on the facility's property near Turbine 5. Photo is facing down.




Photo #: 3 of 13 Time: 10:12AM  
Description: Clear, oily (when touched) material observed splattered on concrete and metal surfaces on the facility's property near Turbine 5.



**ATTACHMENT**

Facility Name: Sewerage & Water Board of New Orleans – Carrollton AI: 5673  
Water Purification Plant

City: New Orleans Parish: Orleans Photographer: Jodi Holeyka

Date: 3/04/2022 Reason: Incident Other ID #: T-207469




Photo #: 4 of 13 Time: 10:25AM  
Description: Clear, oily (when touched) material observed splattered on individually owned vehicles parked on Spruce St. between Eagle St. and Leonidas St.




Photo #: 5 of 13 Time: 10:25AM  
Description: Clear, oily (when touched) material observed splattered on individually owned vehicles parked on Spruce St. between Eagle St. and Leonidas St.



**ATTACHMENT**

Facility Name: Sewerage & Water Board of New Orleans – Carrollton AI: 5673  
Water Purification Plant

City: New Orleans Parish: Orleans Photographer: Jodi Holewka  
Date: 3/04/2022 Reason: Incident Other ID #: T-207469




Photo #: 5 of 13 Time: 10:25AM  
Description: Clear, oily (when touched) material observed splattered on individually owned vehicles parked on Spruce St. between Eagle St. and Leonidas St.




Photo #: 7 of 13 Time: 10:26AM  
Description: Clear, oily (when touched) material observed splattered on individually owned vehicles parked on Spruce St. between Eagle St. and Leonidas St.

**ATTACHMENT**

Facility Name: Sewerage & Water Board of New Orleans – Carrollton AI: 5673  
Water Purification Plant

City: New Orleans Parish: Orleans Photographer: Jodi Holeyka  
Date: 3/04/2022 Reason: Incident Other ID #: T-207469




Photo #: 8 of 13 Time: 10:27AM  
Description: Clear, oily (when touched) material observed splattered on individually owned vehicles parked on Spruce St. between Eagle St. and Leonidas St. View of Turbine 5 stack in the background.




Photo #: 5 of 13 Time: 10:27AM  
Description: Clear, oily (when touched) material observed splattered on individually owned vehicles parked on Spruce St. between Eagle St. and Leonidas St.



**ATTACHMENT**

Facility Name: Sewerage & Water Board of New Orleans – Carrollton AI: 5673  
Water Purification Plant

City: New Orleans Parish: Orleans Photographer: Jodi Holewka  
Date: 3/04/2022 Reason: Incident Other ID #: T-207469




Photo #: 0 of 13 Time: 10:27AM  
Description: Clear, oily (when touched) material observed splattered on individually owned vehicles parked on Spruce St. between Eagle St. and Leonidas St.




Photo #: 11 of 13 Time: 10:28AM  
Description: Clear, oily (when touched) material observed splattered on individually owned vehicles parked on Spruce St. between Eagle St. and Leonidas St. View of Turbine 5 stack in the background.



**ATTACHMENT**

Facility Name: Sewerage & Water Board of New Orleans – Carrollton AI: 5673  
Water Purification Plant

City: New Orleans Parish: Orleans Photographer: Jodi Holewka  
Date: 3/04/2022 Reason: Incident Other ID #: T-207469




Photo #: 12 of 13 Time: 10:29AM

Description: Clear, oily material observed splattered on Spruce St. between Eagle St. and Leonidas St.



Photo #: 13 of 13 Time: 10:29AM

Description: Clear, oily material observed splattered on Spruce St. between Eagle St. and Leonidas St.



AI No: 5673

AI Name: Sewerage & Water Board of New Orleans – Carrollton Water Purification Plant

Alt ID No: Incident #: T-207469

Date of Inspection: 3/04/2022

## **ATTACHMENT 4**

**Action Plan/Email Correspondence  
(7 Pages)**

**Jodi Holewka**

---

**From:** WILSON, Ann <awilson2@swbno.org>  
**Sent:** Friday, April 1, 2022 6:34 PM  
**To:** Jodi Holewka; WASHINGTON, Corwin  
**Cc:** Holly Herrmann; Daniel Cristina  
**Subject:** RE: Action Plan Required!  
**Attachments:** Document\_LDEQ\_RFI\_04012022.pdf

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

**EXTERNAL EMAIL:** Please do not click on links or attachments unless you know the content is safe.

See attached.

**From:** Jodi Holewka <Jodi.Holewka@LA.GOV>  
**Sent:** Friday, March 25, 2022 9:13 AM  
**To:** WILSON, Ann <awilson2@swbno.org>; WASHINGTON, Corwin <cwashington3@swbno.org>  
**Cc:** Holly Herrmann <Holly.Herrmann@LA.GOV>; Daniel Cristina <Daniel.Cristina@la.gov>  
**Subject:** RE: Action Plan Required!  
**Importance:** High

=====  
===== EXTERNAL EMAIL | USE CARE WITH LINKS AND ATTACHMENTS =====  
=====

Ms. Wilson,

The response from Sewerage & Water Board of New Orleans (SWBNO) has been reviewed and deemed inefficient.

The plan requires additional information including, but not limited to:

1. An evaluation of the amount of used oil released.
2. Was a Reportable Quantity exceeded?
3. A delineation of the area affected.
4. A determination of the area requiring remediation.
5. A Root Cause Analysis.
6. Has the equipment been fixed? Is it still being used (if not fixed)?
7. SWBNO plans for preventing this issue in the future. Based on an EDMS records review this appears to be a reoccurring issue.
8. Having residents contact SWBNO to file a claim, is not an acceptable response or avenue for remediation.

Thank you,

*Jodi Holewka*

Louisiana Department of Environmental Quality  
Surveillance Division  
Environmental Scientist III  
Office: (504) 736-7748



Fax: (504) 736-7702

**From:** WILSON, Ann <[awilson2@swbno.org](mailto:awilson2@swbno.org)>  
**Sent:** Friday, March 18, 2022 3:45 PM  
**To:** Jodi Holeyka <[Jodi.Holeyka@LA.GOV](mailto:Jodi.Holeyka@LA.GOV)>; WASHINGTON, Corwin <[cwashington3@swbno.org](mailto:cwashington3@swbno.org)>  
**Cc:** Holly Herrmann <[Holly.Herrmann@LA.GOV](mailto:Holly.Herrmann@LA.GOV)>  
**Subject:** RE: Action Plan Required!

**EXTERNAL EMAIL: Please do not click on links or attachments unless you know the content is safe.**

Jodi, attached is the Board's response for formal action plan for the cleanup of used oil.



**Ann Wilson, Chief Environmental Affairs**  
**SEWERAGE & WATER BOARD of NEW ORLEANS**  
**CELL (504)252-8707**  
2900 Peoples Avenue, Room 215, New Orleans, LA 70122  
8800 S. Claiborne Avenue, Room 207, New Orleans, LA 70118  
[awilson2@swbno.org](mailto:awilson2@swbno.org)

**From:** Jodi Holeyka <[Jodi.Holeyka@LA.GOV](mailto:Jodi.Holeyka@LA.GOV)>  
**Sent:** Tuesday, March 8, 2022 10:37 AM  
**To:** WILSON, Ann <[awilson2@swbno.org](mailto:awilson2@swbno.org)>; WASHINGTON, Corwin <[cwashington3@swbno.org](mailto:cwashington3@swbno.org)>  
**Cc:** Holly Herrmann <[Holly.Herrmann@LA.GOV](mailto:Holly.Herrmann@LA.GOV)>  
**Subject:** Action Plan Required!  
**Importance:** High

=====  
===== EXTERNAL EMAIL | USE CARE WITH LINKS AND ATTACHMENTS =====  
=====

Ms. Wilson,

Attached is a Field Interview Form (FIF) for a inspection/investigation conducted at SWBNO – Carrollton Water Purification Plant located at 8800 S. Claiborne Ave. New Orleans, LA on 3/04/2022 in response to citizen complaint #T-207469.

My investigation revealed that Turbine#5 has an oil leak that is causing oil to be released through the stack. Oil was observed on the facility ground, on Spruce St., and on numerous vehicles parked along Spruce St.

A formal action plan is being requested for the cleanup of the used oil released. Please provide this plan by the close of business on 3/18/2022.

Thank you,

*Jodi Holeyka*

Louisiana Department of Environmental Quality  
Surveillance Division

Environmental Scientist III

Office: (504) 736-7748

Fax: (504) 736-7702





# The Sewerage & Water Board OF NEW ORLEANS

625 ST. JOSEPH STREET  
NEW ORLEANS, LA 70165  
504.529.2837 OR 52.WATER  
[www.swbno.org](http://www.swbno.org)

April 1, 2022

Louisiana Department of Environmental Quality  
c/o Jodi Holewka, Environmental Scientist III  
Surveillance Division  
South East Regional Office  
201 Evans Road, Suite 420  
Elmwood, LA 70123

**RE: CARROLLTON WATER PURIFICATION PLANT  
INCIDENT TRACKING NO. T-207469  
AGENCY INTEREST: 5673**

Ms. Holewka,

On March 4, 2022, the Louisiana Department of Environmental Quality (the Department) conducted an investigation of the **SEWERAGE & WATER BOARD OF NEW ORLEANS (SWBNO) Carrollton Water Purification Plant** located at 8800 S. Claiborne Avenue in New Orleans, Orleans Parish, Louisiana (the Site), in response to a citizen's complaint of oily fluids discharging offsite from turbine operation. Specifically, the investigation revealed remnants of stains observed on street top, catch basin covers and on adjacent residents' property located on Spruce Street. Although, Turbine 5 was operating at the time of the investigation, there was no indication that oily fluids were being emitted and/or discharged to the environment.

On March 18, 2022, SWBNO submitted a response letter to the Department via email detailing the inability to remediate per recommendation of SWBNO's contracted vendor for Emergency Response and Remediation Services, OMI Environmental Solutions, along with SWBNO accepting claims regarding any potential damages to private property per impacted residents. On March 22, 2022, the Department received the Safety Data Sheet for the Turbine Oil, Mobile DTE 732, as requested. On March 25, 2022, the Department requested additional information.

SWBNO has started the process of conducting an internal investigation into the cause of any potential discharge of oily fluids and has sought additional technical assistance in determining a root cause analysis. General Electric is scheduled to perform a full diagnostic evaluation of Turbine No. 5 within the next 60 to 90 days. SWBNO will continue to utilize Turbine No.5 and Turbine No. 6 based upon the operational requirements of this agency. In addition, SWBNO cannot definitively confirm that turbine oil, specifically Mobile DTE 732 was released to the environment. The substance may not be any of the pollutants listed in the reportable quantity list provided in LAC 33: 1.3931.B. Due to the infrequency of the turbine operation, the oil usage has not increased to reach the reportable quantity; regardless if any purported discharge was continuous, intermittent, or as a one-time mass discharge within any continuous 24-hour period.

Per the received claims, SWBNO has identified the potential impacted area as approximately less than or equal to one (1) acre. As stated in the previous response to the Department, there is no substance and or area requiring remediation; the surrounding vegetation reveals no negative signs of impact. Neither the Department, nor SWBNO could determine or confirm if the staining observed on the street top and catch basin covers located on Spruce Street is related to this incident during the investigation on March 3, 2022. Droplets were observed on residents' personal vehicles; however, no samples were taken or requested at the time of the investigation.

If you should have any further questions and/or concerns, please feel free to contact Corwin L. Washington at (504) 418-0927 or via email at [cwashington3@swbno.org](mailto:cwashington3@swbno.org).

Sincerely,



Ann Wilson, Chief  
Environmental Affairs Department  
Sewerage and Water Board of New Orleans

AW/CLW





# **The Sewerage & Water Board**

## **OF NEW ORLEANS**

625 ST. JOSEPH STREET  
NEW ORLEANS, LA 70165  
504.529.2837 OR 52.WATER

[www.swbno.org](http://www.swbno.org)

March 18, 2022

Louisiana Department of Environmental Quality  
c/o Jodi Holewka, Environmental Scientist III  
Surveillance Division  
South East Regional Office  
201 Evans Road, Suite 420  
Elmwood, LA 70123

**RE: CARROLLTON WATER PURIFICATION PLANT**  
**INCIDENT TRACKING NO. T-207469**  
**AGENCY INTEREST: 5673**

Ms. Holewka,

On March 4, 2021, the Louisiana Department of Environmental Quality (Department) conducted an investigation of the **SEWERAGE & WATER BOARD OF NEW ORLEANS (SWBNO)** Carrollton Water Purification Plant located at 8800 S. Claiborne Avenue in New Orleans, Orleans Parish, Louisiana (the Site), in response to a citizen's complaint of oily fluids discharging offsite from turbine operation. Specifically, the investigation revealed remnants of oily residual observed on street top, catch basin covers and on adjacent residents' property located on Spruce Street and the Site adjacent to Turbine 5. Turbine 5 was operating at the time of the investigation and there was no indication that oily fluids were being discharged via the stack.

In an effort to comply with the Department's request to submit a formal action plan for remediation, SWBNO contacted its emergency response & remediation vendor, OMI Environmental Solutions to evaluate the impact of remnants of the oily residual. Specifically, the vendor stated that the standard method of cleanup using industrial soaps and chemicals would not be effective. The cleanup procedure would be ineffective because the oily residual was dried into the concrete and metal. The remnants are tantamount to stains, similar to an automobile leaking oil, it adhered to the concrete and will fade over time. Furthermore, it was stated by OMI that the industrial soaps and chemicals if applied to the automobiles that were impacted by the oily residual would strip the coating and paint off the automobiles causing significant damage to private property.

SWBNO's Department of Risk Management deployed investigators to speak with the residents impacted and it was stated by the residents that the oily residual observed on their automobiles

washes off when the automobiles are washed and detailed. In addition, two (2) claims have already been submitted to SWBNO. SWBNO's Management intends to schedule a meeting to discuss the incident with the impacted residents in the near future.

The Department requested the following items related to Turbine 5: run-time hours, maintenance records, safety data a sheet for the oil product utilized that was emitted via the stack and the anticipated repair completion date. At this time, SWBNO is working on gathering that information and will provide the information available in a separate notification letter on or before March 31, 2022. Any information not available by this date, will be noted in the response.

If you should have any further questions and/or concerns, please feel free to contact Corwin L Washington at (504) 418-0927 or via email at [cwashington3@swbno.org](mailto:cwashington3@swbno.org).

Sincerely,

**Ann Wilson**

Digitally signed by Ann Wilson  
DN: cn=Ann Wilson, o, ou,  
email=awilson2@swbno.org, c=US  
Date: 2022.03.18 15:41:10 -05'00'

Ann Wilson, Chief  
Environmental Affairs Department  
Sewerage and Water Board of New Orleans

AW/CLW



AI No.: 5673

AI Name: Sewerage & Water Board of New Orleans – Carrollton Water Purification Plant

Alt. ID/Permit No.: LAD981511850

Date of Inspection: 04/12/2023; 04/24/2023

## **ATTACHMENT 5**

### **Email Correspondences (Provided Information/Records)**

## Von Magee

---

**From:** FINNEY, Scott <sfinney@swbno.org>  
**Sent:** Wednesday, April 26, 2023 3:33 PM  
**To:** Von Magee  
**Cc:** WILSON, Ann; SPOONER, Ron; TYMRAK, Kaitlin; MANCUSO, Eric; DE JEAN, Shawn; WILLIAMS, Anita  
**Subject:** RE: Questions Regarding LDEQ Complaint T213615 e-mail 2  
**Attachments:** 1-4-2023 to 4-5-2023.pdf; 4-5-2023 to 4-16-2023.pdf; 4-17-2023 to 4-24-2023.pdf

**EXTERNAL EMAIL:** Please do not click on links or attachments unless you know the content is safe.

Von,  
This the remainder of the logs.  
Thanks  
Scott

Scott S. Finney, CIT, REM  
Senior MS4 Stormwater Manager, SUSM  
Sewerage & Water Board of New Orleans  
Environmental Affairs Department  
Room 207  
8800 South Claiborne Ave,  
New Orleans, LA 70118  
(504) 865-0662 office  
(504) 628-7549 Cell  
Email: [sfinney@swbno.org](mailto:sfinney@swbno.org)

---

**From:** FINNEY, Scott  
**Sent:** Wednesday, April 26, 2023 3:27 PM  
**To:** 'Von Magee' <Von.Magee@LA.GOV>  
**Cc:** WILSON, Ann <awilson2@swbno.org>; SPOONER, Ron <rspooneer@swbno.org>; TYMRAK, Kaitlin <ktymrak@swbno.org>; MANCUSO, Eric <EMANCUSO@swbno.org>; DE JEAN, Shawn <SDEJEAN@swbno.org>; WILLIAMS, Anita <awilliams2@swbno.org>  
**Subject:** RE: Questions Regarding LDEQ Complaint T213615 e-mail 2

Von,  
We have gather the information you requested: See attached documents.  
Listed below in **Red** are your questions, and in **Blue** are the responses from SWBNO.  
The log information is over 30 Meg and your system would not receive it. I will place the data in two (2) e-mails.  
All responses were supplied by the General Superintendents office.  
Thanks  
Scott

**A few follow-up questions to your initial inquiry responses:**

**Regarding item #1.a:**

- **If you're proceeding as described, how is the SWBNO going to conduct remedial actions of the released material?**



We have provided car covers to local residents to use at their convenience.

- **Has the SWBNO made any definitive determinations as to an exact source since the time of your last email correspondence?**

As noted below, we are continuing to move forward with establishing a contract with GE to perform an engineering analysis and design and supply a knock-down tank for their vapor extractor, which will hopefully mitigate the issue.

**Regarding item #2:**

- **Please provide the current SDS for the Mobil DTE 732 turbine oil**  
Attached.

**Regarding items 1.b and 3:**

- **Is Turbine 5 still in operation as of this email's date?**  
Yes.
- **Is there an expected return-to-service date for Turbine 4 at this point-in time?**  
Contractors are still inspecting the turbine components and developing a plan for repair. At this point we anticipate the unit to return to service by June 1, 2023.

**New questions:**

**In addition to those follow-ups, I have questions regarding your response to compliance order HE-C-22-00472:**

- **When was the last time the Turbine 5 associated oil tank was filled prior to 04/09/2023, and also the next time after that date?**  
The Turbine 5 oil tank was last filled on 12/29/2022. It has not been filled since 4/9/2023.
- **Are there records available to correlate with filling of the associated oil tank? If so, please provide for the time period between 07/26/2022– the date of this email.**  
Yes. The oil tank is filled by procedure only when the "Low Lube Oil Level" warning on the control system computer screen comes in. It is filled until this warning clears. Currently the operator notebook is the only explicit indication that oil has been added. The page from this date is included. The hourly logs from 7/26/2022 until the present are also included, showing tank level in the column "Oil Tank Level" on side one of the logs, which correlate with tank level gradually decreasing since it was last filled. No daily logs are generated on dates when the turbine is shutdown for the duration of an entire day, which includes the first few days in the request.
- **Since the event in March of 2022, has the SWBNO conducted increased monitoring of the associated oil gauge on the reservoir in comparison to the tank level observed to ensure proper oil level when refilling the reservoir? If so, are there records to indicate this occurred? If so, please provide for the time period of 07/26/2022– the date of this email and describe that account for the most recent filling prior to 04/09/2023.**  
The two indications of oil tank level are the numeric gauge at the tank, and the qualitative "High Lube Oil Level" and "Low Lube Oil Level" warnings on the control system display. The gauge has been tracked hourly since prior to March 2022, and the warnings have been programmed into the control system since prior to that date as well. Visual checks of the tank level gauge on an hourly basis is the most practically frequent monitoring at this time.
- **Did the SWBNO add a knockdown tank vessel to support the associated vapor extractor piping?**

We are continuing to move forward with establishing a contract with GE to perform an engineering analysis and design and supply a knock-down tank for the vapor extractor

Scott S. Finney, CIT, REM  
Senior MS4 Stormwater Manager, SUSM  
Sewerage & Water Board of New Orleans  
Environmental Affairs Department  
Room 207  
8800 South Claiborne Ave,  
New Orleans, LA 70118  
(504) 865-0662 office



(504) 628-7549 Cell  
Email: [Sfinney@swbno.org](mailto:Sfinney@swbno.org)

---

**From:** Von Magee <[Von.Magee@LA.GOV](mailto:Von.Magee@LA.GOV)>  
**Sent:** Friday, April 21, 2023 2:39 PM  
**To:** FINNEY, Scott <[sfinney@swbno.org](mailto:sfinney@swbno.org)>  
**Cc:** WILSON, Ann <[awilson2@swbno.org](mailto:awilson2@swbno.org)>; SPOONER, Ron <[rspooneer@swbno.org](mailto:rspooneer@swbno.org)>; TYMRAK, Kaitlin <[ktymrak@swbno.org](mailto:ktymrak@swbno.org)>; MANCUSO, Eric <[EMANCUSO@swbno.org](mailto:EMANCUSO@swbno.org)>; DE JEAN, Shawn <[SDEJEAN@swbno.org](mailto:SDEJEAN@swbno.org)>; WILLIAMS, Anita <[awilliams2@swbno.org](mailto:awilliams2@swbno.org)>  
**Subject:** Questions Regarding LDEQ Complaint T213615

=====  
===== EXTERNAL EMAIL | USE CARE WITH LINKS AND ATTACHMENTS =====  
=====

Please provide responses to each item within the email below by close-of-business on 04/26/2023. Thank you.

Respectfully,

Von A. Magee  
Louisiana Department of Environmental Quality - SERO  
201 Evans Road Bldg. 4, Ste. 420  
New Orleans, LA 70123

Office: 504-736-7731  
Fax: 504-736-7702

---

**From:** Von Magee <[Von.Magee@LA.GOV](mailto:Von.Magee@LA.GOV)>  
**Sent:** Friday, April 21, 2023 2:35 PM  
**To:** FINNEY, Scott <[sfinney@swbno.org](mailto:sfinney@swbno.org)>  
**Cc:** WILSON, Ann <[awilson2@swbno.org](mailto:awilson2@swbno.org)>; SPOONER, Ron <[rspooneer@swbno.org](mailto:rspooneer@swbno.org)>; TYMRAK, Kaitlin <[ktymrak@swbno.org](mailto:ktymrak@swbno.org)>; MANCUSO, Eric <[EMANCUSO@swbno.org](mailto:EMANCUSO@swbno.org)>; DE JEAN, Shawn <[SDEJEAN@swbno.org](mailto:SDEJEAN@swbno.org)>; WILLIAMS, Anita <[awilliams2@swbno.org](mailto:awilliams2@swbno.org)>  
**Subject:** RE: Questions Regarding LDEQ Complaint T213615  
**Importance:** High

Thank you for the reply Mr. Finney.

A few follow-up questions to your initial inquiry responses:

Regarding item #1.a:

- If you're proceeding as described, how is the SWBNO going to conduct remedial actions of the released material?
- Has the SWBNO made any definitive determinations as to an exact source since the time of your last email correspondence?

Regarding item #2:

- Please provide the current SDS for the Mobil DTE 732 turbine oil

Regarding items 1.b and 3:

- Is Turbine 5 still in operation as of this email's date?



- Is there an expected return-to-service date for Turbine 4 at this point-in time?

In addition to those follow-ups, I have questions regarding your response to compliance order HE-C-22-00472:

- When was the last time the Turbine 5 associated oil tank was filled prior to 04/09/2023, and also the next time after that date?
- Are there records available to correlate with filling of the associated oil tank? If so, please provide for the time period between 07/26/2023 – the date of this email.
- Since the event in March of 2022, has the SWBNO conducted increased monitoring of the associated oil gauge on the reservoir in comparison to the tank level observed to ensure proper oil level when refilling the reservoir? If so, are there records to indicate this occurred? If so, please provide for the time period of 07/26/2023 – the date of this email and describe that account for the most recent filling prior to 04/09/2023.
- Did the SWBNO add a knockdown tank vessel to support the associated vapor extractor piping?

Respectfully,

Von A. Magee  
Louisiana Department of Environmental Quality - SERO  
201 Evans Road Bldg. 4, Ste. 420  
New Orleans, LA 70123

Office: 504-736-7731  
Fax: 504-736-7702

---

**From:** FINNEY, Scott <[sfinney@swbno.org](mailto:sfinney@swbno.org)>  
**Sent:** Friday, April 14, 2023 10:20 AM  
**To:** Von Magee <[Von.Magee@LA.GOV](mailto:Von.Magee@LA.GOV)>  
**Cc:** WILSON, Ann <[awilson2@swbno.org](mailto:awilson2@swbno.org)>; SPOONER, Ron <[rspooner@swbno.org](mailto:rspooner@swbno.org)>; TYMRAK, Kaitlin <[ktymrak@swbno.org](mailto:ktymrak@swbno.org)>; MANCUSO, Eric <[EMANCUSO@swbno.org](mailto:EMANCUSO@swbno.org)>; DE JEAN, Shawn <[SDEJEAN@swbno.org](mailto:SDEJEAN@swbno.org)>; WILLIAMS, Anita <[awilliams2@swbno.org](mailto:awilliams2@swbno.org)>  
**Subject:** RE: Questions Regarding LDEQ Complaint T213615

**EXTERNAL EMAIL:** Please do not click on links or attachments unless you know the content is safe.

Von,

See the questions and answers you requested.

All information was provided by the General Superintendent's Office.

1. Is SWBNO aware of an occurrence fitting this description which occurred on or around 04/09/2023? If so, SWBNO received correspondence from local neighbors regarding oil droplets on April 9, 2023. On this date, Turbine 5 was the only power generation asset in operation.
  - a. Please describe the cause, contributing factors, and any immediate and planned corrective action(s); SWBNO is proceeding under the assumption that what is being observed in the adjacent neighborhood is residual oil emitted from the exhaust stack of Turbine 5. However, the exact cause is unknown, as it appears to be intermittent. SWBNO has engaged GE Gas and Power, the manufacturer of Turbine 5, to perform an engineering analysis and design and supply a knock-down tank for their vapor extractor, which will hopefully mitigate the issue.
  - b. Please provide details regarding the duration (day and start/stop times)?  
Turbine 5 was placed into service on April 3, 2023, following a mechanical issue with Turbine 4 that rendered it out of service. A 25-hz power asset is required to be online at all times at SWBNO in order to provide power for 25-hz potable water pumps and drainage pumps; SWBNO is the only power provider that



can provide 25-hz electricity for these pumps. Turbine 5 will be in operation until such time that Turbine 4 can be returned to use.

2. Please provide SDS sheet of any materials released.  
The composition and makeup of the material that was observed by the neighbors has not been identified. Turbine 5 uses Mobil DTE 732 turbine oil, or an equivalent product.
3. When were the relevant unit(s) last started/brought in to service?  
Prior to this event, Turbine 5 was last used on March 28, 2023 for a short duration during a rain event. However, both Turbines 4 and 5 remain critical to sustained water pumping and drainage operations and will continue to be utilized on a rotational basis until such time that the new Power Complex is operational.
4. Is there any kind of testing conducted toward verifying integrity of the relevant unit(s)? If so, please describe.  
SWBNO operations staff follows an SOP for startup and shutdown of Turbine 5, as well as for operation of the unit.

If you have any other questions please let me know.

Thanks  
Scott

Scott S. Finney, CIT, REM  
Senior MS4 Stormwater Manager, SUSM  
Sewerage & Water Board of New Orleans  
Environmental Affairs Department  
Room 207  
8800 South Claiborne Ave,  
New Orleans, LA 70118  
(504) 865-0662 office  
(504) 628-7549 Cell  
Email: [sfinney@swbno.org](mailto:sfinney@swbno.org)

---

**From:** Von Magee <[Von.Magee@LA.GOV](mailto:Von.Magee@LA.GOV)>  
**Sent:** Wednesday, April 12, 2023 2:57 PM  
**To:** FINNEY, Scott <[sfinney@swbno.org](mailto:sfinney@swbno.org)>  
**Subject:** Questions Regarding LDEQ Complaint T213615  
**Importance:** High

=====  
===== EXTERNAL EMAIL | USE CARE WITH LINKS AND ATTACHMENTS =====  
=====

Good afternoon Mr. Finney. Mr. daniel Cristina and I visited the Carrolton Water Treatment Plant today in-response to citizen complaint T213615 which alleges issues experienced with one of your turbines and resulting oil releasing through the exhaust stack, impacting neighboring houses and vehicles along Spruce Street between Monroe and Leonidas. When we arrived, we spoke with Ms. Anita Williams who directed specific questions to you. Those questions are listed below:

1. Is SWBNO aware of an occurrence fitting this description which occurred on or around 04/09/2023? If so,
  - a. Please describe the cause, contributing factors, and any immediate and planned corrective action(s);
  - b. Please provide details regarding the duration (day and start/stop times)?
2. Please provide SDS sheet of any materials released.
3. When were the relevant unit(s) last started/brought in to service?



4. Is there any kind of testing conducted toward verifying integrity of the relevant unit(s)? If so, please describe.

Please provide requested information by close-of-business on Friday 04/14/2023.

Please also note, I misidentified the date on the Field Interview Form (FIF) I left with Ms. Williams today. The inspection/departure dates both read as "4/2/23" and should read "4/12/23" I will make the correction when the form is sent to EDMS.

Respectfully,

Von A. Magee  
Louisiana Department of Environmental Quality - SERO  
201 Evans Road Bldg. 4, Ste. 420  
New Orleans, LA 70123

Office: 504-736-7731  
Fax: 504-736-7702

Thursday 12/29/22 11-7  
 (D. Peters, E. Eastling, D. Pilot, D. Millet, D. Jarreau)

Equip In: #4 Turbine, A pump, #1-2 S @ panda  
 #3, #4 @ claborne

Equip Out: #2 @ panda, #1 @ claborne  
 B pump, #1 Turbine, #1 EMD

@ 5:16am mod. RAIN In Area

\* #5 Turbine oil level low

#5 Turbine on T.G. @ 5:19am

Thur 12-29-22 7.3 shift  
 G. Alexander, G. Jones, A. Magee, R. Brand, R. Coleman

Equip In: #4 turbine, #5 turbine T.G., A pump,  
 #3 - 60 cycle, #4 - 25 cycle @ chaib, #1 - 25 cycle @  
 panda.

Equip Out: #1 turbine, B pump, #1 pump @ chaib  
 #2 - pump @ panda. 1-EMD OOS

@ 7:00am D. Dedmond call to say he will  
 be running late.

@ 8:00 B. Poole G. Jackson put oil in  
 #5 turbine. off T.G. OOS P & P. Loto DC's



Side One

# Sewerage and Water Board of New Orleans

## #5 Turbine Log



Date: 7-29-22

Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Finion Brg. No. 1 Temp.	Finion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (3T)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (C)	Oil Tank Level	Oil Level Ok In Aux. Oil Pump Yes / No - Add. Needed	Incoming Gas Press.	Kilowatts	Reading Taken By:
12M	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
1AM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
11	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
12N	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	E. Easterling
1PM	/	3601	81	110	126	134	120	/	126	157	160	/	174	/	40	1/2	Y	185	2900	D. Peltus
2	/	3600	81	110	126	134	120	/	126	157	160	/	174	/	40	1/2	Y	185	4700	E. Easterling
3	/	3609	83	110	128	134	120	/	126	158	160	/	174	/	40	1/2	Y	185	4800	
4	/	Stopped @ 3:52pm																		
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
11	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/

General Notes: Started @ 12:50pm Flame on: @ 1:01pm Up to Speed @ 1:14pm Field @ 1:20pm  
 Broke field @ 3:52 Stopped #5 Turbine @ 3:52pm Flame out @ 3:55pm On T.G. @ 4:14pm



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log



Date: 7-29-22

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M																									
1AM																									
2																									
3																									
4																									
5																									
6																									
7																									
8																									
9																									
10																									
11																									
12N																									
1PM	580	580	577	581	585	406					426			85					23	152	02	31	54	55	E.E.
2	587	547	547	550	552	416					455			85					23	152	02	31	54	55	OP
3	548	548	546	551	550	402					454			86					23	152	02	31	54	55	E.E.
4																									
5																									
6																									
7																									
8																									
9																									
10																									
11																									

General Notes: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 7/30/22



Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (31)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (C)	Oil Tank Level	Oil Level Oil In Acc. Oil Pump No. No. Add. Fueling	Incoming Gas Press.	Rebut	Reading Taken By:	
12M																					
1AM																					
2																					
3																					
4																					
5																					
6																					
7																					
8																					
9																					
10																					
11																					
12N																					
1PM		3609	84	118	140	156	129	140	163	163	183	45	1/2	Y	183	1400				D Peters	
2		3615	84	118	140	156	129	140	163	163	183	45	1/2	Y	183	1400				D Peters	
3		3629	84	118	140	156	129	140	163	163	183	45	1/2	Y	183	1400				D Peters	
4																					
5																					
6																					
7																					
8																					
9																					
10																					
11																					

General Notes: @ 12:19pm #5 Turbine started @ 12:24pm Flame on @ 12:38pm up to speed @ 1:00pm Loaded @ 3:44pm #5 Turbine stopped @ 3:47 Flame out @ 3:56pm on T.G.



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log



Date: 7/30/22

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Alt	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right		
12M																										
1AM																										
2																										
3																										
4																										
5																										
6																										
7																										
8																										
9																										
10																										
11																										
12N																										
1PM	612	611	639	612	648	478	/	/	/	/	499	/	/	86	/	/	/	/	23	152	02	31	S4	SS	DP	
2	610	611	610	614	617	480	/	/	/	/	507	/	/	86	/	/	/	/	23	152	02	31	S4	SS	DP	
3	562	563	563	566	567	475	/	/	/	/	489	/	/	86	/	/	/	/	23	152	02	31	S4	SS	DP	
4																										
5																										
6																										
7																										
8																										
9																										
10																										
11																										

General Notes: \_\_\_\_\_



Side One

# Sewerage and Water Board of New Orleans

## #5 Turbine Log

Date: 8-10-22



Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp from Cooler	No. 1 Eng. Temp.	No. 2 Eng. Temp.	No. 2 Thrust Temp.	No. 3 Eng. Temp.	No. 4 Drg. Temp.	Piston Eng. No. 1 Temp.	Piston Eng. No. 2 Temp.	Gear Eng. No. 3 Temp.	Gear Eng. Thrust (2)	Gear Eng. No. 4 Temp.	Generator Eng. Temp. (C)	Oil Tank Level	Oil Level Oil in Gas Oil Pump Yes/No - Added/Noted	Incoming Gas Press.	Kilowatts	Reading Taken By:	
12M	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
1AM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	E. Easterling	
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
6	/	3619	79	110	126	135	120	/	126	157	160	/	192	/	40	1/2	y	184	2800		
7	/	3622	80	110	142	158	130	/	142	162	163	/	179	/	40	1/2	y	184	4000	Ju	
8	/	3647	82	116	143	161	130	/	144	162	164	/	183	/	40	1/2	Yes	184	1000	G. Butler	
9	/	Stopped @ 8:15										/	/	/	/	/	/	/	/	/	
10	/	Rain Load										/	/	/	/	/	/	/	/	/	
11	/	Start @ 12:20										/	/	/	/	/	/	/	/	/	
12N	/	/	/	/	/	/	/	/	Flame @	/	/	/	12:25	/	/	/	/	/	Speed @ 12:35		
1PM	/	3609	79	115	145	161	130	/	146	162	163	/	183	/	47	1/2	y	184	2800	Ju	
2	/	3603	79	115	145	161	130	/	146	162	163	/	183	/	47	1/2	y	184	4200	Ju	
3	/	3603	79	115	145	161	130	/	146	162	163	/	184	/	46	1/2	y	184	1800	No	
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
11	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		

General Notes: Started @ 6:00 am Flame on @ 6:00 am Up to Speed @ 6:10 am Load @ 6:23 am  
 Stopped #5 Turbine 8:15 AM C.B.



Side Two

Sewerage and Water Board of New Orleans  
#5 Turbine Log



Date: 8-10-22

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Air	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M																									
1AM																									
2																									
3																									
4																									
5																									
6	600	599	595	598	603	407					442			80					23 <sup>F</sup>	151	64	31	54	54	E.E.
7	534	534	535	537	539	462					472			83					23 <sup>F</sup>	157	62	30 <sup>F</sup>	53 <sup>F</sup>	54	C.B.
8	534	534	535	537	539	462					472			83					23 <sup>F</sup>	157	62	30 <sup>F</sup>	53 <sup>F</sup>	54	C.B.
9																									
10		8:15 AM Stop #5																							
11																									
12N			Restart								12:30A														
1PM	600	600	598	599	603	462					499								20 <sup>F</sup>	155	63	31	52	54	50
2																			20 <sup>F</sup>	155	62	31	52	54	50
3	528	528	530	530	536	494					491								23	159	63	31	52	54	50
4																									
5																									
6																									
7																									
8																									
9																									
10																									
11																									

General Notes: Started @ 6:00 am Flame on @ 6:00 am Up to Speed @ 6:10 am Load @ 6:23 am  
Stopped #5 Turbine 8:15 AM C.B. @ 3:38 pm Stopped, @ 3:41 Flame out, @ 3:56 pm T.G.



Side One

Sewerage and Water Board of New Orleans



#5 Turbine Log

Date 8-10-22

Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp. From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Piston Brg. No. 1 Temp.	Piston Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (G)	Oil Tank Level	Oil Level On In. Am. Of Tank	Pressure	Temperature	Reading Taken By.
12M	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
1AM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	E. Easterling
9	/	3600	88	105	120	127	116	/	125	155	150	/	168	/	40	1/2	4	184	
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
11	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
12N	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
1PM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
11	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	

General Notes: Started #5 Turbine @ 7:43 am. Flame @ 7:48 am. Stopped #5 Turbine @ 7:53 am. Flame out @ 7:54 am. Stopped #5 Turbine because of unusually high smell of gas outside of Turbine. Started #5 Turbine @ 8:34 am. Flame on @ 8:45 am up to speed @ 8:57 am. Field @ 9:00 am Stopped @ 9:23 am. Flame out @ 9:27 am. T.G. @ 9:35 am



# #5 Turbine Log

Date: 8-10-22



Time	Point No. 1 Exhaust Temp	Point No. 2 Exhaust Temp	Point No. 4 Exhaust Temp	Point No. 5 Exhaust Temp	Point No. 6 Exhaust Temp	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filler	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M																									
1AM																									
2																									
3																									
4																									
5																									
6																									
7																									
8																									
9	512	512	511	514	516	457					355			86					22 <sup>s</sup>	150	60	31	53	55	E.E.
10																									
11																									
12N																									
1PM																									
2																									
3																									
4																									
5																									
6																									
7																									
8																									
9																									
10																									
11																									

General Notes: Started #5 Turbine @ 7:43 am. Flame on @ 7:48 am. Stopped #5 Turbine @ 7:53 am. Flame out @ 7:54 am. Stopped #5 Turbine because of unusually high smell of gas outside of Turbine. Started #5 Turbine @ 8:34 am. Flame on @ 8:45 am. up to Speed @ 8:57 am. Field @ 9:00 am Stopped @ 9:23 am Flame out @ 9:27 am T.G. @ 9:35 am



Side One

# Sewerage and Water Board of New Orleans

## #5 Turbine Log

Date: 8-18-22



Time	Run Hours	Speed/Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (31)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (G)	Oil Tank Level	Oil Level Ok In Avc. Oil Press. Yes/No	Add'l. Notes	Incoming Gas Press	Kilowatts	Reading Taken By:	
12M	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
1AM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	E. Easterling
11	/	3600	79	110	122	131	126	/	120	155	156	/	170	/	40	1/2	y	/	184	1800	/	E. Easterling
12N	/	3600	78	110	122	132	128	/	120	155	158	/	172	/	40	1/2	y	/	184	2000	/	E. Easterling
1PM	/	3600	79	110	124	132	128	/	122	156	159	/	172	/	40	1/2	y	/	184	1400	/	E. Easterling
2	/	3600	86	115	142	160	130	/	142	162	164	/	180	/	40	1/2	y	/	184	1300	/	E. Easterling
3	/	3631	90	115	142	164	130	/	144	163	164	/	182	/	49	1/2	y	/	184	1500	/	SW
4	/	3631	90	115	142	164	130	/	145	162	164	/	182	/	49	1/2	y	/	184	1500	/	SW
5	/																					
6	/																					
7	/																					
8	/																					
9	/																					
10	/																					
11	/																					

General Notes: Started #5 Turbine @ 10:23 am Flame on @ 10:27 am Up to Speed @ 10:40 am Load @ 10:45 am



Side Two

Sewerage and Water Board of New Orleans  
#5 Turbine Log



Date: 8-18-22

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M																									
1AM																									
2																									
3																									
4																									
5																									
6																									
7																									
8																									
9																									
10																									
11	545	545	542	540	550	459					379			84					23 <sup>2</sup>	151	62	30	54	54	E.E.
12N	540	540	543	545	549	458					400			85					23 <sup>3</sup>	152	62	30	54	55	E.E.
1PM	540	547	544	545	548	457					387			85					23	152	62	30	54	55	E.E.
2	549	549	549	552	553	467					480			88					23	151	60	31	54	55	E.E.
3	553	554	554	557	559	471					485			89					22	150	60	31	53	54	5
4	551	552	552	554	557	469					483			88					22	150	60	31	53	54	5
5																									
6																									
7																									
8																									
9																									
10																									
11																									

General Notes: Started #5 Turbine @ 10:23 am. Flame on @ 10:27 am. Up to Speed @ 10:40 am. Load @ 10:45 am



Side One

Seawater and Water Board of New Orleans

#5 Turbine Log

Date: 8-19-22



Time	Run Hours	Speed / rpm	Ambient Temp.	Oil Temp from Cooler	No. 1 Eng. Temp.	No. 2 Eng. Temp.	No. 3 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Eng. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Eng. No. 3 Temp.	Gear Brg. Turbine Oil	Oil Eng. No. 4 Temp.	Generator Eng. Temp. (°)	Oil Tank Level	Oil Level in the Air, Oil Pump No. 1/2	Oil Level in the Air, Oil Pump No. 2/3	Incoming Gas Press.	MAWP	Reading Taken By:	
12M	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
1AM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
11	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
12N	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
1PM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
2	/	/	/	/	/	/	/	/	/	/	/	/	183	/	47	1/2	y	185	1500	/	/	/
3	/	/	84	115	142	160	130	/	140	162	164	/	180	/	47	1/2	y	184	2100	/	/	/
4	/	/	84	115	142	160	130	/	140	162	164	/	183	/	48	1/2	y	184	1900	/	/	/
5	/	/	86	116	143	162	121	/	142	162	164	/	182	/	48	1/2	y	184	1900	/	/	/
6	/	/	88	116	143	164	121	/	145	163	164	/	182	/	/	/	/	184	1700	/	/	/
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
11	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/

General Notes: Started #5 Turbine @ 2:22pm. Flame on @ 2:27pm. Up to Speed @ 2:40pm.



#5 Turbine Log

Date: 8-19-22



Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Air	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right
12M																								
1AM																								
2																								
3																								
4																								
5																								
6																								
7																								
8																								
9																								
10																								
11																								
12N																								
1PM																								
2																								
3	546	547	548	550	552	467					466													
4	562	563	563	565	566	469					484								22 <sup>F</sup>	149	60	31	53	54
5	560	560	561	564	565	467					484								22 <sup>F</sup>	149	60	31	53	54
6	562	562	563	565	566	469					484								22 <sup>F</sup>	148	60	31	53	54
7																			22 <sup>F</sup>	148	60	31	53	54
8																								
9																								
10																								
11																								

General Notes: Started #5 Turbine @ 2:22pm. Flame on @ 2:27pm. Up to Speed @ 2:40pm.



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 8-26-22



Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust(3T)	Gear Brg. No. 4 Temp.	Generator Brg. Temp.(c)	Oil Tank Level	Oil Level OK In Aux. Oil Pump Yes/No Add/Drain	Incoming Gas Press.	Kilowatts	Reading Taken By:	
12M	/																				
1AM	/																				
2	/																				
3	/																				
4	/																				
5	/																				
6	/																				
7	/																				
8	/																				
9	/																				
10	/																				
11	/																				
12N	/																				
1PM	/																				
2	/																				
3	/																				
4	/																				
5	/	3607	86	110	125	135	118	/	126	159	160	/	172	/	40	1/2	y	184	4500	E. Easterling	
6	/	3608	86	110	125	136	118	/	126	159	160	/	172	/	40	1/2	y	184	4100	E. Easterling	
7	/	3606	85	110	126	135	118	/	125	158	160	/	174	/	40	1/2	y	184	4300	E. Easterling	
8	/	3606	86	110	126	136	118	/	125	162	162	/	176	/	40	1/2	y	184	4500	E. Easterling	
9	/	3607	86	110	126	135	118	/	125	162	166	/	178	/	40	1/2	y	184	4500	E. Easterling	
10	/	3606	85	110	126	136	117	/	124	159	162	/	174	/	40	1/2	y	184	4700	E. Easterling	
11	/	3606	85	110	124	136	117	/	124	159	162	/	174	/	40	1/2	y	184	4700	E. Easterling	

General Notes: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log

Date: 8-26-22



Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel- All	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M																									
1AM																									
2																									
3																									
4																									
5																									
6																									
7																									
8																									
9																									
10																									
11																									
12N																									
1PM																									
2																									
3																									
4																									
5	609	609	606	609	614	472					410			84					23 <sup>5</sup>	152	67	31	52	54	E.E.
6	609	609	607	609	613	473					411			85					23 <sup>5</sup>	152	67	31	52	54	E.E.
7	608	608	607	608	612	472					411			85					23 <sup>5</sup>	152	65	31	52	54	E.E.
8	608	608	606	609	612	471					410			80					23 <sup>5</sup>	152	65	31	52	54	E.E.
9	609	609	607	608	610	474					411			85					23 <sup>5</sup>	154	65	31	52	55	E.E.
10	608	608	606	609	610	472					410			80					23	152	64	31	52	53	E.E.
11	608	608	607	611	612	469					518			86					25	152	64	31	52	52	55

General Notes: Started #5 Turbine @ 4:54pm. Flame on @ 4:58pm. Up to Speed @ 5:10pm. Field @ 5:20pm.



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 8-27-22



Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (31)	Gear Brg. No. 4 Temp	Generator Brg. Temp (C)	Oil Tank Level	Oil Level OK in Aux. Oil Pump Yes/No - <i>diff. level</i>	Incoming Gas Press.	Kilowatts	Reading Taken By:
12M	/	3606	85	110	126	136	117	/	127	159	162	/	174	/	40	1/2	Y	184	4700	G J
1AM	/	3612	85	110	126	136	117	/	124	160	162	/	180	/	40	1/2	Y	184	4200	G J
2	/	3612	85	110	126	136	117	/	125	160	162	/	180	/	40	1/2	Y	184	4200	G J
3	/	3612	85	110	126	136	117	/	125	160	162	/	180	/	40	1/2	Y	184	4200	G J
4	/	3613	81	110	142	160	122	/	140	159	162	/	180	/	40	1/2	Y	184	4300	G J
5	/	3613	81	110	142	160	122	/	140	159	162	/	180	/	40	1/2	Y	184	4300	G J
6	/	3613	81	110	142	160	122	/	140	159	162	/	180	/	40	1/2	Y	184	4300	G J
7	/	3612	89	110	142	160	122	/	140	160	162	/	180	/	40	1/2	Y	184	4900	<i>[Signature]</i>
8	/	3612	89	110	142	160	122	/	140	160	162	/	180	/	40	1/2	Y	184	4900	<i>[Signature]</i>
9	/	3612	89	110	142	160	122	/	140	160	162	/	180	/	40	1/2	Y	184	4900	<i>[Signature]</i>
10	/	3612	90	110	142	160	122	/	140	160	162	/	180	/	40	1/2	Y	184	5000	<i>[Signature]</i>
11	/	3602	90	110	142	160	122	/	140	160	162	/	180	/	40	1/2	Y	184	5300	<i>[Signature]</i>
12N	/																			<i>[Signature]</i>
1PM	/																			<i>[Signature]</i>
2	/																			<i>[Signature]</i>
3	/																			<i>[Signature]</i>
4	/																			<i>[Signature]</i>
5	/																			<i>[Signature]</i>
6	/																			<i>[Signature]</i>
7	/																			<i>[Signature]</i>
8	/																			<i>[Signature]</i>
9	/																			<i>[Signature]</i>
10	/																			<i>[Signature]</i>
11	/																			<i>[Signature]</i>

@ 4:40 stopped #5 turbine

General Notes: Did't take Reading do to start of #4 turbine



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log

Date: 8-27-22



Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Air	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Drg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M	608	608	606	609	610	472	/	/	/	/	410	/	/	86	/	/	/	/	23	152	64	31	53	53	GJ
1AM	610	610	608	607	609	462	/	/	/	/	410	/	/	87	/	/	/	/	23	152	64	31	52	53	GJ
2	610	610	608	607	609	462	/	/	/	/	410	/	/	87	/	/	/	/	23	152	64	31	52	53	GJ
3	610	610	608	607	609	462	/	/	/	/	410	/	/	87	/	/	/	/	23	152	64	31	52	53	GJ
4	609	607	606	610	615	469	/	/	/	/	518	/	/	94	/	/	/	/	23	152	64	31	54	54	GJ
5	607	607	606	610	615	469	/	/	/	/	518	/	/	84	/	/	/	/	23	152	64	31	54	54	GJ
6	607	607	606	610	615	469	/	/	/	/	518	/	/	84	/	/	/	/	23	152	64	31	54	54	GJ
7	619	619	618	623	627	474	/	/	/	/	510	/	/	/	/	/	/	/	23	152	68	30	59	59	He
8	619	619	618	623	627	474	/	/	/	/	510	/	/	/	/	/	/	/	23	152	68	30	59	59	He
9	619	619	618	623	627	474	/	/	/	/	510	/	/	/	/	/	/	/	23	152	68	30	59	59	He
10	657	657	656	650	666	476	/	/	/	/	511	/	/	/	/	/	/	/	23	152	64	30	59	59	He
11	657	657	656	660	666	476	/	/	/	/	511	/	/	/	/	/	/	/	23	152	64	30	59	59	He
12N	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
1PM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
11	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/

General Notes:



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 9.31.22



Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (31)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (C)	Oil Tank Level	Oil Level Ok In Aux. Oil Pump	Incoming Gas Press.	Kilowatts	Reading Taken By:	
12M	/																				
1AM	/																				
2	/																				
3	/																				
4	/																				
5	/																				
6	/																				
7	/																				
8	/				@ 7:55 Started				@ 8:04 Flame				@ 8:17 UP to speed								
9	/	3500	89	100	139	159	122	140	162	160		182		46	3/8	Yes	184	9700		Hy	
10	/	3500	89	100	139	159	122	170	162	160		182		46	3/8	Yes	189	9700		Hy	
11	/				@ 10:58 AM Stopped				@ 11:00 AM				Flame out.								
12N	/																				
1PM	/																				
2	/																				
3	/																				
4	/																				
5	/																				
6	/																				
7	/																				
8	/																				
9	/																				
10	/																				
11	/																				

General Notes: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log



Date: 8.31.22

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brig. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M																									
1AM																									
2																									
3																									
4																									
5																									
6																									
7																									
8																									
9	633	635	633	637	642	475					507								29	155	52	30	53	55	No
10	516	516	517	519	520	459					488								25	155	52	30	53	55	Yes
11																									
12N																									
1PM																									
2																									
3																									
4																									
5																									
6																									
7																									
8																									
9																									
10																									
11																									

General Notes: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



Side One

Sewerage and Water Board of New Orleans  
#5 Turbine Log



Date: ~~9/1~~ 9/3/22

Time	Run Hours	Speed/Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (3T)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (C)	Oil Tank Level	Oil Level Ok In Aux. Oil Pump Yes / No. Add if Needed	Incoming Gas Press.	Kilowatts	Reading Taken By:
12M																				
1AM																				
2																				
3																				
4																				
5																				
6																				
7																				
8																				
9																				
10																				
11																				
12N			83	110	127	156	123	-	137	162	160	-		180	45	3/8	Y	185	6200	SM
1PM			100	110	140	160	124	-	140	162	160	-		180	45	3/8	Y	184	6000	SM
2			100	110	142	160	124	-	140	162	160	-		180	45	3/8	Y	184	4800	SM
3		3500	76	100	140	160	124	-	140	162	158	-	180	-	45	3/8	Yes	184	10500	SM
4		3500	76	100	140	160	124	-	140	162	158	-	180	-	45	3/8	Yes	184	11000	SM
5		3600	76	100	140	160	124	-	140	162	158	-	180	-	45	3/8	Yes	184	9000	SM
6		3600	80	100	140	160	124	-	140	162	158	-	180	-	45	3/8	Yes	184	6300	SM
7		3600	80	100	140	160	124	-	140	162	158	-	180	-	45	3/8	Yes	184	5000	SM
8		3600	80	100	140	160	124	-	140	162	158	-	180	-	45	3/8	Yes	184	4000	SM
9		3600	80	100	140	160	124	-	140	162	158	-	180	-	45	3/8	Yes	184	3800	SM
10		3600	80	100	140	160	124	-	140	162	158	-	180	-	45	3/8	Yes	184	3500	SM
11		3620	80	100	140	160	124	-	140	162	158	-	180	-	45	3/8	Yes	184	3500	D.P.

General Notes: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log



Date: 9/3/22

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right
12M																								
1AM																								
2																								
3																								
4																								
5																								
6																								
7																								
8																								
9																								
10																								
11	Start 10:30						Flame 10:42						Speed 10:54						Load 11:01					
12N	715	716	714	712	474	470	-	-	-	-	580	-	-	-	-	-	-	-	24	152	66	30	55	54
1PM	690	698	698	699	669	483	-	-	-	-	542	-	-	-	-	-	-	-	24 1/2	152	66	30	57	52
2	628	628	627	631	625	474	-	-	-	-	533	-	-	-	-	-	-	-	24 1/2	152	66	30	58	52
3	628	628	627	631	625	474	-	-	-	-	530	-	-	-	-	-	-	-	29	152	68	30	54	55
4	785	786	776	773	771	477	-	-	-	-	530	-	-	-	-	-	-	-	28	152	68	30	54	55
5	636	636	635	638	644	474	-	-	-	-	518	-	-	-	-	-	-	-	28	152	68	30	54	55
6	636	636	635	638	644	474	-	-	-	-	518	-	-	-	-	-	-	-	28	152	68	30	54	55
7	636	636	635	638	644	474	-	-	-	-	518	-	-	-	-	-	-	-	29	152	68	30	54	55
8	636	636	635	638	644	474	-	-	-	-	506	-	-	-	-	-	-	-	29	152	68	30	54	55
9	604	609	604	608	611	469	-	-	-	-	506	-	-	-	-	-	-	-	29	152	68	30	54	55
10	604	601	604	608	611	469	-	-	-	-	506	-	-	-	-	-	-	-	29	152	68	30	54	55
11	593	594	592	598	600	469	-	-	-	-	511	-	-	-	-	-	-	-	24	152	68	30	54	55 DP

General Notes: \_\_\_\_\_



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 9/1/22



Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (3T)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (G)	Oil Tank Level	Oil Level OK In Adv. Oil Pump Yes / No. Add / Overfill	Incoming Gas Press.	Kilowatts				Reading Taken By:
12M		3620	80	110	140	160	124	—	140	162	158	—	180	—	45	3/8	Yes	184	3500				D. Peters
1AM		3620	80	110	140	160	124	—	140	162	158	—	180	—	45	3/8	Yes	184	3500				D. Peters
2		3619	80	110	140	160	124	—	140	162	158	—	180	—	45	3/8	Yes	184	3600				D. Peters
3		3619	80	110	140	160	124	—	140	162	158	—	180	—	45	3/8	Yes	184	3600				D. Peters
4		3619	80	110	140	160	124	—	140	162	158	—	180	—	45	3/8	Yes	184	3500				D. Peters
5		3619	80	110	140	160	124	—	140	162	158	—	180	—	45	3/8	Yes	184	3600				D. Peters
6		3619	80	110	140	160	124	—	140	162	158	—	180	—	45	3/8	Yes	184	3600				D. Peters
7	—	3612	83	110	140	160	124	—	140	162	160	—	180	—	45	3/8	Yes	184	4600	—	—	—	C. Butler
8	—	3612	83	110	140	160	124	—	140	162	160	—	180	—	45	3/8	Yes	184	4600	—	—	—	C. Butler
9	—	3613	83	110	140	160	124	—	140	162	160	—	180	—	45	3/8	Yes	184	4500	—	—	—	C. Butler
10	—	3615	83	110	140	160	124	—	140	162	160	—	180	—	45	3/8	Yes	184	4200	—	—	—	C. Butler
11	—	3617	86	110	140	160	124	—	142	162	161	—	182	—	45	3/8	Yes	184	3700	—	—	—	C. Butler
12N	—	3617	86	110	140	160	124	—	142	162	161	—	182	—	45	3/8	Yes	184	3700	—	—	—	C. Butler
1PM	—	3621	86	110	140	160	124	—	142	162	161	—	182	—	45	3/8	Yes	184	3200	—	—	—	C. Butler
2	—	3610	86	110	140	160	124	—	142	162	161	—	182	—	45	3/8	Yes	183	4700	—	—	—	C. Butler
3		3600	88	110	140	160	124	—	142	162	160	—	182	—	45	3/8	Yes	185	3600	—	—	—	No
4		3600	88	110	140	160	124	—	142	162	160	—	182	—	45	3/8	Yes	183	2600	—	—	—	No
5		3600	88	110	140	160	124	—	142	162	160	—	182	—	45	3/8	Yes	183	2000	—	—	—	No
6		3600	84	100	140	160	124	—	142	162	160	—	182	—	45	3/8	Yes	189	3000	—	—	—	No
7		3600	84	100	140	160	124	—	142	162	160	—	182	—	45	3/8	Yes	184	3200	—	—	—	No
8		3600	84	100	140	160	124	—	142	162	160	—	182	—	45	3/8	Yes	189	3000	—	—	—	No
9		3600	84	100	140	160	124	—	142	162	160	—	182	—	45	3/8	Yes	189	2800	—	—	—	No
10		3600	84	100	140	160	124	—	142	162	160	—	182	—	45	3/8	Yes	184	2800	—	—	—	No
11		3623	82	100	140	160	124	—	142	162	165	—	184	—	45	3/8	Yes	185	2900	—	—	—	a 2

General Notes:



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log



Date: 9/4/22

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M	592	593	593	597	599	467	-	-	-	-	510	-	-	-	-	-	-	-	24	152	68	30	54	55	DP
1AM	593	594	594	598	600	467	-	-	-	-	510	-	-	-	-	-	-	-	24	152	68	30	54	55	DP
2	596	596	596	600	602	468	-	-	-	-	512	-	-	-	-	-	-	-	24	152	68	30	54	55	DP
3	596	596	596	599	600	468	-	-	-	-	512	-	-	-	-	-	-	-	24	152	68	30	54	55	DP
4	593	593	593	596	600	468	-	-	-	-	511	-	-	-	-	-	-	-	24	152	68	30	54	55	DP
5	593	593	593	597	600	468	-	-	-	-	510	-	-	-	-	-	-	-	24	152	68	30	54	55	DP
6	594	595	594	598	601	467	-	-	-	-	511	-	-	-	-	-	-	-	24	152	68	30	54	55	DP
7	616	616	615	619	624	469	-	-	-	-	523	-	-	-	-	-	-	-	24	155	69	30 <sup>E</sup>	53 <sup>E</sup>	54	C.B.
8	616	616	615	619	624	469	-	-	-	-	523	-	-	-	-	-	-	-	24	155	69	30 <sup>E</sup>	53 <sup>E</sup>	54	C.B.
9	622	622	622	626	630	471	-	-	-	-	534	-	-	-	-	-	-	-	24	155	69	30 <sup>E</sup>	53 <sup>E</sup>	54	C.B.
10	606	606	605	609	611	470	-	-	-	-	519	-	-	-	-	-	-	-	24	155	69	30 <sup>E</sup>	53 <sup>E</sup>	54	C.B.
11	603	604	603	607	610	472	-	-	-	-	519	-	-	-	-	-	-	-	24	157	64	30 <sup>E</sup>	53 <sup>E</sup>	54	C.B.
12N	603	604	603	607	610	472	-	-	-	-	519	-	-	-	-	-	-	-	24	157	64	30 <sup>E</sup>	53 <sup>E</sup>	54	C.B.
1PM	594	595	595	599	601	473	-	-	-	-	514	-	-	-	-	-	-	-	24	157	64	30 <sup>E</sup>	53 <sup>E</sup>	54	C.B.
2	630	630	628	631	636	477	-	-	-	-	527	-	-	-	-	-	-	-	24	157	64	30 <sup>E</sup>	53 <sup>E</sup>	54	C.B.
3	578	578	579	582	584	469					503								29	157	64	30	54	54	He
4	578	578	579	582	584	469					503								29	157	64	30	54	54	He
5	578	578	579	582	584	469					503								29	157	64	30	54	54	He
6	588	588	589	592	594	469					506								29	157	64	30	54	54	He
7	588	588	589	592	594	469					506								29	157	64	30	54	54	He
8	588	588	589	592	594	469					502								29	157	64	30	54	54	He
9	579	579	580	583	585	467					502								29	157	64	30	54	54	He
10	579	579	580	583	585	467					502								29	157	64	30	54	54	He
11	574	574	580	584	586	466					507			25					24	155	62	30	54	54	C.O.

General Notes:



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 9-5-22



Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (31)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (C)	Oil Tank Level	Oil Level OK In Aux. Oil Pump Yes / No. Add If Needed	Incoming Gas Press.	Kilowatts				Reading Taken By:
12M		3623	81	108	140	160	124	—	142	162	165	—	184	—	45	3/8	Yes	185	2800				a e
1AM		3622	81	108	140	160	124	—	142	162	162	—	184	—	45	3/8	Yes	185	3000				a e
2		3622	81	108	140	160	124	—	142	162	162	—	184	—	45	3/8	Yes	184	3000				a e
3		3623	81	108	140	160	124	—	142	162	162	—	184	—	45	3/8	Yes	185	3000				a e
4		3622	81	108	140	160	124	—	142	162	162	—	184	—	45	3/8	Yes	185	3000				a e
5		3621	81	106	140	160	124	—	140	162	161	—	183	—	45	3/8	Yes	184	3000				a e
6		3621	81	106	140	160	124	—	140	162	161	—	183	—	45	3/8	Yes	184	3100				
7		3621	82	110	140	160	125	—	140	162	161	—	182	—	45	3/8	Yes	185	3700	—	—	—	See
8		3604	84	110	140	159	124	—	142	162	160	—	182	—	45	3/8	Yes	184	5500	—	—	—	C. Butler
9		3619	86	110	140	159	124	—	142	162	160	—	182	—	45	3/8	Yes	184	3400	—	—	—	C. Butler
10		3621	86	110	140	160	124	—	142	162	162	—	182	—	45	3/8	Yes	184	3300	—	—	—	C. Butler
11		3623	86	110	140	160	124	—	142	162	162	—	182	—	45	3/8	Yes	184	2900	—	—	—	C. Butler
12N		3623	87	110	140	160	124	—	142	162	162	—	182	—	45	3/8	Yes	184	2900	—	—	—	C. Butler
1PM		3623	90	110	140	160	124	—	142	162	162	—	183	—	45	3/8	Yes	184	2900	—	—	—	C. Butler
2		3623	90	110	140	160	124	—	142	162	162	—	183	—	45	3/8	Yes	184	2800	—	—	—	C. Butler
3		3600	90	100	140	160	129	—	142	162	162	—	183	—	45	3/8	Yes	184	2800	—	—	—	See
4		3600	90	100	140	160	129	—	142	162	162	—	183	—	45	3/8	Yes	184	2200	—	—	—	See
5		3600	88	100	140	160	129	—	142	162	162	—	183	—	45	3/8	Yes	184	2700	—	—	—	See
6		3600	88	100	140	160	129	—	142	162	162	—	183	—	45	3/8	Yes	184	2700	—	—	—	See
7		3600	88	100	140	160	129	—	142	162	164	—	183	—	45	3/8	Yes	184	2800	—	—	—	See
8		3600	88	100	140	160	129	—	142	162	164	—	183	—	45	3/8	Yes	185	2800	—	—	—	See
9		3600	84	100	140	160	129	—	142	162	164	—	183	—	45	3/8	Yes	185	3100	—	—	—	See
10		3600	84	100	140	160	129	—	142	162	164	—	183	—	45	3/8	Yes	185	3100	—	—	—	See
11		3613	83	108	140	160	124	—	142	162	164	—	183	—	45	3/8	Yes	184	2800	—	—	—	a e

General Notes:



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log

Date: 9-5-22



Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M	578	578	579	582	584	467	<del>582</del>				501	3		85				24	155	62	30	54	54	C-12
1AM	579	580	580	587	585	467					501			84				24	155	62	30	54	54	C-0.
2	581	581	582	585	587	467					507			84				24	155	62	30	54	54	C-0
3	580	580	581	584	587	466					507			87				24	157	62	30	54	55	C-1
4	577	577	578	581	587	464					502			83				24	157	62	30	54	55	C-1
5	579	580	580	587	586	465					502			87				24	157	62	30	54	55	C-1
6	587	587	587	587	589	466					504			87				24	157	62	30	54	55	C-1
7	584	585	585	589	591	466	-	-	-	-	505	-	-	83	-	-	-	24	153	62	30	53	55	55
8	615	615	614	618	<del>624</del> 473	473	-	-	-	-	523	-	-	84	-	-	-	24	155	64	30 <sup>5</sup>	53 <sup>5</sup>	54	C.B.
9	594	595	595	598	601	470	-	-	-	-	513	-	-	84	-	-	-	24	155	64	30 <sup>5</sup>	53 <sup>5</sup>	54	C.B.
10	594	594	594	598	600	472	-	-	-	-	512	-	-	86	-	-	-	24	155	62	30 <sup>5</sup>	53 <sup>5</sup>	54	C.B.
11	587	588	588	591	594	473	-	-	-	-	509	-	-	87	-	-	-	24	155	62	30 <sup>5</sup>	53 <sup>5</sup>	54	C.B.
12N	588	588	589	592	594	473	-	-	-	-	509	-	-	87	-	-	-	24	155	62	30 <sup>5</sup>	53 <sup>5</sup>	54	C.B.
1PM	588	588	589	592	594	473	-	-	-	-	509	-	-	91	-	-	-	24	155	62	30 <sup>5</sup>	53 <sup>5</sup>	54	C.B.
2	590	591	591	594	596	475	-	-	-	-	511	-	-	92	-	-	-	24	155	62	30 <sup>5</sup>	53 <sup>5</sup>	54	C.B.
3	584	584	585	589	592	575					511			92				24	155	62	30	53	54	54
4	584	584	585	589	592	575					511			92				24	165	62	30	53	54	54
5	580	580	582	586	590	570					506			90				24	155	62	30	53	54	54
6	580	580	582	586	590	570					506			90				24	155	62	30	53	54	54
7	582	582	584	589	592	568					506			90				24	155	62	30	53	54	54
8	582	582	584	589	592	568					506			90				24	155	62	30	53	54	54
9	589	589	590	593	595	469					506			89				24	155	62	30	53	54	54
10	589	589	590	593	595	469					506			88				24	155	62	30	53	54	54
11	579	579	580	583	584	465					502			88				24	155	62	30	54	55	C-0.

General Notes:



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 9-6-22



Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No.1 Brg. Temp	No.2 Brg. Temp.	No. 2 Thrust Temp.	No.3 Brg. Temp.	No.4 Brg. Temp	Pinion Brg. No.1 Temp.	Pinion Brg. No.2 Temp.	Gear Brg. No.3 Temp.	Gear Brg. Thrust(37)	Gear Brg. No.4 Temp	Generator Brg. Temp.(C)	Oil Tank Level	Oil Level Oil In Ann. Oil Pump Yes No. Add if Steady	Incoming Gas Press.	Kilowatts				Reading Taken By:
12M		3613	84	108	140	160	126	—	142	162	162	—	183	—	45	3/8	Yes	184	2800				a 2h
1AM		3612	84	108	140	160	126	—	142	162	162	—	183	—	45	3/8	Yes	185	2900				a 4h
2		3612	84	108	140	160	126	—	142	162	162	—	183	—	45	3/8	Yes	185	2900				a 6h
3		3613	84	108	140	160	126	—	142	162	162	—	183	—	45	3/8	Yes	184	2800				a 8h
4		3612	83	108	140	160	126	—	142	162	162	—	183	—	45	3/8	Yes	184	2900				a 2h
5		3612	82	108	140	160	126	—	142	162	162	—	183	—	45	3/8	Yes	184	3000				a 4h
6		3615	82	106	140	160	126	—	142	162	162	—	183	—	45	3/8	Yes	184	2600				a 2h
7	—	3611	82	112	142	159	125	—	142	162	161	—	182	—	45	3/8	Yes	184	3100	—	—	—	C. Bradley
8	—	3611	82	112	142	159	125	—	142	162	161	—	182	—	45	3/8	Yes	185	3100	—	—	—	C. Bradley
9	—	3600	85	112	142	159	125	—	142	162	161	—	182	—	45	3/8	Yes	184	4100	—	—	—	C. Bradley
10	—	3600	86	112	142	159	125	—	142	162	161	—	182	—	45	3/8	Yes	184	4600	—	—	—	C. Bradley
11	—	3613	86	112	142	160	126	—	142	162	161	—	182	—	45	3/8	Yes	184	4400	—	—	—	C. Bradley
12N	—	3613	87	112	142	160	126	—	142	162	161	—	182	—	45	3/8	Yes	186	4400	—	—	—	C. Bradley
1PM	—				12:20pm Stop #9 Turbine.								—	—	—	—	—	—	—	—	—	—	C. Bradley
2	—																						
3																							
4																							
5																							
6																							
7																							
8																							
9																							
10																							
11																							

General Notes: \_\_\_\_\_



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log



Date: 9-6-22

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply Temp.	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right		
12M	579	579	580	583	585	466					502			87					24	155	62	30	54	55	C.O.	
1AM	582	582	583	586	588	466					502			86					24	155	60	30	54	55	C.O.	
2	580	580	581	584	586	465					501			86					24	155	60	30	54	55	C.O.	
3	577	577	578	581	583	464					500			86					24	155	61	30	54	55	C.O.	
4	577	577	578	581	583	464					500			86					24	155	61	30	54	55	C.O.	
5	580	580	580	584	586	465					501			86					24	155	61	30	54	55	C.O.	
6	570	571	570	574	575	467					497			86					24	155	61	30	54	55	C.O.	
7	582	582	583	586	588	465	—	—	—	—	501	—	—	85	—	—	—	—	24	155	62	30 <sup>5</sup>	53 <sup>5</sup>	54 <sup>5</sup>	C.B.	
8	582	582	583	586	588	465	—	—	—	—	501	—	—	85	—	—	—	—	24	155	62	30 <sup>5</sup>	53 <sup>5</sup>	54 <sup>5</sup>	C.B.	
9	625	625	624	628	633	472	—	—	—	—	528	—	—	88	—	—	—	—	24	155	62	30 <sup>5</sup>	53 <sup>5</sup>	54 <sup>5</sup>	C.B.	
10	623	623	623	627	632	473	—	—	—	—	529	—	—	88	—	—	—	—	24	155	62	30 <sup>5</sup>	53 <sup>5</sup>	54 <sup>5</sup>	C.B.	
11	617	617	619	621	625	473	—	—	—	—	526	—	—	89	—	—	—	—	24	155	62	30 <sup>5</sup>	53 <sup>5</sup>	54 <sup>5</sup>	C.B.	
12N	619	619	619	623	627	474	—	—	—	—	527	—	—	89	—	—	—	—	24	155	62	30 <sup>5</sup>	53 <sup>5</sup>	54 <sup>5</sup>	C.B.	
1PM							12:20pm Stop #5 Turbine					—	—	—	—	—	—	—							C.B.	
2							—	—	—	—	—	—	—	—	—	—	—	—								C.B.
3																										
4																										
5																										
6																										
7																										
8																										
9																										
10																										
11																										

General Notes: \_\_\_\_\_



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 9-7-22



Time	Run Hours	Speed / Kpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (3 T)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (C)	Oil Tank Level	Oil Level OK In Aux. Oil Pump Yes / No - Add if Needed	Incoming Gas Press.	Kilowatts	Reading Taken By:	
11 PM	12M	3630	74	108	140	160	128	—	142	165	165	—	183	—	45	718	40	184	2400	a u	
12 AM	1AM	3633	76	108	140	160	128	—	142	165	165	—	187	—	45	718	40	185	2000	a u	
	2																				
	3																				
	4																				
	5																				
	6																				
	7																				
	8																				
	9																				
	10																				
	11																				
	12N																				
	1PM																				
	2																				
	3																				
	4																				
	5																				
	6																				
	7																				
	8																				
	9																				
	10																				
	11																				

General Notes: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log



Date: 9-8-22

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Air	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply Temp.	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
11 AM 12M	568	569	569	572	574	459					478			81					24	155	62	30	54	55	C.R.
12 AM 1AM	548	549	549	552	554	458					420			81					24	155	62	30	54	55	C.R.
2																									
3																									
4																									
5																									
6																									
7																									
8																									
9																									
10																									
11																									
12N																									
1PM																									
2																									
3																									
4																									
5																									
6																									
7																									
8																									
9																									
10																									
11																									

General Notes: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



Side One

Sewerage and Water Board of New Orleans



#5 Turbine Log

Date: 10/4/22

Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust(3T)	Gear Brg. No. 4 Temp	Generator Brg. Temp.(C)	Oil Tank Level	Oil Level OK In Add. Oil Pump Yes / No - Add If Needed	Incoming Gas Press.	Kilowatts	Reading Taken By:	
12M	/																				
1AM	/																				
2	/																				
3	/																				
4	/																				
5	/																				
6	/																				
7	/																				
8	/																				
9	/																				
10	/																				
11	/																				
12N	/																				
1PM	/	3600	88	110	131	149	118	/	134	162	160	/	178	/	40	1/4	Y	181	4400	E. Easterling	
2	/	3002	89	110	131	149	119	/	134	163	160	/	178	/	40	1/4	Y	182	4500	E. Easterling	
3	/	3615	84	110	137	148	122	/	140	162	162	/	180	/	42	1/4	Y	182	4400	SW	
4	/	3612	84	110	137	158	120	/	140	163	162	/	180	/	42	1/4	Yes	182	4500	C. Butler	
5	/	3614	84	110	137	158	120	/	140	163	162	/	180	/	42	1/4	Yes	182	4400	C. Butler	
6	/	3614	84	110	137	158	120	/	140	163	162	/	180	/	42	1/4	Yes	182	4400	C. Butler	
7	/	3613	79	110	137	159	120	/	141	162	162	/	180	/	42	1/4	Yes	183	4400	C. Butler	
8	/	3613	79	110	137	159	120	/	141	162	162	/	180	/	42	1/4	Yes	183	4400	C. Butler	
9	/	3615	79	110	137	159	120	/	141	162	162	/	180	/	42	1/4	Yes	183	4400	C. Butler	
10	/	3615	79	110	137	159	120	/	141	162	162	/	180	/	42	1/4	Yes	183	4400	C. Butler	
11	/	3615	76	110	137	159	120	/	140	162	160	/	180	/	42	1/4	Yes	183	4500	SW	

General Notes: Started #5 Turbine @ 12:42pm. Flame on @ 12:48pm. Up to Speed @ 1:00pm. Load @ 1:05pm.



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log



Date: 10/4/22

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft.	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg-Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right		
12M																										
1AM																										
2																										
3																										
4																										
5																										
6																										
7																										
8																										
9																										
10																										
11																										
12N																										
1PM	617	617	616	619	624	476					463			82					23 <sup>±</sup>	151	63	31	53	54	E.E.	
2	619	619	618	618	623	477					462			83					23 <sup>±</sup>	152	63	31	53	54	E.E.	
3	615	615	614	618	622	475					514			83					24	154	63	30 <sup>±</sup>	53	54	C.B.	
4	616	616	615	619	623	473					523			86					24	155	64	30 <sup>±</sup>	53	54 <sup>±</sup>	C.B.	
5	616	616	615	619	623	473					524			86					24	155	64	30 <sup>±</sup>	53	54 <sup>±</sup>	C.B.	
6	610	610	610	613	618	472					526			86					24	155	64	30 <sup>±</sup>	53	54 <sup>±</sup>	C.B.	
7	608	608	607	611	616	469					525			86					24	155	64	30 <sup>±</sup>	53	54 <sup>±</sup>	C.B.	
8	608	608	607	611	616	469					525			86					24	155	64	30 <sup>±</sup>	53	54 <sup>±</sup>	C.B.	
9	600	600	600	604	608	467					521			87					24	155	64	30 <sup>±</sup>	53	54 <sup>±</sup>	C.B.	
10	600	600	600	604	608	467					521			87					24	155	64	30 <sup>±</sup>	53	54 <sup>±</sup>	C.B.	
11	601	601	600	604	608	466					615			87					24	155	64	30	53	54	C.B.	

General Notes: Started #5 Turbine @ 12:42pm. Flame on @ 12:48pm. Up to Speed @ 1:00pm. Load @ 1:05pm.



Side One

# Sewerage and Water Board of New Orleans



## #5 Turbine Log

Date: 10.5.22

Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (3)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (G)	Oil Tank Level	Oil Level OK In P. Oil Pump Yes/No.	Oil Level OK In No. 1 Oil Pump Yes/No.	Additional	Incoming Gas Press.	Kilowatts	Reading Taken By:
12M		3600	76	110	137	159	120		140	162	160	✓	180		42	1/4	Yes		183	4500	Ng	
1AM		3600	76	110	138	160	120		140	162	160		180		42	1/4	Yes		183	4500	Ng	
2		3600	76	110	138	160	120		140	162	160		180		42	1/4	Yes		183	4500	Ng	
3		3600	76	96	138	160	120		140	162	160		180		42	1/4	Yes		183	4500	Ng	
4		3600	72	96	138	160	120		140	162	160		180		42	1/4	Yes		183	4500	Ng	
5		3600	72	96	138	160	120		140	162	160		180		42	1/4	Yes		183	4500	Ng	
6		3600	72	96	138	160	120		140	162	160		180		42	1/4	Yes		183	4500	Ng	
7		3600	76	110	138	160	120		140	162	160		180		42	1/4	Yes		183	4500	Ng	
8		3600	76	110	138	160	120		140	162	160		180		42	1/4	Yes		183	4500	Ng	
9		3600	78	110	138	160	120		140	162	160		180		42	1/4	Yes		183	4500	Ng	
10		3600	80	110	138	160	120		140	162	160		180		42	1/4	Yes		183	5100	Ng	
11		3600	80	110	138	160	120		140	162	160		180		42	1/4	Yes		183	5700	Ng	
12N		3600	80	110	138	160	120		140	162	160		180		42	1/4	Yes		183	5600	Ng	
1PM		3600	80	110	138	160	120		140	162	160		180		42	1/4	Yes		183	4100	Ng	
2		3600	80	110	138	160	120		141	162	161		180		42	1/4	Yes		183	4000	C. Butler	
3		3618	86	110	137	159	122		140	162	161		180		42	1/4	Yes		183	3900	C. Butler	
4		3618	87	110	137	159	120		140	162	161		180		42	1/4	Yes		183	4200	C. Butler	
5		3618	87	110	137	159	120		140	162	161		180		42	1/4	Yes		183	4200	C. Butler	
6		3617	88	110	137	159	120		140	162	161		180		42	1/4	Yes		183	4300	C. Butler	
7		3616	88	110	137	159	120		140	162	161		180		42	1/4	Yes		183	4700	C. Butler	
8		3616	88	110	137	159	120		140	162	161		180		42	1/4	Yes		183	4700	C. Butler	
9		3613	88	110	137	159	120		140	162	161		180		42	1/4	Yes		183	4500	C. Butler	
10		3613	88	110	137	159	120		140	162	161		180		42	1/2	Yes		183	4500		
11		3600	88	110	137	160	120		140	162	160		180		42	1/2	Yes		183	4500		

General Notes:



## Sewerage and Water Board of New Orleans #5 Turbine Log



Date: 10.5.22

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brig. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M	600	600	600	604	608	466					515			87					24	155	67	30	53	54	No
1AM	600	600	600	604	608	466					515			87					24	155	67	30	53	54	No
2	600	600	598	602	606	462					510			87					24	155	67	30	53	54	No
3	600	600	598	602	606	462					510			87					24	155	67	30	53	54	No
4	600	600	598	602	606	462					510			87					24	155	67	30	53	54	No
5	590	590	589	598	603	460					509			87					24	155	67	30	53	54	No
6	590	590	589	598	603	460					509			87					24	155	67	30	53	54	No
7	600	600	600	604	606	464					521			87					24	155	68	30	53	54	No
8	604	604	604	607	611	464					521			87					24	155	68	30	53	54	DP
9	606	606	605	608	613	467					522			87					24	155	68	30	53	54	DP
10	600	600	606	609	613	467					522			87					24	155	68	30	53	54	DP
11	608	608	606	609	614	476					521			87					24	155	68	30	53	54	DP
12N	645	645	644	647	651	478					549			87					24	155	68	30	53	54	DP
1PM	645	645	644	647	652	478					551			87					24	155	68	30	53	54	DP
2	648	648	646	650	655	480					552			87					24	155	68	30	53	54	DP
3	611	611	611	615	619	475					523			87					24	155	68	30	53	54	
4	607	607	607	611	614	476					529			87					24	155	69	30	53	54	5u
5	604	604	604	608	611	475					527			87					24	155	69	30	53	54	C.B.
6	606	607	606	610	613	474					527			87					24	155	69	30	53	54	C.B.
7	605	605	604	608	612	471					525			88					24	155	69	30	53	54	C.B.
8	605	605	604	608	612	471					525			88					24	155	69	30	53	54	C.B.
9	611	611	610	614	618	470					527			88					24	155	69	30	53	54	C.B.
10	611	611	610	614	618	470					527			88					24	155	69	30	53	54	C.B.
11	605	605	604	608	612	468					518			87					24	155	69	30	53	54	No

General Notes: \_\_\_\_\_



Side One

# Sewerage and Water Board of New Orleans

## #5 Turbine Log

Date: 10.6.22



Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp. From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (3T)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (C)	Oil Tank Level	Oil Level/Di. Above Oil Pump Yes/No - Add/Need	Incoming Gas Press.	Kilowatts	Reading Taken By:
12M	/	3600	88	110	138	160	120	/	140	162	160	/	180	/	42	1/4	Yes	183	4700	<i>[Signature]</i>
1AM	/	3600	88	110	138	160	120	/	140	162	160	/	180	/	42	1/4	Yes	183	4700	<i>[Signature]</i>
2	/	3600	88	100	138	160	120	/	140	162	160	/	180	/	42	1/4	Yes	183	4400	<i>[Signature]</i>
3	/	3600	80	100	138	160	120	/	140	162	160	/	180	/	42	1/4	Yes	183	4400	<i>[Signature]</i>
4	/	3600	74	94	138	160	120	/	140	162	160	/	180	/	42	1/4	Yes	183	4100	<i>[Signature]</i>
5	/	3600	74	94	138	160	120	/	140	162	160	/	180	/	42	1/4	Yes	183	4100	<i>[Signature]</i>
6	/	3600	74	94	138	160	120	/	140	162	160	/	180	/	42	1/4	Yes	183	4200	D. Peters
7	/	3600	74	110	138	160	120	/	140	162	160	/	180	/	42	1/4	Yes	183	3900	D. Peters
8	/	3600	76	110	138	160	120	/	140	162	160	/	180	/	42	1/4	Yes	183	4200	D. Peters
9	/	3600	79	110	138	160	120	/	140	162	160	/	180	/	42	1/4	Yes	183	4200	D. Peters
10	/	3600	79	110	138	160	120	/	140	162	160	/	180	/	42	1/4	Yes	183	4200	
11	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
12N	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
1PM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
11	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	

General Notes: #5 stopped @ 10:31am  
 Flame out @ 10:38am  
 On T.G. @ 11:00am



Side Two

Sewerage and Water Board of New Orleans  
#5 Turbine Log



Date: 10.6.22

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Fwd.	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M	605	605	604	608	612	468					518			87					24	155	68	30	53	54	DP
1AM	605	605	604	608	612	468					518			87					24	155	68	30	53	54	DP
2	600	600	602	604	610	466					506			84					24	155	68	30	53	54	DP
3	600	600	602	604	610	466					506			84					24	155	68	30	53	54	DP
4	600	600	602	604	610	466					506			84					24	155	68	30	53	54	DP
5	591	591	591	595	599	464					512			80					24	155	68	30	53	54	DP
6	591	591	591	595	599	464					512			80					24	155	68	30	53	54	DP
7	593	593	592	596	600	462					515			80					24	155	68	30	53	54	DP
8	588	588	588	592	595	464					511			80					24	155	68	30	53	54	DP
9	601	601	600	604	607	468					518			80					24	155	68	30	53	54	DP
10	601	601	601	601	608	468					519			80					24	155	68	30	53	54	DP
11																									
12N																									
1PM																									
2																									
3																									
4																									
5																									
6																									
7																									
8																									
9																									
10																									
11																									

General Notes:



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 10-29-22



Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No.1 Brg. Temp.	No.2 Brg. Temp.	No. 2 Thrust Temp.	No.3 Brg. Temp.	No.4 Brg. Temp.	Plinon Brg. No.1 Temp.	Plinon Brg. No.2 Temp.	Gear Brg. No.3 Temp.	Gear Brg. Thrust(3T)	Gear Brg. No.4 Temp.	Generator Brg. Temp.(C)	Oil Tank Level	Oil Level OK In Air. Oil Pump Yes/No. <i>ditto/checked</i>	Incoming Gas Press.	Kilowatts	Reading Taken By:	
12M	/																				
1AM	/																				
2	/																				
3	/																				
4	/																				
5	/																				
6	/																				
7	/																				
8	/																				
9	/																				
10	/																				
11	/																				
12N	/																				
1PM	/	3620	75	100	116	123	115	/	116	154	157	/	159	/	40	1/4*	Y	183	2800	E.E.J	
2	/	3621	76	105	117	124	116	/	117	154	158	/	160	/	40	1/4*	Y	184	2900	E.E.J	
3	/	3621	77	109	137	160	120	/	136	162	162	/	180	/	40	5/16	Yes	183	2000	R. Butler	
4	/	3621	77	109	137	160	120	/	136	162	162	/	180	/	40	5/16	Yes	183	2000	C. Butler	
5	/																				
6	/																				
7	/																				
8	/																				
9	/																				
10	/																				
11	/																				

Stop #5 Turbine @ 4:48 AM

General Notes: Started #5 Turbine @ 1:15pm. Flame on @ 1:18pm. Up to Speed @ 1:33pm. Load @ 1:39pm.  
 \* Oil Tank level is @ 1/4. Uncertain of which reading (gauge on Turbine/Digital reading) is the actual reading.



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log

Date: 10-29-22



Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Heater	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right		
12M																										
1AM																										
2																										
3																										
4																										
5																										
6																										
7																										
8																										
9																										
10																										
11																										
12N																										
1PM	530	529	528	531	534	454					371			76						23 <sup>5</sup>	150	61	30	53	54	EEJ
2	529	530	527	531	533	454					371			78						23 <sup>5</sup>	151	62	31	54	54	EEJ
3	550	551	551	554	556	462					479			78						23 <sup>3</sup>	155	63	30 <sup>5</sup>	53	54	C.B.
4	550	551	551	554	556	462					479			78						23 <sup>3</sup>	155	63	30 <sup>5</sup>	53	54	C.B.
5																										
6																										
7																										
8																										
9																										
10																										
11																										

General Notes: \_\_\_\_\_



Side One

## Sewerage and Water Board of New Orleans

### #5 Turbine Log



Date: 11/5/22

Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (3 T)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (C)	Oil Tank Level	Oil Level Ok In Acc. Oil Pump Yes / No - Add if needed	Incoming Gas Press.	Kilowatts				Reading Taken By:	
12M																								
1AM																								
2																								
3																								
4																								
5																								
6																								
7																								
8																								
9																								
10																								
11		3609	64	102	134	152	118	—	132	158	160	—	120	—	40	1/4	20	184	2100				a LR	
12N		3610	67	105	136	154	120	—	132	158	160	—	180	—	40	1/4	20	183	2300				a LR	
1PM		3608	70	105	138	158	120	—	132	160	160	—	180	—	40	1/4	20	185	2700				a LR	
2		3621	72	105	138	158	120	—	132	160	160	—	120	—	40	1/4	20	184	1000				a LR	
3																								
4																								
5																								
6																								
7																								
8																								
9																								
10																								
11																								

General Notes: \_\_\_\_\_



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log

Date: 11/5/22



Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filler	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right
12M																								
1AM																								
2																								
3																								
4																								
5																								
6																								
7																								
8																								
9																								
10																								
11	520	521	520	524	525	546					419								24	155	62	30	53	54
12N	537	538	538	541	543	548					461								24	155	63	30	53	55
1PM	545	550	550	553	555	452					480								24	155	63	30.5	53	55
2	505	504	510	512	514	447					465								24	155	63	30.5	53	55
3																								
4																								
5																								
6																								
7																								
8																								
9																								
10																								
11																								

General Notes: \_\_\_\_\_



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 11-14-22



Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (3T)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (C)	Oil Tank Level	Oil Level Ok In Aux. Oil Pump Yes / No - add if needed	Incoming Gas Press.	Kilowatts	Reading Taken By:	
12M	/																				
1AM	/																				
2	/																				
3	/																				
4	/																				
5	/																				
6	/																				
7	/																				
8	/																				
9	/																				
10	/																				
11	/																				
12N	/																				
1PM	/																				
2	/																				
3	/																				
4	/																				
5	/																				
6	/																				
7	/	3500	64	90	132	152	118		125	158	155		172		40	1/4	Y	184	2700	GJ	
8	/	3510	64	90	132	152	118		125	158	155		172		40	1/4	Y	184	2800	GJ	
9	/	3600	62	105	134	154	118		129	158	158		172		40	1/4	Y	184	1300	GJ	
10	/	3600	62	105	134	154	118		128	158	158		172		40	1/4	Y	184	1300	GJ	
11	/	3011	61	105	134	154	117		120	150	157		174		40	1/4	Y	184	953	E.E.	

General Notes:



Side Two

Sewerage and Water Board of New Orleans  
#5 Turbine Log

Date: 11-14-22



Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Byg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right		
12M																										
1AM																										
2																										
3																										
4																										
5																										
6																										
7																										
8																										
9																										
10																										
11																										
12N																										
1PM																										
2																										
3																										
4																										
5																										
6																										
7	529	530	529	533	535	444					429			64					23	155	60	30	53	55	GJ	
8	529	530	529	533	535	444					429			68					23	155	60	30	53	55	GJ	
9	507	507	507	510	511	439					445			66					23	153	64	31	53	54	GJ	
10	507	507	507	510	511	439					445			66					23	153	64	31	53	54	GJ	
11	499	500	500	502	504	438					440			60					23	151	62	31	52	54	E.E.	

General Notes:



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 11-15-22



Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (3T)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (G)	Oil Tank Level	Oil Level OK In Aux. Oil Pump Yes / No - Add If Needed	Incoming Gas Press.	Kilowatts				Reading Taken By:	
12M	/	3605	04	105	134	150	110	/	132	157	158	/	174	/	40	1/4	Y	184	2400				E.E.	
1AM	/	3005	05	105	135	150	117	/	132	158	159	/	174	/	40	1/4	Y	184	2900				E.E.	
2	/	3006	05	105	135	150	117	/	133	157	158	/	173	/	40	1/4	Y	184	2800				E.E.	
3	/	3005	04	105	135	155	110	/	133	158	158	/	174	/	40	1/4	Y	184	2900				E.E.	
4	/							/				/		/										
5	/							/				/		/										
6	/							/				/		/										
7	/							/				/		/										
8	/							/				/		/										
9	/							/				/		/										
10	/							/				/		/										
11	/							/				/		/										
12N	/							/				/		/										
1PM	/							/				/		/										
2	/							/				/		/										
3	/							/				/		/										
4	/							/				/		/										
5	/							/				/		/										
6	/							/				/		/										
7	/							/				/		/										
8	/							/				/		/										
9	/							/				/		/										
10	/							/				/		/										
11	/							/				/		/										

General Notes: Stopped #5 Turbine @ 3:58 am. Flame out @ 4:03 am. # 5 Turbine on T.G. @ 4:19 am.



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log



Date: 11-15-22

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft.	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brig. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M	532	533	533	530	537	446	/	/	/	/	406	/	/	66	/	/	/	/	23	150	55	30	53 <sup>L</sup>	56	E.E.
1AM	532	532	533	535	537	447	/	/	/	/	406	/	/	66	/	/	/	/	23 <sup>L</sup>	151	56	31	53 <sup>L</sup>	56	E.E.
2	530	533	532	535	537	446	/	/	/	/	405	/	/	67	/	/	/	/	23	150	56	31	54	56	E.E.
3	531	532	533	535	536	445	/	/	/	/	406	/	/	66	/	/	/	/	23	151	55	31	54	55	E.E.
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
11	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
12N	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
1PM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
11	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/

General Notes: \_\_\_\_\_



Side One

# Sewerage and Water Board of New Orleans



## #5 Turbine Log

Date: 11-25-22

Time	Rpm	Speed / Rpm	Ambient Temp.	Oil Temp. From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (T)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (C)	Oil Tank Level	Oil Level (H) in Aux. Oil Pump No. 1	Oil Level (H) in Aux. Oil Pump No. 2	Increasing Gas Press.	Kilowatts	Reading Taken By:
12M		3600	70	90	132	152	118		130	160	162	174	40	40	40	1/4	Yes	183	1560	Aa	
1AM		3600	70	105	132	152	118		130	155	160	174	40	40	40	1/4	Y	183	1500	GJ	
2		3600	70	105	132	152	118		130	160	160	174	40	40	40	1/4	Y	183	1200	GJ	
3		3600	70	105	132	152	118		130	160	160	174	40	40	40	1/4	Y	183	1200	GJ	
4		3600	71	105	132	152	118		130	160	160	174	40	40	40	1/4	Y	183	2200	GJ	
5		3600	72	106	134	153	118		130	155	160	174	40	40	40	1/4	Y	183	2300	GJ	
6		3600	72	106	134	153	118		130	155	160	174	40	40	40	1/4	Y	183	2300		
7		@ 7:15 AM Stopped																			
8																					
9																					
10																					
11																					
12N																					
1PM																					
2																					
3																					
4																					
5																					
6																					
7																					
8																					
9																					
10																					
11																					

General Notes:



Side Two

Sewerage and Water Board of New Orleans  
#5 Turbine Log



Date: 11-28-22

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Big. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right		
12M	523	524	528	526	528	449					431			78					23	152	60	32	54	55	GJ	
1AM	523	523	523	526	528	447					436			78					23	152	60	32	54	55	GJ	
2	523	523	523	526	528	447					436			78					23	152	60	32	54	55	GJ	
3	521	521	521	555	527	446					437			76					23	152	60	32	54	55	GJ	
4	523	523	523	537	530	445					438			73					23	152	60	32	54	55	GJ	
5	526	526	526	558	532	447					441			78					23	152	60	32	54	55	GJ	
6	527	527	526	559	532	447					446			78					23	152	60	32	54	55	GJ	
7	@ 7:15 AM						Stopped																			
8																										
9																										
10																										
11																										
12N																										
1PM																										
2																										
3																										
4																										
5																										
6																										
7																										
8																										
9																										
10																										
11																										

General Notes: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



Side One

# Sewerage and Water Board of New Orleans

## #5 Turbine Log

Date: 11-20-22



Time	Rur. Hours	Speed / RPM	Ambient Temp.	Oil Temp. From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Piston Brg. No. 1 Temp.	Piston Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (G)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (C)	Oil Tank Level	Oil Level Ok. In Adv. Oil Pump Yes / No - Add If Needed	Incoming Gas Press.	Kilowatts	Reading Taken By:	
12M	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
1AM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
11	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
12N	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
1PM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	40	14	4	183	3200	E. Easterling, Jr.
3	/	3594	02	100	116	132	114	/	116	154	152	/	156	/	40	14	4	183	1750	E. Easterling, Jr.	
4	/	3604	02	105	118	134	116	/	118	156	154	/	154	/	40	14	4	183	1887	E. Easterling, Jr.	
5	/	3606	03	108	120	134	118	/	119	150	154	/	155	/	40	14	4	183	1670	E. Easterling, Jr.	
6	/	3602	02	106	119	134	118	/	119	155	155	/	156	/	/	/	/	/	/	/	
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
11	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	

General Notes:

\_\_\_\_\_

\_\_\_\_\_



Side Two

# Sewerage and Water Board of New Orleans

## #5 Turbine Log



Date: 11-20-22

Time	Point No. 1 Exhaust Temp	Point No. 2 Exhaust Temp	Point No. 4 Exhaust Temp	Point No. 5 Exhaust Temp	Point No. 6 Exhaust Temp	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Fwd.	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filler	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M																									
1AM																									
2																									
3																									
4																									
5																									
6																									
7																									
8																									
9																									
10																									
11																									
12N																									
1PM																									
2																									
3	505	505	503	508	571	454	/	/	/	/	421	/	/	08	/	/	/	/	23 <sup>s</sup>	151	02	31	52	55	E.E.
4	504	503	502	507	509	452	/	/	/	/	423	/	/	09	/	/	/	/	23 <sup>s</sup>	152	02	32	52	55	E.E.
5	504	504	502	500	508	453	/	/	/	/	422	/	/	08	/	/	/	/	24	151	01	31	52	54	E.E.
6	504	504	503	505	507	452	/	/	/	/	424	/	/	08	/	/	/	/	23 <sup>s</sup>	151	01	31	53	54	E.E.
7							/	/	/	/	/	/	/	/	/	/	/	/							
8							/	/	/	/	/	/	/	/	/	/	/	/							
9							/	/	/	/	/	/	/	/	/	/	/	/							
10							/	/	/	/	/	/	/	/	/	/	/	/							
11							/	/	/	/	/	/	/	/	/	/	/	/							

General Notes: Started #5 Turbine @ 2:11pm. Flame on @ 2:15pm. Up to Speed @ 2:29pm. Load @ 2:32pm. Broke Field @ 0:32pm. Stopped #5 Turbine @ 0:33pm. Flame out @ 0:30pm. T.G. @ 0:53pm.



Side One

## Sewerage and Water Board of New Orleans

### #5 Turbine Log



Date: 12/11/22

Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust(3 T)	Gear Brg. No. 4 Temp	Generator Brg. Temp.(C)	Oil Tank Level	Oil Level Ok In All Oil Pump We / No. Add If Needed	Incoming Gas Press.	Kilowatts				Reading Taken By:
12M																							
1AM																							
2																							
3																							
4																							
5																							
6																							
7																							
8																							
9																							
10																							
11		3642	70	102	126	142	110	—	118	155	156	—	168	—	40	1/4	40	184	1200				a b
12N		3671	72	102	128	142	118	—	118	158	158	—	170	—	40	1/4	40	184	1200				a b
1PM		3635	72	105	130	144	120	—	170	160	158	—	170	—	40	1/2	2	184	1700				a b
2																							
3																							
4																							
5																							
6																							
7																							
8																							
9																							
10																							
11																							

General Notes: \_\_\_\_\_



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log

Date: 12/11/22



Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M																									
1AM																									
2																									
3																									
4																									
5																									
6																									
7																									
8																									
9																									
10		Started	10:25 A	flame on	10:31 A																				
11	555	556	559	558	562	454					399								23	155	65	31	53	55	
12N	558	558	556	560	564	458					402								23	155	65	31	53	55	
1PM	557	557	556	561	563	457					404								23	155	65	31	53	55	
2			Stopped	1:28 P	flame out	1:41 P																			
3																									
4																									
5																									
6																									
7																									
8																									
9																									
10																									
11																									

General Notes:



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 12-14-22



Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (3T)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (C)	Oil Tank Level	Oil Level Ok In Aux. Oil Pump Yes / No. Add If Needed	Incoming Gas Press.	Kilowatts					Reading Taken By:	
12M	/																								
1AM	/																								
2	/																								
3	/																								
4	/																								
5	/																								
6	/																								
7	/																								
8	/																								
9	/	3608	78	101	117	131	112	/	118	153	156	/	162	/	40	1/4	Y	183	1202					E. Easterling	
10	/	3607	80	102	117	132	118	/	120	154	156	/	162	/	40	1/4	Y	184	1500					E. Easterling	
11	/	3608	81	103	119	134	120	/	122	154	157	/	163	/	40	1/4	Y	183	6100					E. Easterling	
12N	/	3606	83	103	122	130	122	/	124	156	158	/	164	/	40	1/4	Y	184	5900					E. Easterling	
1PM	/	3605	83	103	122	136	122	/	124	156	158	/	164	/	40	1/4	Y	184	5200					E. Easterling	
2	/	3616	83	105	122	136	122	/	124	156	158	/	164	/	40	1/4	Y	184	2500					D. Peters	
3	/	3611	79	105	136	138	119	/	140	160	165	/	180	/	40	1/4	Y	185	1600					SM	
4	/	3608	79	105	134	158	120	/	141	161	165	/	182	/	40	1/4	Y	183	1700					SM	
5	/	3596	72	110	126	156	120	/	141	161	165	/	182	/	40	1/4	Y	183	10000					SM	
6	/	3615	70	110	126	156	120	/	141	160	165	/	180	/	40	1/4	Y	183	4300					SM	
7	/	3655	69	110	138	156	118	/	140	160	165	/	180	/	40	1/4	Y	185	2900					SM	
8	/	3645	69	110	128	156	118	/	140	159	163	/	180	/	40	1/4	Y	184	1700					SM	
9	/	3650	68	110	128	156	118	/	140	159	163	/	180	/	40	1/4	Y	183	1200					SM	
10	/	3650	66	110	138	156	118	/	141	156	163	/	180	/	40	1/4	Y	183	1200					SM	
11	/																								

General Notes: Started #5 Turbine @ 8:29am. Flame on @ 8:36am. Up to Speed @ 8:50am. Load @ 8:54am.



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log

Date: 12-14-22



Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel - Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right		
12M																										
1AM																										
2																										
3																										
4																										
5																										
6																										
7																										
8																										
9	526	527	527	529	531	455					383			74					23 <sup>5</sup>	151	57	31	53	54	E.E.	
10	525	526	527	529	532	458					389			76					23	152	56	31	53	54	E.E.	
11	526	527	528	530	531	406					400			78					23 <sup>2</sup>	152	56	31	53	55	E.E.	
12N	525	526	527	529	530	405					402			80					23 <sup>5</sup>	152	56	32	54	56	E.E.	
1PM	630	629	628	632	637	472					533			78					23 <sup>5</sup>	152	56	32	54	56	E.E.	
2	550	551	553	550	549	458					498			78					23 <sup>5</sup>	152	56	32	54	56	OP	
3	544	545	545	547	549	460					483			80					24	155	60	32	53	54	SW	
4	525	525	525	538	540	453					475			80					24	155	60	32	54	55	SW	
5	758	759	758	761	767	481					615			80					24	155	60	32	54	55	SW	
6	589	588	586	589	592	457					520			80					24	155	60	32	54	54	SW	
7	545	546	546	549	551	455					496			80					24	155	60	32	54	54	SW	
8	517	519	519	521	523	449					473			80					24	155	60	32	54	54	SW	
9	506	506	507	509	511	446					462			81					24	155	60	32	54	54	SW	
10	505	505	506	508	510	444					459			81					24	155	60	32	54	54	SW	
11						stopped					10:20															

General Notes:







Side Two

# Sewerage and Water Board of New Orleans

## #5 Turbine Log



Date: \_\_\_\_\_

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Fwd.	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brig. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right		
12M																										
1AM																										
2																										
3																										
4																										
5																										
6																										
7																										
8																										
9																										
10																										
11																										
12N																										
1PM																										
2																										
3																										
4																										
5																										
6																										
7	542	542	541	544	548	438		434			439			55						23 <sup>2</sup>	155	66	31	53	54	see
8	555	555	554	558	562	437		<del>434</del>			463			55						23 <sup>2</sup>	155	66	31	53	54	see
9	557	551	551	555	559	438		425			475			55						23 <sup>2</sup>	155	66	31	53	54	see
10	601	601	600	604	609	445					510			57						23 <sup>2</sup>	155	66	31	53	54	see
11	505	506	507	510	511	485					483			55						23 <sup>2</sup>	155	66	31	53	54	see

General Notes: \_\_\_\_\_



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 12-20-22



Time	Run Hours	Speed/Rpm	Ambient Temp.	Oil Temp. Front Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Fusion Brg. No. 1 Temp.	Fusion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (31)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (C)	Oil Pan Level	Oil Level OK In Ass. Oil Pump Yes/No. AMPLINAGE	Incoming Gas Press.	Kilowatts	Reading Taken By:
12M		3600	64	107	134	154	116		130	160	156	Ø	180		40	1/4	Yes	185	1600	Ho
1AM		3600	64	107	134	154	116		130	160	156	Ø	180		40	1/4	Yes	185	1600	Ho
2																				
3																				
4																				
5																				
6																				
7																				
8																				
9																				
10																				
11																				
12N																				
1PM																				
2																				
3																				
4																				
5																				
6																				
7																				
8																				
9																				
10																				
11																				

General Notes:



Side Two

Sewerage and Water Board of New Orleans  
#5 Turbine Log



Date:

Time	Point No. 1 Exhaust Temp	Point No. 2 Exhaust Temp	Point No. 4 Exhaust Temp	Point No. 5 Exhaust Temp	Point No. 6 Exhaust Temp	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M	500	500	502	508	510	482					483			55					23	155	166	31	SS	SS	
1AM	500	500	502	508	510	485					483			55					23	155	166	31	SS	SS	
2																									
3																									
4																									
5																									
6																									
7																									
8																									
9																									
10																									
11																									
12N																									
1PM																									
2																									
3																									
4																									
5																									
6																									
7																									
8																									
9																									
10																									
11																									

General Notes: @ 1:31am stopped #5 turbine.



Side One

# Sewerage and Water Board of New Orleans



## #5 Turbine Log

Date: 12-20-27

Time	Run Hours	Speed/Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Finion Brg. No. 1 Temp.	Finion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (T)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (C)	Oil Tank Level	Oil Level Or. In case Oil Pump Yes/No Add. Number	Incoming Gas Press.	Kilowatts	Reading Taken By:
12M	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
1AM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	su
7	/	/	/	Start	7:55	/	/	/	/	Flame	8:05	/	/	/	/	/	Speed	184	115	su
8	/	/	/	/	/	/	/	/	/	133	161	157	180	/	40	7/16	183	1800	su	
9	/	3612	62	110	136	153	114	/	/	133	162	158	180	/	40	7/16	184	3800	su	
10	/	3587	62	110	136	153	114	/	/	134	164	160	180	/	40	7/16	183	5600	su	
11	/	3399	63	110	136	155	120	/	/	136	164	160	180	/	40	7/16	183	9200	su	
12N	/	3585	64	110	137	157	125	/	/	136	165	160	180	/	40	7/16	184	3800	su	
1PM	/	3622	64	110	137	160	130	/	/	132	158	162	180	/	40	7/16	184	4700	su	
2	/	3655	67	110	137	156	118	/	/	132	158	160	180	/	40	7/16	su	129	1200	su
3	/	3658	68	108	136	156	118	/	/	Flame at	7:54	/	1	/	/	T.G.	e 402 P	/	/	su
4	/	/	/	Stopped	e 7:48 P	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
11	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/

General Notes: Start 7:55 Flame 8:05 Speed 8:15



Side Two

Sewerage and Water Board of New Orleans  
#5 Turbine Log



Date: 12.20.22

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right		
12M																										
1AM																										
2																										
3																										
4																										
5																										
6																										
7			Start	7:55																						
8								Flame	8:05																see	
9	554	554	554	560	563	442					524									Speed	8:15				see	
10	662	662	662	667	671	458					540									23	148	69	30 <sup>E</sup>	53	54	see
11	621	621	622	626	629	451					535									23	149	68	30 <sup>E</sup>	53	54	see
12N	637	637	637	642	647	460					549									23	150	67	30 <sup>E</sup>	53	54	see
1PM	575	576	575	579	583	455					508									23	150	67	30 <sup>E</sup>	53	54	see
2	525	526	527	530	531	450					479									23	150	67	30 <sup>E</sup>	53	54	see
3	513	514	514	517	518	448					464									23	150	67	20 <sup>E</sup>	53	54	c.d.
4																										
5																										
6																										
7																										
8																										
9																										
10																										
11																										

General Notes: Start 7:55 Flame 8:05 Speed 8:15



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 1/4/23



Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (31)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (C)	Oil Tank Level	Oil Level Ok In Aux. Oil Pump Yes / No - Add if Needed	Incoming Gas Press.	Kilowatts	Reading Taken By:		
12M																						
1AM			Stat	e 1.3 8am			Flare on e	1:41am														
2	/	3624	63	108	122	140	110	-	120	156	158	-	170	-	40	1/2	yes	185	4400	a LR		
3		3624	83	105	126	152	120	-	130	158	160	-	180	-	40	1/2	Y	183	2200	GJ		
4							stopped	#	5 turbines @ 3:45 AM										Flare at e	3:57A		GJ
5																						
6																						
7																						
8																						
9																						
10																						
11																						
12N																						
1PM																						
2																						
3																						
4																						
5																						
6																						
7																						
8																						
9																						
10																						
11																						

General Notes: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log



Date: 1/4/23

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel- All Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Drg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right
12M																							
1AM																							
2	522	568	566	562	577	447					383							24	155	65	31	52.5	55
3	527	538	529	532	534	447					445							24	153	65	31	53	55
4																							
5																							
6																							
7																							
8																							
9																							
10																							
11																							
12N																							
1PM																							
2																							
3																							
4																							
5																							
6																							
7																							
8																							
9																							
10																							
11																							

General Notes: stopped # 5 turbine @ 3:45 pm

GJ  
GJ



Side One

# Sewerage and Water Board of New Orleans

## #5 Turbine Log

Date: 1-17-23



Time	Run Hours	Speed / RPM	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Finion Brg. No. 1 Temp.	Finion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (T)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (G)	Oil Tank Level	Oil Level Oil In Aux. Oil Pump Yes / No - Add / Deduct	Incoming Gas Press.	Kilowatts	Reading Taken By:
12M	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
1AM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
10	/	3600	80	90	136	154	112	/	138	160	158	Q	180	/	40	1/2	Yes	182	568	/
11	/	3600	80	92	136	154	112	/	138	160	158	Q	180	/	40	1/2	Yes	182	1000	/
12N	/	3600	80	92	136	154	112	/	138	160	158	Q	180	/	40	1/2	Yes	182	3400	/
1PM	/	3600	84	96	136	154	112	/	138	160	158	Q	180	/	40	1/2	Yes	182	3000	/
2	/	8600	90	96	136	154	112	/	138	160	158	Q	180	/	40	1/2	Yes	182	3000	/
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
11	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/

General Notes: \_\_\_\_\_



Side Two

Sewerage and Water Board of New Orleans  
#5 Turbine Log



Date: 1-17-23

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right
12M																								
1AM																								
2																								
3																								
4																								
5																								
6																								
7																								
8																								
9																								
10	583	583	583	587	589	466																		
11	583	583	583	587	589	466																		
12N	580	581	581	589	586	465																		
1PM	582	582	581	585	587	468																		
2	583	583	582	586	588	470																		
3																								
4																								
5																								
6																								
7																								
8																								
9																								
10																								
11																								

@ 9:23 Started  
 @ 9:42 Am UP to speed  
 @ 9:48 Load.

10 586 84 22 155 60 31 53 54  
 11 486 84 22 155 60 31 53 54  
 12N 491 84 22 155 60 31 53 54  
 1PM 500 84 22 155 60 31 53 54  
 2 500 84 22 155 60 31 53 54

General Notes:



Side One

Sewerage and Water Board of New Orleans



#5 Turbine Log

Date: 1-19-25

Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp	Filcon. Brg. No. 1 Temp.	Piston Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (T)	Gear Brg. No. 4 Temp	Generator Brg. Temp. (G)	Oil Tank Level	Oil Level Oil to A.M.K. Oil Pump Yes / No. Add. Oil Needed	Incoming Gas Press.	Kilowatts	Reading Taken By.	
12M																					
1AM																					
2																					
3																					
4																					
5																					
6																					
7																					
8		3600	59	90	136	158	124		132	159	155	Ø	178		40	1/2	Yes	183	3900	No	
9		3600	59	90	136	158	124		132	159	155	Ø	178		40	1/2	Yes	183	4100	No	
10		3600	62	92	136	158	124		132	159	155	Ø	178		40	1/2	Yes	182	4000	No	
11		3600	76	92	136	158	124		132	159	155	Ø	178		40	1/2	Yes	182	3900	No	
12N		3600	76	92	136	158	124		132	159	155	Ø	178		40	1/2	Yes	182	3900	No	
1PM		3600	78	90	136	158	124		132	159	155	Ø	178		40	1/2	Yes	182	4100	No	
2		3600	78	90	136	158	124		132	159	155	Ø	178		40	1/2	Yes	182	4100	No	
3																					
4																					
5																					
6																					
7																					
8																					
9																					
10																					
11																					

Start @ 6:50 AM Flare @ 6:57 AM UP to speed 7:08 AM

@ load off 2:33pm Stopped @ 2:39 pm T.G @ 2:59 PM

No  
No  
No  
No  
No  
No

General Notes:



Side Two

Sewerage and Water Board of New Orleans  
#5 Turbine Log



Date: 1-19-20

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brig. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right		
12M																										
1AM																										
2																										
3																										
4																										
5																										
6																										
7																										
8	567	567	567	570	574	499	/	/	/	/	470	/	/	70	/	/	/	/	23	152	65	82	54	55	No	
9	567	567	567	570	574	499	/	/	/	/	470	/	/	70	/	/	/	/	23	152	65	52	54	55	No	
10	585	585	585	588	592	460	/	/	/	/	499	/	/	72	/	/	/	/	23	152	65	52	54	55	No	
11	586	586	585	589	593	463	/	/	/	/	508	/	/	74	/	/	/	/	23	184	65	52	54	55	No	
12N	586	586	585	589	593	463	/	/	/	/	508	/	/	76	/	/	/	/	23	134	65	52	54	55	No	
1PM	588	588	588	592	595	464	/	/	/	/	509	/	/	76	/	/	/	/	23	134	65	52	54	55	No	
2	592	592	591	595	599	464	/	/	/	/	509	/	/	78	/	/	/	/	23	134	65	52	54	55	No	
3																										
4																										
5																										
6																										
7																										
8																										
9																										
10																										
11																										

General Notes:



Side One

# Sewerage and Water Board of New Orleans



## #5 Turbine Log

Date: 1-20-23

Time	Ran Hours	Speed RPM	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (31)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (3)	Oil Tank Level	Oil Level (4) in Oil Pump See Oil diff. Level	Baromet. Gas Press.	Kilowatts	Reading Taken By:	
12M	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
1AM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
9		@ 9:12 Am Started			@ 9:28 Am		UP	to speed		@ 9:34 load.											
10		3600	64	85	132	152	120	124	154	156	180	180	180	180	40	1/2	Yes	184	526	No Hay /	
11		3600	64	85	132	152	120	124	154	156	180	180	180	40	1/2	Yes	184	469			
12N		3600	68	90	132	152	120	124	156	158	182	182	182	40	1/2	Yes	184	5186			
1PM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		
11	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/		

General Notes: \_\_\_\_\_



Side Two

Sewerage and Water Board of New Orleans  
#5 Turbine Log



Date: 1.20.23

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Air	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M																									
1AM																									
2																									
3																									
4																									
5																									
6																									
7																									
8																									
9																									
10	180	181	181	183	185	117						752		68					22	195	55	32	54	55	No
11	180	181	181	183	185	117						152		68					22	195	55	32	54	55	No
12N	182	182	182	184	186	116						455		70					22	195	55	32	54	55	No
1PM	@ 12:54 load off								@ 1:00	stopped					@ 1:25	on T.G.									
2																									
3																									
4																									
5																									
6																									
7																									
8																									
9																									
10																									
11																									

General Notes:



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 11/24/23



Time	Run Hours	Speed / RPM	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (T)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (G)	Oil-Pink Level	Oil Level Oil In case. Oil Pump Yes / No. Add / Subtract	Incoming Gas Press.	MIHOURS	Reading Taken By:
12M	/	/	7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
1AM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
11	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
12N	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
1PM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
11	/	3600	72	100	124	135	115	/	130	155	158	180	/	35	42	Yes	183	933	/	D Petras

General Notes:  
 @ 9:45pm #5 started  
 @ ~~9:50p~~ 9:52p Flame  
 @ 10:05p up to speed  
 @ 10:20p Loaded.



Side Two

Sewerage and Water Board of New Orleans  
#5 Turbine Log



Date: 1/24/23

Time	Point No. 1 Exhaust Temp	Point No. 2 Exhaust Temp	Point No. 4 Exhaust Temp	Point No. 5 Exhaust Temp	Point No. 6 Exhaust Temp	Point No. 8 Comp. Disch. Temp	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Air	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right
12M																								
1AM																								
2																								
3																								
4																								
5																								
6																								
7																								
8																								
9																								
10																								
11																								
12N																								
1PM																								
2																								
3																								
4																								
5																								
6																								
7																								
8																								
9																								
10																								
11	510	511	510	513	515	450					38.1			66					23.2	150	60	30.2	53.2	54

General Notes:



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 1/25/23



Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg Temp	No. 2 Brg Temp	No. 2 Thrust Temp	No. 3 Brg Temp	No. 4 Brg Temp	Filum Brg No. 1 Temp	Phion Brg No. 2 Temp	Gear Brg No. 3 Temp	Gear Brg Thrust(21)	Gear Brg No. 4 Temp	Generator Brg Temp (C)	Oil Tank Level	Oil Level Oil In case Oil Pump Yes / No - Add if needed	Incoming Gas Press.	Kilowatts	Reading Taken By:
12M		3600	72	106	124	135	115		130	155	158		180		35	1/2	Yes	183	250	J.P. Torres
1AM																				
2																				
3																				
4																				
5																				
6																				
7																				
8																				
9																				
10																				
11																				
12N																				
1PM																				
2																				
3																				
4																				
5																				
6																				
7																				
8																				
9																				
10																				
11																				

General Notes: @ 12:50am #5 stopped  
 @ 12:53am Flame out  
 @ 1: out-G.



Side Two

# Sewerage and Water Board of New Orleans

## #5 Turbine Log



Date: 1/25/23

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Fwd.	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right
12M	539	539	539	542	544	427	/	/	/	/	52	/	/	66	/	/	/	/	235	180	60	305	530	54
1AM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
11	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
12N	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
1PM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
11	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/

General Notes:

---



---



---



Side One

# Sewerage and Water Board of New Orleans



## #5 Turbine Log

Date: 2-1-23

Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (31)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (G)	Oil Tank Level	Oil Level Oil In Case Oil Pump No. 1/2 in. Add if needed	Incoming Gas Press.	Kilowatts	Reading Taken By:
12M	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
1AM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
9													160		40°C	1/2	4	184	0	E. Easterling
10		3600	57	105	120	131	116		130	151	152		100		40°C	1/2	4	184	0	E. Easterling
11		3600	58	106	120	132	116		130	151	152		180		40°C	1/2	4	184	0	E. Easterling
12N		3600	57	110	122	140	112		125	150	150									
1PM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
11	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	

General Notes: started #5 Turbine @ 9:25 am. Flame on @ 9:34 am. Up to Speed @ 9:41 am. \* Test run for #5 Turbine to see where and or how many gas leaks they have on the Turbine. \* Stopped #5 Turbine @ 11:00 am. Flame out @ 11:11 am. T.G. @ 11:20 am. Started #5 Turbine @ 11:35 am. Flame on @ 11:40 am. Up to Speed @ 11:55 am. Stopped #5 Turbine @ 12:11 pm. Flame out @ 12:15 pm. T.G. @ 12:38 pm



Side Two

Sewerage and Water Board of New Orleans  
#5 Turbine Log



Date: 2-1-23

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-At	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M																									
1AM																									
2																									
3																									
4																									
5																									
6																									
7																									
8																									
9																									
10	459	459	459	402	404	420					343			58					23 <sup>2</sup>	151	62	52	31	54	E.E.
11	459	400	400	403	404	420					344			58					23 <sup>5</sup>	152	62	52	32	54	E.E.
12N	403	404	405	407	408	424					395			60					23 <sup>2</sup>	152	62	31	52	54	E.E.
1PM																									
2																									
3																									
4																									
5																									
6																									
7																									
8																									
9																									
10																									
11																									

General Notes:



Side One

# Sewerage and Water Board of New Orleans

## #5 Turbine Log

Date: 2-3-23



Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Flion Brg. No. 1 Temp.	Flion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (T)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (C)	Oil Tank Level	Oil Level Oil In or Oil Pump Yes/No. Add/Reduce	Incoming Gas Press	Kilowatts	Reading Taken By:
12M	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
1AM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
9	/	3600	52	105	119	130	114	/	110	150	149	/	180	/	40°C	1/2	4	184	0	E. Easterling
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
11	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
12N	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
1PM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
11	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	

General Notes: Started #5 Turbine @ 8:39 am. Flame on @ 8:44 am. Up to Speed @ 8:50 am. Stopped #5 Turbine @ 9:34 am  
 Flame out @ 9:38 am. T.G. @ 9:54 am.



Side Two

Sewerage and Water Board of New Orleans  
#5 Turbine Log



Date: 2-3-23

Time	Point No. 1 Exhaust Temp	Point No. 2 Exhaust Temp	Point No. 4 Exhaust Temp	Point No. 5 Exhaust Temp	Point No. 6 Exhaust Temp	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M																									
1AM																									
2																									
3																									
4																									
5																									
6																									
7																									
8																									
9	451	452	451	453	456	421					343			54					23 <sup>5</sup>	151	63	31	52	55	E.E.
10																									
11																									
12N																									
1PM																									
2																									
3																									
4																									
5																									
6																									
7																									
8																									
9																									
10																									
11																									
General Notes:																									



Side One

# Sewerage and Water Board of New Orleans

## #5 Turbine Log

Date: 2-8-23



Time	Run Hours	Speed - Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (T)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (C)	Oil Tank Level	Oil Level Oil In Pump No. 1/No. 2/No. 3/No. 4/If Needed	Incoming Gas Press.	Kilowatts	Reading Taken By:	
12M	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
1AM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
11	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
12N	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
1PM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
10	/	3608	73	110	114	124	112	/	110	145	155	/	180	/	40°	1/2	4	175	1063	E. Eustering	
11	/	3500	70	90	134	130	116	/	132	155	156	/	172	/	40	1/2	Yes	774	6700	<i>[Signature]</i>	

General Notes: Started #5 Turbine @ 9:28pm. Flame on @ 9:34pm. Up to Speed @ 9:45pm.



Side Two

Sewerage and Water Board of New Orleans  
#5 Turbine Log



Date: 2-8-23

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Alt	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brig. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right		
12M																										
1AM																										
2																										
3																										
4																										
5																										
6																										
7																										
8																										
9																										
10																										
11																										
12N																										
1PM																										
2																										
3																										
4																										
5																										
6																										
7																										
8																										
9																										
10	513	513	512	515	518	450					357			70					24	151	50	31	52	54	E.E.	
11	669	669	667	672	678	461					526			72					29	152	65	31	53	55	th	

General Notes:



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 2.9.23



Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (3T)	Gear Brg. No. 4 Temp	Generator Brg. Temp. (C)	Oil Tank Level	Oil Level OK In Air. Oil Pump Yes / No. Add / Needed	Incoming Gas Press.	Kilowatts	Reading Taken By:
12M	/	3500	70	90	134	130	116	/	132	155	156	/	172	/	40	1/2	Yes	174	6700	Ma
1AM	/	3600	70	90	134	130	116	/	132	155	156	/	172	/	40	1/2	Yes	174	1200	Ma
2	/	3600	70	90	134	130	116	/	132	155	156	/	172	/	40	1/2	Yes	174	1200	Ma
3	/	3600	72	90	134	130	116	/	132	155	156	/	172	/	40	1/2	Yes	174	1200	Ma
4	/	3600	72	90	134	130	116	/	132	155	156	/	172	/	40	1/2	Yes	174	1100	Ma
5	/	3600	64	90	134	130	116	/	132	158	160	/	172	/	46	1/2	Yes	174	1200	Ma
6	/	3600	64	90	134	131	116	/	132	158	160	/	172	/	40	1/2	Yes	174	1200	Ma
7	/	3602	62	92	134	130	110	/	132	158	100	/	172	/	40°C	1/2	Y	175	1100	E.E.
8	/	3603	63	92	133	128	110	/	132	157	100	/	172	/	40°C	1/2	Y	175	1000	E.E.
9	/																			
10	/																			
11	/																			
12N	/																			
1PM	/																			
2	/																			
3	/																			
4	/																			
5	/																			
6	/																			
7	/																			
8	/																			
9	/																			
10	/																			
11	/																			

General Notes: @ 7:10am, Central Control broke field on #5 Turbine. Stopped #5 Turbine @ 8:05 am. Flame out @ 8:10 am. T.G. @ 8:28 am.



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log

Date: 2.9.23



Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Ditch Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filler	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M	669	669	667	672	678	416					526			72					24	150	65	31	53	55	No
1AM	538	538	540	542	543	417					478			72					24	150	65	31	53	55	No
2	533	533	534	537	538	449					473			72					24	150	65	31	53	55	No
3	530	530	532	536	539	442					480			72					24	150	65	31	53	55	No
4	525	526	526	529	531	446					464			72					24	150	65	31	53	55	No
5	521	521	522	525	526	442					462			72					24	150	65	31	53	55	No
6	521	521	522	525	526	442					462			72					24	150	65	31	53	55	No
7	521	520	522	525	526	442					402			72					24	150	64	31	53	55	E.E.
8	520	520	521	524	525	440					402			72					24	150	64	31	53	54	E.E.
9																									
10																									
11																									
12N																									
IPM																									
2																									
3																									
4																									
5																									
6																									
7																									
8																									
9																									
10																									
11																									

General Notes: \_\_\_\_\_



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 2.13.23



Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No.1 Brg. Temp	No.2 Brg. Temp.	No.2 Thrust Temp.	No.3 Brg. Temp.	No.4 Brg. Temp.	Pinion Brg. No.1 Temp.	Pinion Brg. No.2 Temp.	Gear Brg. No.3 Temp.	Gear Brg. Thrust(3T)	Gear Brg. No.4 Temp	Generator Brg. Temp.(C)	Oil Tank Level	Oil Level Ok In Aux. Oil Pump Yes / No - Add/L/Drain/Get	Incoming Gas Press.	Kilowatts	Reading Taken By:		
12M	/																					
1AM	/																					
2	/																					
3	/																					
4	/																					
5	/																					
6	/																					
7	/																					
8	/																					
9	/																					
10	/																					
11	/																					
12N	/	3600	72	82	134	152	120	/	136	150	156	/	174	/	40	1/2	Yes	175	3900	No [Signature]		
1PM	/	3600	72	82	139	152	120	/	136	150	156	/	174	/	40	1/2	Yes	175	3900			
2	/	3600	72	82	134	152	120	/	136	150	156	/	174	/	40	1/2	Yes	175	3900			
3	/	3600	72	82	139	152	120	/	136	150	156	/	174	/	40	1/2	Yes	175	4200			
4	/	3600	72	88	139	152	120	/	136	150	156	/	174	/	40	1/2	Yes	175	4200			
5	/				Stopped		@		4:55P													
6	/																					
7	/																					
8	/																					
9	/																					
10	/																					
11	/																					

General Notes:



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log

Date: 2-13-23



Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Alt.	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M																									
1AM																									
2																									
3																									
4																									
5																									
6																									
7																									
8																									
9																									
10																									
11																									
12N	589	589	589	598	597	456					486			68					23	150	55	31	54	55	Key
											500			68					23	150	55	31	54	55	Key
1PM	598	598	597	601	605	457					510			68					23	150	55	31	54	55	Key
2	602	602	601	604	609	460					510			68					23	150	55	31	58	55	Key
3	602	602	601	604	609	460					510			68					23	150	55	31	58	55	Key
4	602	602	601	604	609	460					510			68					23	150	55	31	58	55	Key
5																									
6																									
7																									
8																									
9																									
10																									
11																									

Stopped @ 4:58P

General Notes:



PORT OF NEW ORLEANS  
**#5 Turbine Log**



Date: 3-17-23

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Big Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Erector Left	Exhaust Erector Right			
12M																											
1AM																											
2																											
3																											
4																											
5																											
6																											
7																											
8																											
9																											
10																											
11	518	518	515	519	521	445					304			70													
12N	518	518	516	519	521	448					308			70					23	151	02	31	52	54	E.E.		
1PM	523	523	522	524	526	447					449			72					23	152	02	32	52	54	E.E.		
2	524	524	522	524	525	447					448			72					22 <sup>S</sup>	150	02	31	52	54	E.E.		
3							@ 3:39 pm Stopped												22 <sup>S</sup>	150	02	32	52	54	E.E.		
4												@ 3:42 pm Flame Out															
5							@ 4:00 T.G.																				
6																											
7																											
8																											
9																											
10																											
11																											

General Notes: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 3-17-23



Time	Bar. Hrs.	Speed / RPM	Ambient Temp.	Oil Temp / Avon Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Friction Brg. No. 1 Temp.	Friction Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (T)	Gear Brg. No. 4 Temp.	Lubricator Brg. Temp. (°)	Oil Tank Level	Oil Level Ok	Oil Temp. No. 1 / No. 2 / No. 3 / No. 4	Incoming Gas Press.	Oil Pressure	Oil Temp. (°C)	Oil Temp. (°F)	Reading Taken By:	
12M	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
1AM	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
10	/	/	/	/	/	/	/	118	140	155	/	104	/	40°C	1/2	Y	175	1000	/	/	/	/	EE	
11	/	3625	67	110	118	110	115	118	140	150	/	104	/	40°C	1/2	Y	175	1400	/	/	/	/	EE	
12N	/	3628	67	110	118	110	115	118	140	150	/	104	/	40°C	1/2	Y	175	1500	/	/	/	/	EE	
1PM	/	3627	64	110	138	157	122	140	154	101	/	180*	/	40°C	1/2	Y	175	1400	/	/	/	/	EE	
2	/	3628	62	110	138	156	122	140	154	101	/	180*	/	40°C	1/2	Y	175	1400	/	/	/	/		
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
6	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
7	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
8	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
9	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
11	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	

General Notes: Started #5 Turbine @ 10:52 am. Flame @ 10:57 am. Up to Speed @ 11:10 am. Load @ 11:15 am  
 @ Gear Brg. Thrust reading was @ 180°F Will notify Low Lift. @ 3:39 pm Stopped @ 3:52 pm Flame Out, @ 4:00 pm TG  
 @ 4:08 GAS closed Vent open 2 x C. Butter



Side One

# Sewerage and Water Board of New Orleans

## #5 Turbine Log

Date: 4/3/23



Time	Run Hours	Speed Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (T)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (C)	Oil Tank Level	Oil Level Oil In. Aux. Oil Pump Yes/No. Add L. Needed	Incoming Gas Press.	Kilowatts	Reading Taken By:	
12M																					
1AM																					
2																					
3																					
4																					
5																					
6																					
7																					
8																					
9	Cleaning up #4 Turbine + B Pump																				
10																					
11																					
12N	200/150	86	105	135	155	119		142	162	162		180		41	1/2	Yes	177	3000			
1PM	300/150	86	105	135	155	119		142	162	162		180		41	1/2	Yes	177	3000			
2	300/150	87	105	135	155	119		142	162	162		180		41	1/2	Yes	177	3000		alt RL	
3	3616	88	105	170	160	122		144	162	161		180		41	1/2	Yes	177	2900		alt RL	
4	3616	88	105	170	160	122		144	162	161		180		41	1/2	Yes	177	2600		alt RL	
5	3616	88	105	170	160	122		144	162	161		180		41	1/2	Yes	177	2600		alt RL	
6	3616	88	105	170	160	122		144	162	161		180		41	1/2	Yes	178	2600		alt RL	
7	3615	84	105	176	160	121		144	161	161		180		41	1/2	Yes	178	2700		alt RL	
8	3614	84	105	136	160	121		144	160	160		180		41	1/2	Yes	178	3400		alt RL	
9	3610	83	105	136	160	120		144	160	160		180		41	1/2	Yes	178	2900		alt RL	
10	3615	83	105	136	160	120		144	160	160		180		41	1/2	Yes	178	2900		DP.	
11	3615	83	105	130	160	120		144	160	160		180		41	1/2	Yes	178	2900			

General Notes:



Side Two

Sewerage and Water Board of New Orleans  
#5 Turbine Log



Date: 4/3/23

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Ditch Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Alt.	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply Temp.	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Director Left	Exhaust Director Right
12M																								
1AM																								
2																								
3																								
4																								
5																								
6																								
7																								
8																								
9																								
10	Clearing up #4 Turbine & B Pump																							
11																								
12N	590	590	589	592	595	591	/	-	-	-	502	/	/	76	/	/	/	/	23 <sup>5</sup>	155	61	30 <sup>5</sup>	53	54
1PM	590	590	589	592	595	591	/	-	-	-	502	/	/	76	/	/	/	/	23 <sup>5</sup>	155	61	30 <sup>5</sup>	53	54
2	590	590	589	592	595	591	/	-	-	-	502	/	/	76	/	/	/	/	23 <sup>5</sup>	155	61	30 <sup>5</sup>	53	54
3	597	597	596	600	603	474	/	/	/	/	515	/	/	88	/	/	/	/	23 <sup>5</sup>	155	61	31	53	54
4	587	587	587	590	592	472	/	/	/	/	510	/	/	88	/	/	/	/	23 <sup>5</sup>	155	61	31	53	54
5	587	587	587	588	590	471	/	/	/	/	510	/	/	88	/	/	/	/	23 <sup>5</sup>	155	61	31	53	54
6	585	585	585	586	588	471	/	/	/	/	508	/	/	88	/	/	/	/	23 <sup>5</sup>	155	61	31	53	54
7	584	584	587	586	589	470	/	/	/	/	508	/	/	86	/	/	/	/	23 <sup>5</sup>	155	61	31	53	54
8	580	580	586	589	592	470	/	/	/	/	510	/	/	86	/	/	/	/	23 <sup>5</sup>	155	61	31	53	54
9	597	594	593	598	601	469	/	/	/	/	512	/	/	85	/	/	/	/	23 <sup>5</sup>	155	61	31	53	54
10	585	585	587	588	590	467	/	/	/	/	509	/	/	84	/	/	/	/	23 <sup>5</sup>	155	61	31	53	54
11	582	583	582	586	589	467	/	/	/	/	507	/	/	84	/	/	/	/	23 <sup>5</sup>	155	61	31	53	54

General Notes:



Side One

# Sewerage and Water Board of New Orleans

## #5 Turbine Log

Date: 4/14/23



Time	Run Hours	Speed / RPM	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Cear Brg. No. 3 Temp.	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (C)	Oil Tank Level	Oil Level Ok Le. Aux. Oil Pump Yes/No - Add Oil/Excess?	Incoming Gas Press.	Kilovatts	Reading Taken By:
12M		3615	83	105	136	160	120		144	160	160		180	41	1/2	Yes	178	2900	558835
1AM		3615	84	105	136	160	120		144	160	160		180	41	1/2	Yes	178	2900	
2		3615	84	105	136	160	120		144	160	160		180	41	1/2	Yes	178	2900	
3		3615	84	105	136	160	120		144	160	160		180	41	1/2	Yes	178	2900	
4		3615	84	105	136	160	120		144	160	160		180	41	1/2	Yes	178	2900	
5		3615	84	105	136	160	120		144	160	160		180	41	1/2	Yes	178	3100	
6		3615	84	105	136	160	120		144	160	160		180	41°	1/2	yes	178	3100	
7		3612	78	105	136	160	120		140	160	156		178	41°	1/2	yes	178	2700	
8		3615	80	105	136	160	120		140	160	156		178	41°	1/2	yes	177	2700	
9		3615	82	105	136	160	120		140	160	158		180	41°	1/2	yes	178	2700	
10		3615	84	105	136	160	120		142	160	158		180	41°	1/2	yes	178	2700	
11		3615	86	105	136	160	120		142	160	158		180	41°	1/2	yes	178	2700	
12N		3616	82	105	136	160	120		142	160	160		180	41°	1/2	yes	178	2700	
1PM		3615	90	105	136	160	120		142	160	160		180	41°	1/2	yes	178	2700	
2		3615	90	105	136	160	120		142	160	160		180	41°	1/2	yes	178	2700	
3		3614	90	105	136	160	120		144	160	160		180	41°	1/2	yes	177	3000	
4		3614	88	105	136	160	120		144	160	160		180	41°	1/2	yes	177	3100	
5		3613	87	105	136	160	120		144	160	160		180	41°	1/2	yes	177	3200	
6		3613	85	105	136	160	120		144	160	160		180	41°	1/2	yes	178	3100	
7		3613	83	105	136	160	120		144	160	160		180	41°	1/2	yes	178	3300	
8		3612	82	105	136	160	120		144	160	160		180	41°	1/2	yes	177	3700	
9		3611	82	105	136	160	120		142	160	160		180	41°	1/2	yes	177	4100	
10		3606	81	105	136	160	120		142	160	154		181	41°	1/2	yes	177	3400	
11		3611	81	105	136	160	120		142	160	154		181	41°	1/2	yes	177	3400	

General Notes:



Side Two

# Sewerage and Water Board of New Orleans

## #5 Turbine Log



Date: 4/14/23

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right
12M	583	583	583	586	589	466	/	/	/	/	507	/	/	84	/	/	/	/	23 <sup>2</sup>	155	61	31	53	54
1AM	583	583	583	586	589	465	/	/	/	/	507	/	/	84	/	/	/	/	23 <sup>2</sup>	155	61	31	53	54
2	583	583	583	587	589	465	/	/	/	/	507	/	/	84	/	/	/	/	23 <sup>2</sup>	155	61	31	53	54
3	583	583	583	586	589	466	/	/	/	/	507	/	/	84	/	/	/	/	23 <sup>2</sup>	155	61	31	53	54
4	583	583	583	587	589	465	/	/	/	/	507	/	/	84	/	/	/	/	23 <sup>2</sup>	155	61	31	53	54
5	583	583	582	586	589	466	/	/	/	/	506	/	/	84	/	/	/	/	23 <sup>2</sup>	155	61	31	53	54
6	583	583	582	586	589	466	/	/	/	/	506	/	/	84	/	/	/	/	23 <sup>2</sup>	155	61	31	53	54
7	584	584	583	587	590	464	/	/	/	/	508	/	/	82	/	/	/	/	21 <sup>2</sup>	155	61	31	53	54
8	576	576	576	579	582	463	/	/	/	/	507	/	/	82	/	/	/	/	23	155	61	31	53	54
9	579	579	579	582	584	466	/	/	/	/	504	/	/	83	/	/	/	/	23	155	61	31	53	54
10	584	584	584	587	589	469	/	/	/	/	507	/	/	84	/	/	/	/	23	155	61	31	53	54
11	585	585	585	588	590	472	/	/	/	/	508	/	/	85	/	/	/	/	23	155	61	31	53	54
12N	587	587	586	590	592	472	/	/	/	/	509	/	/	86	/	/	/	/	23	155	61	31	53	54
1PM	588	588	588	592	594	474	/	/	/	/	511	/	/	88	/	/	/	/	23	155	61	31	53	54
2	588	588	588	591	594	473	/	/	/	/	511	/	/	88	/	/	/	/	23	155	61	31	53	54
3	593	593	592	596	599	474	/	/	/	/	514	/	/	88	/	/	/	/	23	155	61	31	53	54
4	594	594	593	597	600	474	/	/	/	/	515	/	/	87	/	/	/	/	23	155	61	31	53	54
5	595	595	594	598	601	474	/	/	/	/	516	/	/	87	/	/	/	/	23	155	61	31	53	54
6	594	594	593	597	600	471	/	/	/	/	515	/	/	86	/	/	/	/	23	155	61	31	53	54
7	589	589	588	592	594	469	/	/	/	/	511	/	/	85	/	/	/	/	23	155	61	31	53	54
8	592	592	591	595	598	469	/	/	/	/	513	/	/	84	/	/	/	/	23	155	61	31	53	54
9	593	593	592	596	598	468	/	/	/	/	513	/	/	84	/	/	/	/	23	155	61	31	53	54
10	611	611	609	613	617	462	/	/	/	/	523	/	/	84	/	/	/	/	23	155	61	31	53	54
11	593	593	592	596	599	468	/	/	/	/	515	/	/	84	/	/	/	/	23	155	61	31	53	54

General Notes:



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 4/5/23



Time	Run Hours	Speed / Kpm	Ambient Temp.	Oil Temp From Cooler	No.1 Brg. Temp	No.2 Brg. Temp.	No. 2 Thrust Temp.	No.3 Brg. Temp.	No.4 Brg. Temp.	Pinion Brg. No.1 Temp.	Pinion Brg. No.2 Temp.	Gear Brg. No.3 Temp.	Gear Brg. Thrust(3T)	Gear Brg. No.4 Temp	Generator Brg. Temp.(C)	Oil Tank Level	Oil Level Ok In Aux. Oil Pump Yes / No. diff if needed	Incoming Gas Press.	Kilowatts	Reading Taken By:
12M		3611	81	105	136	160	120		142	160	159		181		41	1/2	Yes	177	3400	
1AM		3612	81	105	136	160	120		142	160	159		181		41	1/2	Yes	177	3300	
2		3614	81	105	136	160	120		142	160	159		181		41	1/2	Yes	177	3300	
3		3614	81	105	136	160	120		142	160	159		181		41	1/2	Yes	177	2900	
4		3614	83	105	136	160	120		142	160	159		181		41	1/2	Yes	177	2900	
5		3614	83	105	136	160	120		142	160	159		181		41	1/2	Yes	177	2900	
6		3614	83	105	136	160	120		142	160	159		181		41	1/2	Yes	177	2900	
7		3615	84	105	136	159	119		142	160	160		180		41	1/2	Yes	178	2800	ST-L
8		3615	84	105	136	159	119		142	160	160		180		41	1/2	Yes	178	2800	ST-L
9		3615	84	105	136	159	119		142	160	160		180		41	1/2	Yes	178	2800	ST-L
10		3614	85	105	136	159	119		142	160	160		180		41	1/2	Yes	178	2900	ST-L
11		3614	86	105	137	159	120		142	160	160		180		41	1/2	Yes	178	3000	ST-L
12N		3615	86	105	137	160	120		143	160	160		181		41	1/2	Yes	178	3000	ST-L
1PM		3611	87	105	138	160	121		143	160	160		181		41	1/2	Yes	178	3300	ST-L
2		3611	87	105	139	160	121		144	160	160		181		41	1/2	Yes	178	3300	ST-L
3		3000	87	105	139	100	121		143	100	100		182		41	1/2	Yes	178	3500	E.E.
4		3613	87	105	139	160	121		143	160	160		182		41	1/2	Y	178	2900	GJ
5		3614	86	105	136	160	121		143	160	160		182		41	1/2	Y	178	2900	GJ
6		3614	86	105	136	160	121		143	160	160		182		41	1/2	Y	178	2900	GJ
7		3614	86	105	136	160	121		143	160	160		182		41	1/2	Y	178	2900	GJ
8		3614	86	105	136	160	121		143	160	160		182		41	1/2	Y	178	2900	GJ
9		3611	86	105	136	160	121		143	160	160		182		41	1/2	Y	178	2900	GJ
10		3610	85	105	136	100	120		142	100	100		181		41	1/2	Yes	178	3500	GJ / E.E.
11		3610	85	105	136	160	120		142	160	160		181		41	1/2	Yes	178	3600	JP

General Notes:



Side Two

# Sewerage and Water Board of New Orleans

## #5 Turbine Log



Date: 4/5/23

Time	Point No. 1 Exhaust Temp	Point No. 2 Exhaust Temp	Point No. 4 Exhaust Temp	Point No. 5 Exhaust Temp	Point No. 6 Exhaust Temp	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right
12M	596	596	598	599	602	469	/	/	/	/	516	/	/	84	/	/	/	/	23	155	61	31	53	54
1AM	591	591	590	594	597	466	/	/	/	/	513	/	/	84	/	/	/	/	23	155	61	31	53	54
2	591	591	590	594	596	466	/	/	/	/	508	/	/	84	/	/	/	/	23	155	61	31	53	54
3	581	581	581	584	587	465	/	/	/	/	508	/	/	84	/	/	/	/	23	155	61	31	53	54
4	580	580	580	583	586	466	/	/	/	/	508	/	/	84	/	/	/	/	23	155	61	31	53	54
5	580	580	580	583	586	466	/	/	/	/	505	/	/	84	/	/	/	/	23	155	61	31	53	54
6	579	579	578	582	584	463	/	/	/	/	504	/	/	84	/	/	/	/	23	155	61	31	53	54
7	580	581	579	581	584	468	/	/	/	/	504	/	/	84	/	/	/	/	23	155	61	30 <sup>S</sup>	53	54
8	581	581	579	581	584	469	/	/	/	/	504	/	/	84	/	/	/	/	23	155	61	30 <sup>S</sup>	53	54
9	581	581	579	581	584	469	/	/	/	/	504	/	/	84	/	/	/	/	23	155	61	30 <sup>S</sup>	53	54
10	583	583	582	582	586	469	/	/	/	/	506	/	/	84	/	/	/	/	23	155	61	30 <sup>S</sup>	53	54
11	585	585	586	586	591	470	/	/	/	/	508	/	/	84	/	/	/	/	23	155	61	30 <sup>S</sup>	53	54
12N	588	589	590	591	594	470	/	/	/	/	510	/	/	84	/	/	/	/	23	155	61	30 <sup>S</sup>	53	54
1PM	592	593	592	594	598	473	/	/	/	/	515	/	/	84	/	/	/	/	23	155	61	30 <sup>S</sup>	53	54
2	599	599	597	598	602	473	/	/	/	/	517	/	/	84	/	/	/	/	23	155	61	31	53	54
3	599	598	598	598	602	474	/	/	/	/	510	/	/	84	/	/	/	/	23	155	61	31	53	54
4	592	592	592	595	598	473	/	/	/	/	515	/	/	84	/	/	/	/	23	155	61	31	53	54
5	591	591	591	594	596	473	/	/	/	/	513	/	/	84	/	/	/	/	23	155	61	31	53	54
6	588	589	588	591	594	470	/	/	/	/	512	/	/	84	/	/	/	/	23	155	61	31	53	54
7	588	589	588	591	594	470	/	/	/	/	512	/	/	84	/	/	/	/	23	155	61	31	53	54
8	588	592	591	595	598	474	/	/	/	/	512	/	/	84	/	/	/	/	23	155	61	31	53	54
9	590	590	589	593	596	469	/	/	/	/	512	/	/	84	/	/	/	/	23	155	61	30 <sup>S</sup>	53	54
10	590	590	588	592	596	468	/	/	/	/	512	/	/	83	/	/	/	/	23	155	61	30 <sup>S</sup>	53	54
11	600	599	598	602	605	467	/	/	/	/	516	/	/	83	/	/	/	/	23	155	61	30 <sup>S</sup>	53	54

General Notes: \_\_\_\_\_

E.E.  
G1  
G1  
G1  
G1  
G1  
G1  
G1  
G1  
G1/E.E.  
D



Side Two

Sewerage and Water Board of New Orleans  
#5 Turbine Log

Date: 4/6/23



Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel - Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Eng. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M	600	599	598	602	605	467	/	/	/	/	508	/	/	83	/	/	/	/	23	155	61	30 <sup>5</sup>	53	54	DP
1AM	587	587	586	590	593	465	/	/	/	/	509	/	/	83	/	/	/	/	23	155	61	30 <sup>5</sup>	53	54	DP
2	587	587	586	590	593	465	/	/	/	/	508	/	/	83	/	/	/	/	23	155	61	30 <sup>5</sup>	53	54	DP
3	586	586	586	590	593	465	/	/	/	/	509	/	/	83	/	/	/	/	23	155	61	30 <sup>5</sup>	53	54	DP
4	580	580	580	583	585	463	/	/	/	/	505	/	/	83	/	/	/	/	23	155	61	30 <sup>5</sup>	53	54	DP
5	580	579	579	583	585	462	/	/	/	/	504	/	/	83	/	/	/	/	23	155	61	30 <sup>5</sup>	53	54	DP
6	580	580	579	583	585	463	/	/	/	/	504	/	/	83	/	/	/	/	23	155	61	30 <sup>5</sup>	53	54	DP
7	581	580	579	582	585	463	/	/	/	/	504	/	/	82	/	/	/	/	23	155	61	30 <sup>5</sup>	53	54	E.E.
8	582	580	578	582	585	462	/	/	/	/	503	/	/	81	/	/	/	/	23	155	61	31	53	54	E.E.
9	583	581	578	581	584	463	/	/	/	/	503	/	/	82	/	/	/	/	23	154	61	31	53	54	E.E.
10	585	585	585	588	590	468	/	/	/	/	507	/	/	84	/	/	/	/	23	154	62	31	53	54	E.E.
11	585	586	586	587	589	468	/	/	/	/	506	/	/	84	/	/	/	/	23	154	62	31	53	54	E.E.
12N	588	589	588	592	594	470	/	/	/	/	511	/	/	84	/	/	/	/	23	154	62	31	53	54	E.E.
IPM	589	589	588	591	593	471	/	/	/	/	511	/	/	84	/	/	/	/	23	154	62	30 <sup>5</sup>	53	54	E.E.
2	589	589	588	590	592	472	/	/	/	/	512	/	/	84	/	/	/	/	23	154	62	30 <sup>5</sup>	53	54	E.E.
3	589	589	589	593	595	471	/	/	/	/	510	/	/	84	/	/	/	/	23	154	62	30 <sup>5</sup>	53	54	DP
4	590	590	590	593	596	472	/	/	/	/	510	/	/	84	/	/	/	/	23	154	62	30 <sup>5</sup>	53	54	DP
5	595	595	594	598	601	470	/	/	/	/	514	/	/	84	/	/	/	/	23	154	62	30 <sup>5</sup>	53	54	DP
6	593	593	593	597	600	469	/	/	/	/	513	/	/	84	/	/	/	/	23	154	62	30 <sup>5</sup>	53	54	DP
7	592	593	592	596	599	469	/	/	/	/	513	/	/	84	/	/	/	/	23	154	62	30 <sup>5</sup>	53	54	DP
8	596	596	595	599	603	468	/	/	/	/	514	/	/	84	/	/	/	/	23	154	62	30 <sup>5</sup>	53	54	DP
9	587	587	586	590	592	465	/	/	/	/	509	/	/	84	/	/	/	/	23	154	62	30 <sup>5</sup>	53	54	DP
10	604	604	601	606	610	466	/	/	/	/	515	/	/	84	/	/	/	/	23	154	62	30 <sup>5</sup>	53	54	DP
11	604	605	604	608	613	467	/	/	/	/	517	/	/	84	/	/	/	/	23	154	62	30 <sup>5</sup>	53	54	DP

General Notes:



Side One

Sewerage and Water Board of New Orleans



#5 Turbine Log

Date: 4/6/23

Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No.1 Brg. Temp	No.2 Brg. Temp.	No. 2 Thrust Temp.	No.3 Brg. Temp.	No.4 Brg. Temp.	Pinion Brg. No.1 Temp.	Pinion Brg. No.2 Temp.	Gear Brg. No.3 Temp.	Gear Brg. Thrust(3T)	Gear Brg. No.4 Temp.	Generator Brg. Temp.(C)	Oil Tank Level	Oil Level Ok In Aux. Oil Pump Yes / No - Add Oil/Level	Incoming Gas Press.	Kilowatts			Reading Taken By:
12M	/	3612		105	136	160			142	160	160		181		41	1/2	Yes	178	3100			BB
1AM	/	3612		105	136	160			142	160	160		181		41	1/2	Yes	178	3100			BB
2	/	3611		105	136	160			142	160	160		181		41	1/2	Yes	178	3100			BB
3	/	3611		105	136	160			142	160	160		181		41	1/2	Yes	178	3100			BB
4	/	3613		105	136	160			142	160	160		181		41	1/2	Yes	178	2900			BB
5	/	3613		105	136	160			142	160	160		181		41	1/2	Yes	178	2900			BB
6	/	3613		105	136	160			142	160	160		181		41	1/2	Yes	178	2900			BB
7	/	3613	82	105	135	160	120		142	160	160		180		41	1/2	Yes	178	3100			E.E.
8	/	3613	83	105	136	160	120		143	161	160		181		41	1/2	Yes	178	3000			E.E.
9	/	3612	84	105	136	160	121		143	161	160		181		41	1/2	Yes	178	2700			E.E.
10	/	3614	83	105	136	158	118		143	155	160		180		41	1/2	Yes	178	2800			E.E.
11	/	3609	83	105	136	158	119		143	155	160		180		41	1/2	Yes	178	3500			E.E.
12N	/	3612	83	105	135	158	119		143	155	160		180		41	1/2	Yes	179	3400			E.E.
1PM	/	3613	84	105	136	159	119		144	155	160		180		41	1/2	Yes	178	2900			E.E.
2	/	3614	85	105	136	159	120		144	155	160		180		41	1/2	Yes	178	2900			E.E.
3	/	3613	85	105	136	159	120		144	155	160		180		41	1/2	Yes	178	2800			BB
4	/	3613	85	105	136	159	120		144	155	160		180		41	1/2	Yes	178	2800			BB
5	/	3611	85	105	136	159	120		144	155	160		180		41	1/2	Yes	178	3000			BB
6	/	3611	85	105	136	159	120		144	155	160		180		41	1/2	Yes	178	3200			BB
7	/	3611	85	105	136	159	120		144	155	160		180		41	1/2	Yes	178	3300			BB
8	/	3610	85	105	136	159	120		144	155	160		180		41	1/2	Yes	178	3500			BB
9	/	3612	85	105	136	159	120		144	155	160		180		41	1/2	Yes	178	3500			BB
10	/	3612	85	105	136	159	120		144	155	160		180		41	1/2	Yes	178	3100			BB
11	/	3612	85	105	136	159	120		144	155	160		180		41	1/2	Yes	178	3100			BB

General Notes:



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 4/1/23



Time	Run Hours	Speed / rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (31)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (c)	Oil Tank Level	Oil Level OK In Adv. On Pump No. 1 No. 2 diff. (2/level)	Incoming Gas Press.	Kilowatts	Reading Taken By:
12M		3618	85	105	136	159	120		144	155	160		180		41	1/2	Yes	178	3300	DP
1AM		3618	85	105	136	159	120		144	155	160		180		41	1/2	Yes	178	3300	DP
2		3619	85	105	136	159	120		144	155	160		180		41	1/2	Yes	178	3300	DP
3		3619	85	105	136	159	120		144	155	160		180		41	1/2	Yes	178	3300	DP
4		3619	85	105	136	159	120		144	155	160		180		41	1/2	Yes	178	3300	DP
5		3619	85	105	136	159	120		144	155	160		180		41	1/2	Yes	178	3300	DP
6		3619	85	105	136	159	120		144	155	160		180		41	1/2	Yes	178	3300	DP
7		3621	82	105	136	159	120		142	155	160		180		41	1/2	Yes	178	3000	E.E.
8		3619	82	105	136	160	120		142	155	160		180		41	1/2	Yes	178	3100	E.E.
9		3618	81	105	136	159	121		142	156	160		180		41	1/2	Yes	179	3200	E.E.
10		3619	80	106	137	158	120		143	156	160		180		41	1/2	Yes	179	3100	E.E.
11		3619	78	105	136	157	116		139	152	158		178		41	1/2	Yes	178	3100	E.E.
12N		3611	78	106	136	157	117		140	152	158		179		41	1/2	Yes	178	4400	E.E.
1PM		3610	78	106	136	157	117		140	152	158		179		41	1/2	Yes	179	3800	E.E.
2		3624	78	106	137	156	120		140	152	158		179		41	1/2	Yes	178	2500	E.E.
3		3600	78	105	136	156	116		140	152	158		178		41	1/2	Yes	178	2600	DP
4		3600	78	105	136	156	114		140	152	158		178		41	1/2	Yes	179	2800	DP
5		3600	76	105	136	156	114		140	152	158		178		41	1/2	Yes	179	2900	DP
6		3600	78	105	136	156	114		140	152	158		178		41	1/2	Yes	179	2900	DP
7		3600	78	105	136	156	114		140	152	158		178		41	1/2	Yes	179	2600	DP
8		3600	78	105	136	156	114		140	152	158		178		41	1/2	Yes	179	2500	DP
9		3600	78	105	136	156	114		140	152	158		178		41	1/2	Yes	179	2600	DP
10		3600	78	105	136	156	114		140	152	158		178		41	1/2	Yes	179	2600	DP
11		3619	78	105	136	156	116		140	152	158		178		41	1/2	Yes	179	2400	DP

General Notes:



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log



Date: 4/7/23

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft.	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brig. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M	588	588	588	592	595	465	/	/	/	/	511	/	/	84	/	/	/	/	23	154	62	30 <sup>5</sup>	53	54	
1AM	588	589	588	592	595	465	/	/	/	/	511	/	/	84	/	/	/	/	23	154	62	30 <sup>5</sup>	53	54	
2	587	589	585	590	594	465	/	/	/	/	510	/	/	84	/	/	/	/	23	154	62	30 <sup>5</sup>	53	54	
3	586	584	583	587	595	465	/	/	/	/	509	/	/	84	/	/	/	/	23	154	62	30 <sup>5</sup>	53	54	
4	584	584	583	587	595	463	/	/	/	/	507	/	/	84	/	/	/	/	23	154	62	30 <sup>5</sup>	53	54	
5	584	584	583	587	590	463	/	/	/	/	507	/	/	84	/	/	/	/	23	154	62	30 <sup>5</sup>	53	54	
6	582	583	582	586	588	462	/	/	/	/	506	/	/	84	/	/	/	/	23	154	62	30 <sup>5</sup>	53	54	E.E.
7	582	583	582	586	588	462	/	/	/	/	506	/	/	84	/	/	/	/	23	154	62	31	53	54	E.E.
8	581	583	582	586	588	403	/	/	/	/	507	/	/	83	/	/	/	/	23	154	62	31	53	54	E.E.
9	571	571	571	574	577	460	/	/	/	/	504	/	/	83	/	/	/	/	23	154	62	31	53	54	E.E.
10	574	573	573	576	579	461	/	/	/	/	501	/	/	83	/	/	/	/	23	153	62	31	53	54	E.E.
11	579	580	579	583	585	464	/	/	/	/	504	/	/	80	/	/	/	/	23	153	62	31	53	54	E.E.
12N	610	609	607	611	615	466	/	/	/	/	520	/	/	81	/	/	/	/	23	153	62	31	53	54	E.E.
1PM	590	589	588	592	595	466	/	/	/	/	518	/	/	81	/	/	/	/	23	153	62	31	53	54	E.E.
2	564	564	564	567	568	460	/	/	/	/	495	/	/	80	/	/	/	/	23	153	62	31	53	54	/
3	564	564	564	567	568	460	/	/	/	/	495	/	/	80	/	/	/	/	23	153	62	31	53	54	/
4	573	573	572	576	578	461	/	/	/	/	497	/	/	80	/	/	/	/	23	153	62	31	53	54	/
5	573	573	572	576	578	461	/	/	/	/	497	/	/	80	/	/	/	/	23	153	62	31	53	54	/
6	570	570	573	576	578	462	/	/	/	/	497	/	/	80	/	/	/	/	23	153	62	31	53	54	/
7	570	570	573	576	578	462	/	/	/	/	497	/	/	80	/	/	/	/	23	153	62	31	53	54	/
8	567	567	567	570	572	461	/	/	/	/	497	/	/	82	/	/	/	/	23	153	62	31	53	54	/
9	567	567	567	570	572	461	/	/	/	/	497	/	/	82	/	/	/	/	23	153	62	31	53	54	/
10	566	566	566	569	571	460	/	/	/	/	497	/	/	82	/	/	/	/	23	153	62	31	53	54	DP
11	558	558	558	561	563	457	/	/	/	/	491	/	/	82	/	/	/	/	23	153	62	31	53	54	

General Notes: \_\_\_\_\_







Side Two

Sewerage and Water Board of New Orleans  
#5 Turbine Log



Date: 4/8/23

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Air	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M	558	559	558	561	563	456	/	/	/	/	490	/	/	82	/	/	/	/	23	153	62	31	53	54	DP
1AM	576	576	575	579	581	458	/	/	/	/	500	/	/	82	/	/	/	/	23	153	62	31	53	54	DP
2	576	575	575	578	581	458	/	/	/	/	508	/	/	82	/	/	/	/	23	153	62	31	53	54	DP
3	562	562	563	564	567	455	/	/	/	/	492	/	/	82	/	/	/	/	23	153	62	31	53	54	DP
4	562	562	562	565	568	458	/	/	/	/	492	/	/	82	/	/	/	/	23	153	62	31	53	54	DP
5	555	555	554	558	560	454	/	/	/	/	487	/	/	82	/	/	/	/	23	153	62	31	53	54	DP
6	555	555	555	558	560	455	/	/	/	/	487	/	/	82	/	/	/	/	23	153	62	31	53	54	DP
7	554	554	554	557	559	454	/	/	/	/	487	/	/	82	/	/	/	/	23	153	62	31	53	54	DP
8	556	556	556	559	561	455	/	/	/	/	487	/	/	76	/	/	/	/	23	153	62	31	53	54	DP
9	563	563	562	566	568	455	/	/	/	/	491	/	/	76	/	/	/	/	23	153	62	31	53	54	DP
10	563	563	563	566	569	455	/	/	/	/	491	/	/	76	/	/	/	/	23	153	62	31	53	54	DP
11	564	564	563	567	569	455	/	/	/	/	492	/	/	76	/	/	/	/	23	153	62	31	53	54	DP
12N	566	566	565	569	571	455	/	/	/	/	494	/	/	76	/	/	/	/	23	153	62	31	53	54	DP
1PM	565	565	564	568	570	456	/	/	/	/	493	/	/	76	/	/	/	/	23	153	62	31	53	54	DP
2	565	565	565	568	570	456	/	/	/	/	493	/	/	76	/	/	/	/	23	153	62	31	53	54	DP
3	565	565	565	568	570	456	/	/	/	/	493	/	/	80	/	/	/	/	23	156	62	31	52	54	DP
4	565	565	565	568	570	456	/	/	/	/	493	/	/	80	/	/	/	/	23	156	62	31	52	54	DP
5	570	570	570	573	575	461	/	/	/	/	499	/	/	80	/	/	/	/	23	156	62	31	52	54	DP
6	570	570	570	573	575	461	/	/	/	/	499	/	/	80	/	/	/	/	23	156	62	31	52	54	DP
7	570	570	570	573	575	461	/	/	/	/	495	/	/	80	/	/	/	/	23	156	62	31	52	55	DP
8	570	570	570	573	575	461	/	/	/	/	495	/	/	80	/	/	/	/	23	156	62	31	52	55	DP
9	566	566	565	569	572	456	/	/	/	/	495	/	/	82	/	/	/	/	23	156	62	31	52	55	DP
10	566	566	565	569	572	456	/	/	/	/	495	/	/	82	/	/	/	/	23	156	62	31	52	55	DP
11	562	562	561	565	567	456	/	/	/	/	495	/	/	82	/	/	/	/	23	156	62	31	52	55	DP


General Notes:



Sewerage and Water Board of New Orleans

No. 1 Turbine Log

Date: 4-9-23



Time	Runs /hour	Speed/ Rpm	Sambient Temp.	Oil Temp From Cooler	No. 1 Eng. Temp	No. 2 Eng. Temp.	No. 2 Thrust Temp.	No. 3 Eng. Temp.	No. 4 Eng. Temp.	Injection No. 1 Temp.	Injection No. 2 Temp.	Gear Eng. No. 3 Temp.	Gear Eng. No. 4 Temp.	Generator Eng. Temp. (C)	Oil Tank Level	Oil Level in Tanks, Oil Pump No. 1, 2, 3, 4 Add'l Notes	Injection Oil Press.	Injection Gas Press.	Injection Water	Reading Taken By
12M		3600	72	105	136	156	118	140	152	158	/	178	41	1/2	Yes	179	2700			No
1AM		3600	72	105	136	156	118	140	152	158	/	178	41	1/2	Yes	179	2600			No
2		3600	72	105	136	156	118	140	152	158	/	178	41	1/2	Yes	179	2600			No
3		3600	72	105	136	156	118	140	152	158	/	178	41	1/2	Yes	179	2700			No
4		3600	76	105	136	156	118	140	152	158	/	178	41	1/2	Yes	179	2700			No
5		3600	76	105	136	156	118	140	152	158	/	178	41	1/2	Yes	179	2700			No
6		3600	76	105	136	156	118	140	152	156	/	178	41	1/2	Yes	179	2600			E.E.
7		3619	74	105	136	156	118	140	152	156	/	178	41	1/2	Yes	179	2900			E.E.
8		3619	73	105	136	156	118	140	153	156	/	177	41	1/2	Yes	179	2900			E.E.
9		3619	74	106	136	155	119	142	153	156	/	178	41	1/2	Yes	179	2900			E.E.
10		3619	74	106	136	155	119	142	153	156	/	178	41	1/2	Yes	179	2900			E.E.
11		3616	72	106	136	156	120	142	153	156	/	178	41	1/2	Yes	178	2900			E.E.
12N		3619	72	106	137	155	118	140	152	155	/	178	41	1/2	Yes	178	3100			E.E.
1PM		3616	70	106	137	155	118	142	153	155	/	177	41	1/2	Yes	179	3100			No
2		3615	68	106	136	156	118	138	150	156	/	178	41	1/2	Yes	178	2900			No
3		3600	70	106	136	156	118	140	152	156	/	178	41	1/2	Yes	178	2900			No
4		3600	70	106	136	156	118	140	152	156	/	178	41	1/2	Yes	178	3100			No
5		3600	70	106	136	156	118	140	152	156	/	178	41	1/2	Yes	178	3100			No
6		3600	70	106	136	156	118	140	152	156	/	178	41	1/2	Yes	178	3200			No
7		3600	70	106	136	156	118	140	152	156	/	178	41	1/2	Yes	178	3100			No
8		3600	70	106	136	156	118	140	152	156	/	178	41	1/2	Yes	178	3100			No
9		3600	70	106	136	156	118	140	152	156	/	178	41	1/2	Yes	178	2900			No
10		3600	70	106	136	156	118	140	152	156	/	178	41	1/2	Yes	178	2900			No
11		3600	70	106	136	156	118	140	155	156	/	178	41	1/2	Yes	178	2900			No

General Notes:



#5 Turbine Log

Date: 7-9-23



Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M	558	558	558	561	564	455					493		78						22	152	64	31	53	55	No
1AM	552	552	556	561	564	455					493		78						22	152	64	31	53	55	No
2	550	550	552	558	559	459					494		78						22	152	64	31	53	55	No
3	550	550	552	558	559	459					494		78						22	152	64	31	53	55	No
4	547	547	547	550	550	448					489		78						22	152	64	31	53	55	No
5	547	547	547	550	550	448					489		78						22	152	64	31	53	55	No
6	547	547	547	550	550	448					489		78						22	152	64	31	53	55	No
7	541	542	541	545	547	448					480		78						22	152	64	31	53	55	No
8	549	549	548	552	554	448					483		78						22 <sup>E</sup>	152	63	31	53	55	E.E.
9	548	548	547	550	552	447					483		79						23	152	64	31	53	55	E.E.
10	550	550	549	553	555	449					484		79						23	153	64	31	53	55	E.E.
11	551	551	550	554	556	450					485		79						23	152	64	31	53	54	E.E.
12N	551	551	550	554	556	450					485		79						23	153	64	31	53	55	E.E.
1PM	554	554	553	559	561	451					487		78						23	153	64	31	53	55	E.E.
2	555	554	554	557	560	451					487		76						23	153	64	31	53	55	E.E.
3	555	554	554	557	560	451					487		76						23	153	64	31	53	55	No
4	555	554	554	557	560	451					487		72						23	153	64	31	53	55	No
5	557	557	556	560	563	453					499		72						23	153	64	31	53	55	No
6	557	557	556	560	563	453					494		72						23	153	64	31	53	55	No
7	554	554	553	560	563	453					494		72						23	153	64	31	53	55	No
8	554	554	553	560	563	453					499		72						23	153	64	31	53	55	No
9	554	554	553	558	560	449					492		72						23	153	64	31	53	55	No
10	548	548	548	552	554	449					490		72						23	153	64	31	53	55	No
11	548	548	548	552	554	449					490		72						23	153	64	31	53	55	No

General Notes:



# Sewerage and Water Dept. of New Orleans

## No. 1 Turbine Log

Date **4-10-23**



Time	Rot. Hours	Speed / RPM	Ambient Temp.	Oil Temp. / From Case	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Brg. Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Plum. Brg. No. 1 Temp.	Plum. Brg. No. 2 Temp.	Gen. Brg. No. 3 Temp.	Gear Brg. Temp. (1)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (6)	Oil Tank Level	Oil Level Ok. In Case, Oil Pump 75% No. 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12	Incoming Gas Press.	Pressure	Reading Taken By:
12M		3600	68	106	136	156	118		140	152	159	178	41	41	41	1/2	Yes	179	2900	No
1AM		3600	68	106	136	156	118		140	152	159	178	41	41	41	1/2	Yes	179	2900	No
2		3600	68	106	136	156	118		140	152	159	178	41	41	41	1/2	Yes	179	3100	No
3		3600	68	106	136	156	118		140	152	159	178	41	41	41	1/2	Yes	179	3100	No
4		3600	68	106	136	156	118		140	152	159	178	41	41	41	1/2	Yes	179	3000	No
5		3600	68	106	136	156	118		140	152	159	178	41	41	41	1/2	Yes	179	3900	No
6		3600	68	106	136	156	118		140	152	158	178	41	41	41	1/2	Yes	179	3200	E.E.
7		3615	68	106	136	156	118		140	152	158	178	41	41	41	1/2	Yes	179	3100	E.E.
8		3615	68	106	136	156	118		140	152	158	178	41	41	41	1/2	Yes	179	3100	E.E.
9		3615	69	106	136	155	119		139	153	157	179	41	41	41	1/2	Yes	178	3100	E.E.
10		3616	69	106	137	150	118		139	153	157	179	41	41	41	1/2	Yes	178	3000	E.E.
11		3612	70	106	137	150	119		139	153	158	179	41	41	41	1/2	Yes	178	3100	E.E.
12N		3615	70	106	136	156	118		139	153	157	179	41	41	41	1/2	Yes	178	3100	E.E.
1PM		3615	72	106	136	155	118		138	153	157	178	41	41	41	1/2	Yes	178	3100	E.E.
2		3615	72	106	135	155	118		138	153	156	178	41	41	41	1/2	Yes	178	3000	No
3		3600	72	106	136	156	118		138	152	158	178	41	41	41	1/2	Yes	178	3000	No
4		3600	76	106	136	156	118		138	152	158	178	41	41	41	1/2	Yes	178	2900	No
5		3600	76	106	136	156	118		138	152	158	178	41	41	41	1/2	Yes	178	3000	No
6		3600	74	106	136	156	118		138	152	158	178	41	41	41	1/2	Yes	178	3000	No
7		3600	74	106	136	156	118		138	152	158	178	41	41	41	1/2	Yes	178	3000	No
8		3600	72	106	136	156	118		138	152	158	178	41	41	41	1/2	Yes	178	3000	No
9		3600	72	106	136	156	118		138	152	158	178	41	41	41	1/2	Yes	178	3000	No
10		3600	72	106	136	156	118		138	152	158	178	41	41	41	1/2	Yes	178	3000	No
11		3617	72	106	136	156	118		138	154	158	178	41	41	41	1/2	Yes	178	3000	cehl ee

General Notes: \_\_\_\_\_



# #5 Turbine Log

Date: 4-10-23



Time	Point No. 1 Exhaust Temp	Point No. 2 Exhaust Temp	Point No. 4 Exhaust Temp	Point No. 5 Exhaust Temp	Point No. 6 Exhaust Temp	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-AR	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Director Left	Exhaust Director Right	
12M	546	546	546	549	552	448					490		70						22	152	64	32	52	55	No
1AM	546	546	546	549	552	448					490		70						22	152	64	32	52	55	No
2	546	546	546	549	552	448					482		70						22	152	64	32	52	55	No
3	548	548	548	551	556	449					483		70						22	152	64	32	52	55	No
4	548	548	548	551	559	449					483		70						22	152	64	32	52	55	No
5	549	549	549	554	556	447					483		68						22	152	64	32	52	55	No
6	549	549	549	554	556	447					483		68						22	152	64	32	52	55	No
7	554	554	553	557	560	449					487		68						22	152	64	32	52	55	No
8	556	556	556	559	562	451					487		68						22	152	64	32	53	54	E.E.
9	557	557	557	561	563	452					488		68						22	153	64	32	53	54	E.E.
10	561	560	559	563	566	453					490		69						23	153	64	32	53	54	E.E.
11	563	563	562	566	566	456					492		69						23	153	64	32	53	54	E.E.
12N	568	568	566	571	573	459					494		70						23	153	64	32	53	54	E.E.
IPM	568	568	567	571	573	459					496		70						23	153	64	32	53	55	E.E.
2	572	572	571	575	577	462					499		72						23	153	64	32	53	54	E.E.
3	572	572	571	575	577	462					499		72						23	153	64	32	53	54	No
4	570	570	569	575	577	462					499		72						23	153	64	32	53	55	No
5	570	570	569	573	575	460					499		78						23	153	64	32	53	55	No
6	570	570	569	573	575	460					499		78						23	153	64	32	53	55	No
7	567	570	569	573	572	467					496		78						23	153	64	32	53	55	No
8	567	567	566	570	572	457					496		78						23	153	64	32	53	55	No
9	564	565	564	568	570	457					495		78						23	153	64	32	53	55	No
10	564	566	564	568	570	457					495		78						23	153	64	32	53	55	No
11	557	557	556	560	562	454					490		78						23	153	64	32	53	55	(c-o)

General Notes:



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 4-11-23



Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (31)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (4)	Oil Tank Level	Oil Level Ok In Aux. Oil Pump Yes / No. Add. L. Needed	Incoming Gas Press.	Kilowatts	Reading Taken By:
12M		3617	72	106	136	158	118		178	154	152		178		41	1/2	42	178	2800	all run
1AM		3617	72	106	136	158	118		178	154	152		177		41	1/2	42	178	2800	all run
2		3617	71	106	136	158	116		178	152	152		176		41	1/2	42	177	2800	all ch
3		3617	70	106	136	156	116		178	152	160		176		41	1/2	42	177	2800	all run
4		3617	70	106	136	156	116		178	151	160		176		41	1/2	42	177	2800	all ch
5		3617	69	106	136	156	116		178	150	160		176		41	1/2	42	177	2800	all ch
6		3618	68	106	136	156	116		178	150	159		176		41	1/2	42	177	2600	all run
7		3608	68	106	136	156	116		138	150	159		176		41	1/2	Yes	177	3000	
8		3616	68	106	136	156	116		138	150	159		176		41	1/2	Yes	177	3800	
9		3616	68	106	136	156	116		138	150	159		176		41	1/2	Yes	177	3800	
10		3616	68	106	136	156	116		138	150	159		176		41	1/2	Yes	177	2900	
11		3615	68	106	136	156	116		138	150	159		176		41	1/2	Yes	177	3000	
12N		3615	77	106	136	158	116		140	150	159		176		41	1/2	Yes	178	3000	
1PM		3615	77	106	136	158	116		140	150	159		176		41	1/2	Yes	178	3000	
2		3615	77	106	136	158	116		140	150	159		176		41	1/2	Yes	178	3000	
3		3600	77	106	136	158	116		140	155	160		178		41	1/2	Yes	179	3000	
4		3600	68	106	136	158	116		140	155	160		178		41	1/2	Yes	179	3100	
5		3600	68	106	136	158	116		140	155	160		178		41	1/2	Yes	179	3100	
6		3600	68	106	136	158	116		140	155	160		178		41	1/2	Yes	179	3300	
7		3600	68	106	136	158	114		140	155	160		178		41	1/2	Yes	179	3400	
8		3600	68	106	136	158	114		140	155	160		178		41	1/2	Yes	179	3400	
9		3600	70	106	136	158	116		140	155	160		178		41	1/2	Yes	179	4100	
10		3600	70	106	136	158	116		140	155	160		178		41	1/2	Yes	179	4100	
11		3616	70	106	136	156	116		140	153	160		178		41	1/2	Yes	178	3000	all run

General Notes: \_\_\_\_\_



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log



Date: 4-11-27

Time	Point No. 1 Saltnat Temp	Point No. 2 Current Temp	Point No. 4 Exhaust Temp	Point No. 5 Exhaust Temp	Point No. 6 Exhaust Temp	Point No. 8 Comp. Disch. Temp	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-All	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Director Left	Exhaust Director Right	
12M	556	557	556	559	561	454					489			76					23	155	64	32	53	55	a ll
											490			76					23	155	64	32	53	55	a ll
1AM	558	558	557	561	567	455					490			76					23	155	64	32	53	55	a ll
2	557	557	556	560	562	454					489			75					23	155	64	32	53	55	a ll
3	556	556	555	559	561	453					488			75					23	155	64	32	53	55	a ll
4	555	555	554	558	560	452					486			75					23	155	64	32	53	55	a ll
5	552	552	555	555	557	451					485			75					23	155	64	32	53	55	a ll
6	548	548	548	551	553	450					489			75					23	155	64	32	53	55	DP
7	557	557	556	560	562	453					491			75					23	155	64	32	53	55	DP
8	557	557	556	560	562	454					493			75					23	155	64	32	53	55	DP
9	561	561	560	564	566	456					493			75					23	155	64	32	53	55	DP
10	561	561	561	565	567	456					493			75					23	155	64	32	53	55	DP
11	563	563	562	567	569	457					493			75					23	155	64	32	53	55	DP
12N	570	570	569	573	575	460					497			78					23	155	64	32	53	55	DP
1PM	570	570	569	573	575	461					497			78					23	155	64	32	53	55	DP
2	570	570	569	572	575	460					497			78					23	155	64	32	53	55	DP
3	570	570	569	572	575	460					497			78					23	155	64	32	53	55	DP
4	568	568	567	570	573	458					496			78					23	155	64	32	53	55	DP
5	568	568	567	570	573	458					496			78					23	155	64	32	53	55	DP
6	568	568	567	570	573	458					496			78					23	155	64	32	53	55	DP
7	586	586	589	590	590	459					486			78					23	155	64	32	53	55	DP
8	586	586	589	590	590	459					486			78					23	155	64	32	53	55	DP
9	591	591	589	593	598	461					510			78					23	155	64	32	53	55	DP
10	591	591	589	593	598	461					510			78					23	155	64	32	53	55	DP
11	565	565	564	568	571	458					495			77					23	155	64	31	53	55	a ll

General Notes:



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 4-12-23



Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (31)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (C)	Oil Tank Level	Oil Level Ok In Aux. Oil Pump Yes / No. Add. If Needed	Incoming Gas Press.	Kilowatts			Reading Taken By:
12M		3616	70	106	136	156	116		140	153	160		177		41	1/2	yes	178	3000			alt rbr
1AM		3616	70	106	136	156	116		140	153	160		177		41	1/2	yes	178	3000			alt rbr
2		3616	72	106	136	156	116		140	153	160		177		41	1/2	yes	177	3000			alt rbr
3		3617	73	106	136	156	116		140	153	160		176		41	1/2	yes	177	3000			alt rbr
4		3616	73	106	136	156	116		140	153	160		176		41	1/2	yes	178	3000			alt rbr
5		3616	73	106	136	156	116		140	153	160		176		41	1/2	yes	178	3000			alt rbr
6		3618	72	106	136	156	116		140	153	160		176		41	1/2	yes	177	2700			alt rbr
7		3617	72	106	136	156	116		140	153	160		176		41	1/2	Yes	178	2900			D.P.
8		3617	72	106	136	156	116		140	153	160		176		41	1/2	Yes	177	2800			D.P.
9		3618	72	106	136	156	116		140	153	160		176		41	1/2	Yes	177	2900			D.P.
10		3617	72	106	136	156	116		140	153	160		176		41	1/2	Yes	177	2800			D.P.
11		3617	72	106	136	156	116		140	153	160		176		41	1/2	Yes	178	2850			D.P.
12N		3612	72	106	136	156	116		140	153	160		176		41	1/2	Yes	178	3600			D.P.
1PM		3611	72	106	136	156	116		140	153	160		176		41	1/2	Yes	178	3600			D.P.
2		3614	72	106	136	156	116		140	153	160		176		41	1/2	Yes	178	3600			D.P.
3		3600	72	106	136	156	116		140	153	160		176		41	1/2	Yes	178	3200			D.P.
4		3600	72	106	136	156	116		140	153	160		176		41	1/2	Yes	178	2700			D.P.
5		3600	72	106	136	156	116		140	153	160		176		41	1/2	Yes	178	3000			D.P.
6		3600	72	106	136	156	116		140	153	160		176		41	1/2	Yes	178	3100			D.P.
7		3600	68	106	136	156	116		140	153	160		176		41	1/2	Yes	178	3100			D.P.
8		3600	68	106	136	156	116		140	153	160		176		41	1/2	Yes	178	3200			D.P.
9		3600	68	106	136	156	116		140	153	160		176		41	1/2	Yes	178	3200			D.P.
10		3600	68	106	136	156	116		140	153	160		176		41	1/2	Yes	178	3200			D.P.
11		3615	70	106	136	156	116		140	153	158		176		41	1/2	yes	177	3300			alt rbr

General Notes:



Side Two

# Sewerage and Water Board of New Orleans

## #5 Turbine Log

Date: 4-12-23



Time	Point No. 1 Exhaust Temp	Point No. 2 Exhaust Temp	Point No. 4 Exhaust Temp	Point No. 5 Exhaust Temp	Point No. 6 Exhaust Temp	Point No. 8 Comp. Disch. Temp	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply Temp.	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Reg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Inboard Discharge Left	Outboard Discharge Right	
12M	565	565	563	567	569	457					499			77					23	155	64	31	53	55	a LR
1AM	563	563	562	565	568	456					494			77					23	155	64	31	53	55	a LR
2	562	562	561	564	567	455					493			77					23	155	64	31	53	55	a LR
3	564	564	563	566	569	457					494			77					23	155	64	31	53	55	a LR
4	562	562	561	564	567	455					492			77					23	155	64	31	53	55	a LR
5	560	560	559	562	565	454					491			77					23	155	64	31	53	55	a LR
6	559	559	558	561	564	453					487			77					23	155	64	31	53	55	a LR
7	555	555	554	557	560	453					488			74					23	155	64	31	53	55	DP
8	555	555	554	558	560	453					487			74					23	155	64	31	53	55	DP
9	556	556	555	559	561	454					488			74					23	155	64	31	53	55	DP
10	557	557	555	559	561	454					489			74					23	155	64	31	53	55	DP
11	560	560	559	562	564	456					490			74					23	155	64	31	53	55	DP
12N	578	578	577	581	584	459					501			74					23	155	64	31	53	55	DP
1PM	582	582	580	584	588	460					504			74					23	155	64	31	53	55	DP
2	570	570	569	572	575	459					497			74					23	155	64	32	54	55	DP
3	558	559	558	561	563	457					491			76					23	155	64	32	54	55	DP
4	559	559	558	561	563	457					491			76					23	155	64	32	54	55	DP
5	564	564	563	566	570	456					494			76					23	155	64	32	54	55	DP
6	564	564	563	566	570	456					494			76					23	155	64	32	54	55	DP
7	567	566	565	569	572	456					494			76					23	155	64	32	54	55	DP
8	567	566	565	569	572	456					497			76					23	155	64	32	54	55	DP
9	567	566	565	569	572	456					497			76					23	155	64	32	54	55	DP
10	567	566	565	569	572	454					496			76					23	155	64	31	53	55	a LR
11	563	563	561	564	567	452					492			76					23	155	64	31	53	55	a LR

General Notes: \_\_\_\_\_



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 4-15-23



Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (JT)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (C)	Oil Tank Level	Oil Level OK In Aux. Oil Pump Yes / No. Add. L. Needed	Incoming Gas Press.	Kilowatts	Reading Taken By:
12M		3615	70	106	136	156	116		140	153	158		176		N/A	1/2	Yes	178	3300	dtl ed
1AM		3616	69	106	136	156	116		138	152	156		174		NA	1/2	Yes	178	4000	dtl ed
2		3612	68	106	136	156	116		132	150	155		174		NA	1/2	Yes	177	3700	dtl ed
3		3615	68	106	136	156	116		138	150	156		174		NA	1/2	Yes	178	3300	dtl ed
4		3615	68	106	136	156	116		138	150	156		174		NA	1/2	Yes	178	3200	dtl ed
5		3617	68	106	136	156	116		138	150	156		174		NA	1/2	Yes	177	2900	dtl ed
6		3617	68	106	136	156	116		138	150	156		174		NA	1/2	Yes	177	7000	dtl ed
7		3619	68	106	136	156	116		138	150	156		174		N/A	1/2	Yes	177	2800	D. Peters
8		3619	68	106	136	156	116		138	150	156		174		N/A	1/2	Yes	177	3000	D. Peters
9		3615	68	106	136	156	116		138	150	156		174		NA	1/2	Yes	177	3000	D. Peters
10		3617	70	106	136	156	116		138	150	156		174		N/A	1/2	Yes	177	2800	D. Peters
11		3619	70	106	136	156	116		138	150	156		174		N/A	1/2	Yes	177	2600	D. Peters
12N		3617	70	106	136	156	116		138	150	156		174		N/A	1/2	Yes	177	3000	D. Peters
1PM		3616	70	106	136	156	116		138	150	156		174		N/A	1/2	Yes	178	3000	D. Peters
2		3616	70	106	136	156	116		138	150	156		174		N/A	1/2	Yes	178	3000	D. Peters
3		3618	72	106	136	156	117		137	150	156		178		N/A	1/2	Yes	178	3000	E. Easterling
4		3617	72	106	136	155	116		137	150	156		175		N/A	1/2	Yes	179	3000	E. Easterling
5		3618	72	105	136	155	117		137	150	155		175		N/A	1/2	Yes	179	3000	E. Easterling
6		3617	72	106	136	155	117		138	150	156		175		N/A	1/2	Yes	179	3000	E. Easterling
7		3617	72	106	136	155	117		138	151	156		175		N/A	1/2	Yes	178	3000	E. Easterling
8		3616	70	106	135	155	116		137	150	155		174		N/A	1/2	Yes	178	3200	E. Easterling
9		3615	70	105	136	156	117		138	150	156		174		N/A	1/2	Yes	178	3400	E. Easterling
10		3617	70	105	136	156	117		138	150	156		174		N/A	1/2	Yes	178	3100	E. Easterling
11		3619	70	106	136	156	116		138	151	156		174		NA	1/2	Yes	178	2700	dtl ed

General Notes:



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log

Date: 4/17/20



Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 3 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Alt.	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Temp.	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Big-Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Discharge Left	Exhaust Discharge Right	
12M	564	564	562	565	569	453						493			76					23	155	64	31	53	55	a r
1AM	575	575	573	576	580	452						495			75					23	155	64	31	53	55	a r
2	564	564	567	571	575	452						495			74					23	155	64	31	53	55	a r
3	560	560	558	562	565	451						492			74					23	155	64	31	53	55	a r
4	557	557	566	560	562	451						490			74					23	155	64	31	53	55	a r
5	550	550	544	553	555	449						486			74					23	155	64	31	53	55	a r
6	554	554	552	556	558	451						487			74					23	155	64	31	53	55	a r
7	546	546	545	548	551	450						483			74					23	155	64	31	53	55	DP
8	554	554	553	557	560	451						487			74					23	155	64	31	53	55	DP
9	557	557	555	559	562	452						489			74					23	155	64	31	53	55	DP
10	551	551	550	553	555	453						486			74					23	155	64	31	53	55	DP
11	550	550	549	552	554	452						485			74					23	155	64	31	53	55	DP
12N	560	560	558	562	565	455						491			74					23	155	64	31	53	55	DP
1PM	562	562	561	565	567	457						493			74					23	155	64	31	53	55	DP
2	564	563	562	565	569	458						494			74					23	155	64	31	53	55	E.E.
3	564	563	562	565	568	459						494			74					23	155	64	31	53	55	E.E.
4	566	566	565	568	571	459						496			74					23	155	64	31	53	55	E.E.
5	568	568	567	570	572	460						496			75					23	156	64	31	54	55	E.E.
6	568	568	567	571	572	460						498			74					23	155	64	31	54	55	E.E.
7	567	567	565	569	572	459						497			74					23	156	64	30 <sup>5</sup>	54	55	E.E.
8	566	566	565	568	571	458						496			74					23	155	63	31	54	55	E.E.
9	569	569	568	571	574	455						497			74					23	155	63	31	54	55	E.E.
10	561	561	559	563	566	455						492			74					23	155	64	31	54	55	a r
11	542	542	541	540	543	451						484			74					23	155	64	31	54	55	a r

General Notes:



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 4-14-23



Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 1 Temp.	Gear Brg. Thrust (°F)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (°C)	Oil Tank Level	Oil Level Ok In Aux. Oil Pump Yes / No. <small>add if needed</small>	Incoming Gas Press.	Kilowatts			Reading Taken By:
12M		3619	70	106	136	156	116		138	151	156		174		MA	1/2	yes	178	2700			chl kl
1AM		3619	70	106	136	156	116		138	151	156		174		MA	1/2	yes	178	2700			chl kl
2		3619	70	106	136	156	116		138	151	156		174		MA	1/2	yes	177	2700			chl kl
3		3619	70	106	136	156	116		136	150	155		174		MA	1/2	yes	177	2700			chl kl
4		3619	70	106	136	156	116		136	150	155		174		MA	1/2	yes	178	2700			chl kl
5		3618	70	106	136	156	116		136	150	155		174		MA	1/2	yes	178	2800			chl kl
6		3616	70	106	136	156	116		136	150	155		174		MA	1/2	yes	177	2000			chl kl
7		3616	70	106	136	156	116		136	150	155		174		N/A	1/2	Yes	177	3000			DP
8		3616	70	106	136	156	116		136	150	155		174		N/A	1/2	Yes	177	3000			DP
9		3610	70	106	136	156	116		136	150	155		174		N/A	1/2	Yes	177	3800			DP
10		3610	70	106	136	156	116		136	150	155		174		N/A	1/2	Yes	177	3800			DP
11		3616	70	106	136	156	116		136	150	155		174		N/A	1/2	Yes	177	3000			DP
12N		3619	70	106	136	156	116		136	150	155		174		N/A	1/2	Yes	178	2600			DP
1PM		3619	70	106	136	156	116		136	150	155		174		N/A	1/2	Yes	178	2600			DP
2		3620	70	106	136	156	116		136	150	155		174		N/A	1/2	Yes	178	2600			DP
3		3621	74	100	130	150	117		130	150	155		174		N/A	1/2	yes	178	2600			E.E.
4		3621	74	100	135	155	116		130	150	155		174		N/A	1/2	yes	178	2600			E.E.
5		3620	73	100	135	155	117		136	150	155		174		N/A	1/2	yes	178	2700			E.E.
6		3618	73	100	135	155	116		135	151	155		173		N/A	1/2	yes	177	2900			E.E.
7		3617	73	100	130	150	117		130	151	156		174		N/A	1/2	yes	178	3100			E.E.
8		3615	72	100	130	150	116		135	150	155		173		N/A	1/2	yes	178	3300			E.E.
9		3616	72	100	135	155	117		135	150	155		173		N/A	1/2	yes	178	3400			E.E.
10		3616	70	100	135	154	116		135	150	155		174		N/A	1/2	yes	178	3300			E.E.
11		3616	70	106	136	156	116		135	150	156		174		N/A	1/2	Yes	178	3100			DP

General Notes:



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log



Date: 4-14-23

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 3 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 5 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel Fwd.	Point No. 10 1st Stage Wheel Fwd.	Point No. 11 1st Stage Wheel Fwd.	Point No. 12 1st Stage Wheel Fwd.	Point No. 20 2nd Stage Wheel-All	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Eng. Header	Lube Oil Pump Disch.	Compression Lifecharge	Temp. Relay Outlet	Exhaust Disch. Left	Exhaust Disch. Right	
12M	547	547	546	549	552	449	/	/	/	/	483	/	/	74	/	/	/	/	23	155	64	31	54	55	a LR
1AM	546	546	545	548	551	449	/	/	/	/	482	/	/	74	/	/	/	/	23	155	64	31	54	55	a LR
2	548	548	547	550	553	450	/	/	/	/	483	/	/	74	/	/	/	/	23	155	64	31	54	55	a LR
3	547	547	546	549	552	450	/	/	/	/	482	/	/	74	/	/	/	/	23	155	64	31	54	55	a LR
4	549	549	548	551	554	452	/	/	/	/	483	/	/	74	/	/	/	/	23	155	64	31	54	55	a LR
5	549	549	548	551	554	452	/	/	/	/	483	/	/	74	/	/	/	/	23	155	64	31	54	55	a LR
6	553	553	551	555	558	449	/	/	/	/	486	/	/	74	/	/	/	/	23	155	63	31	54	55	a LR
7	551	551	550	550	554	450	/	/	/	/	485	/	/	74	/	/	/	/	23	155	63	31	54	55	D.P.
8	556	555	554	557	560	452	/	/	/	/	487	/	/	74	/	/	/	/	23	155	63	31	54	55	D.P.
9	589	589	586	590	594	463	/	/	/	/	507	/	/	74	/	/	/	/	23	155	63	31	54	55	D.P.
10	589	589	585	588	593	463	/	/	/	/	507	/	/	74	/	/	/	/	23	155	63	31	54	55	D.P.
11	573	573	571	575	578	463	/	/	/	/	500	/	/	74	/	/	/	/	23	155	63	31	54	55	D.P.
12N	564	564	564	567	569	462	/	/	/	/	496	/	/	74	/	/	/	/	23	155	63	31	54	55	D.P.
1PM	570	570	569	572	575	467	/	/	/	/	499	/	/	74	/	/	/	/	23	155	63	31	54	55	D.P.
2	572	572	571	574	576	469	/	/	/	/	502	/	/	74	/	/	/	/	23	155	63	31	54	55	E.E.
3	573	573	572	575	578	470	/	/	/	/	502	/	/	74	/	/	/	/	23	155	64	31	54	55	E.E.
4	573	573	572	574	577	471	/	/	/	/	503	/	/	74	/	/	/	/	23	154	64	31	54	55	E.E.
5	575	574	572	575	579	400	/	/	/	/	503	/	/	74	/	/	/	/	23	155	64	31	54	55	E.E.
6	575	574	573	576	579	406	/	/	/	/	502	/	/	73	/	/	/	/	23	155	64	31	54	55	E.E.
7	579	579	577	580	583	405	/	/	/	/	504	/	/	73	/	/	/	/	23	155	64	31	54	55	E.E.
8	579	579	577	580	583	403	/	/	/	/	504	/	/	73	/	/	/	/	23	155	63	31	54	55	E.E.
9	577	576	575	578	582	401	/	/	/	/	503	/	/	73	/	/	/	/	23	155	63	31	54	55	E.E.
10	575	575	574	577	580	401	/	/	/	/	502	/	/	73	/	/	/	/	23	155	63	31	54	55	E.E.
11	570	570	568	572	575	458	/	/	/	/	498	/	/	73	/	/	/	/	23	155	63	31	54	55	No

General Notes: \_\_\_\_\_







# #5 Turbine Log

Date: 4-15-23



Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M	570	570	568	572	575	458					498			73					23	155	63	31	54	55	DP
1AM	570	570	568	572	575	458					498			76					23	155	63	31	54	55	DP
2	570	570	568	572	575	458					498			70					23	155	63	31	54	55	DP
3	570	570	568	572	575	458					498			70					23	155	63	31	54	55	DP
4	560	560	558	562	575	457					490			70					23	155	63	31	54	55	DP
5	562	560	558	562	565	457					490			70					23	155	63	31	54	55	DP
6	568	558	557	561	563	458					489			70					23	155	63	31	54	55	DP
7	577	577	578	579	582	460					500			76					23	155	63	31	54	55	DP
8	577	578	574	579	582	460					500			76					23	155	63	31	54	55	DP
9	580	581	574	580	585	466					505			76					23	155	63	31	54	55	DP
10	585	585	585	585	590	468					508			76					23	155	63	31	54	55	DP
11	590	590	588	592	595	468					509			76					23	155	63	31	54	55	DP
12N	602	602	599	603	607	469					517			76					23	155	63	31	54	55	DP
1PM	590	590	588	592	596	465					511			76					23	155	63	31	54	55	DP
2	705	705	703	706	710	471					588			76					23	155	63	31	54	55	DP
3	607	606	604	607	613	464					530			76					23	155	63	31	54	55	DP
4	595	575	593	596	601	463					524			76					23	155	63	31	54	55	DP
5	591	591	589	593	597	463					517			76					23	155	63	31	54	55	DP
6	592	592	571	575	578	459					502			76					23	155	63	31	54	55	DP
7	594	573	572	576	579	459					502			76					23	155	63	31	54	55	DP
8	594	574	572	576	580	460					502			76					23	155	63	31	54	55	DP
9	592	591	589	589	593	461					512			76					23	155	63	31	54	55	DP
10	591	591	589	592	596	462					513			76					23	155	63	31	54	55	DP
11	597	595	591	593	594	460					513			76					23	155	63	31	54	55	DP

General Notes:



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 4-16-23



Time	Run Hours	Speed/Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (T)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (C)	Oil Tank Level	Oil Level OK In A.S. Oil Pump Test No. Add/Drain	Incoming Gas Press	Kilowatts	Reading Taken By:
12M		3600	72	106	136	156	116		136	150	156		174		N/A	1/2	Yes	178	4300	Sh
1AM		3600	72	106	136	156	114		136	150	156		174		N/A	1/2	Yes	178	4000	Sh
2		3600	72	106	136	156	114		136	150	156		178		N/A	1/2	Yes	178	4000	Sh
3		3600	72	106	136	156	114		136	150	156		174		N/A	1/2	Yes	178	3900	Sh
4		3600	72	106	136	156	116		136	150	156		174		N/A	1/2	Yes	178	4200	Sh
5		3600	72	106	136	156	116		136	150	156		174		N/A	1/2	Yes	178	4300	Sh
6		3600	72	106	136	156	116		136	150	156		174		N/A	1/2	Yes	178	4400	Sh
7		3630	72	106	136	156	116		136	150	156		174		N/A	1/2	Yes	178	3600	Sh
8		3630	72	106	136	156	116		136	150	156		174		N/A	1/2	Yes	178	3600	Sh
9		3616	72	106	136	156	116		136	150	156		174		N/A	1/2	Yes	178	3500	Sh
10		3616	72	106	136	156	116		136	150	156		174		N/A	1/2	Yes	178	3300	Sh
11		3616	72	106	136	156	116		136	150	156		174		N/A	1/2	Yes	178	3800	Sh
12N		3611	72	106	136	156	116		136	150	156		174		N/A	1/2	Yes	178	3900	Sh
1PM		3612	72	106	136	156	116		136	150	156		174		N/A	1/2	Yes	178	3900	Sh
2		3612	72	106	136	156	116		136	150	156		174		N/A	1/2	Yes	178	3900	Sh
3		3600	72	106	136	156	116		136	150	158		174		N/A	1/2	Yes	178	3800	Sh
4		3600	72	106	136	156	116		136	150	158		174		N/A	1/2	Yes	179	3800	Sh
5		3600	72	106	136	156	116		136	156	158		174		N/A	1/2	Yes	179	3600	Sh
6		3600	72	106	136	156	116		136	156	158		174		N/A	1/2	Yes	179	3600	Sh
7		3600	72	106	136	156	116		136	150	158		174		N/A	1/2	Yes	179	3200	Sh
8		3600	72	106	136	156	116		136	150	158		174		N/A	1/2	Yes	178	3200	Sh
9		3600	72	106	136	156	116		136	150	158		174		N/A	1/2	Yes	178	3200	Sh
10		3600	72	106	136	156	116		136	150	158		174		N/A	1/2	Yes	178	3200	Sh
11		3600	72	106	136	156	116		136	150	158		174		N/A	1/2	Yes	178	3200	Sh

General Notes:



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log

Date: 4-16-23



Time	Point No. 1 Exhaust Temp	Point No. 2 Exhaust Temp	Point No. 4 Exhaust Temp	Point No. 5 Exhaust Temp	Point No. 6 Exhaust Temp	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel Fwd.	Point No. 10 2nd Stage Wheel Fwd.	Point No. 11 1st Stage Wheel Fwd.	Point No. 12 1st Stage Wheel Fwd.	Point No. 20 2nd Stage Wheel - Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brig. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Discharge Left	Exhaust Discharge Right	
12M	597	595	591	593	594	460	/	/	/	/	513	/	/	76	/	/	/	/	23	155	63	31	54	55	Ng
1AM	597	595	591	593	594	460	/	/	/	/	513	/	/	76	/	/	/	/	23	155	63	31	54	55	Ng
2	569	569	567	571	575	456	/	/	/	/	500	/	/	76	/	/	/	/	23	155	63	31	54	55	Ng
3	569	569	567	571	575	456	/	/	/	/	500	/	/	76	/	/	/	/	23	155	63	31	54	55	Ng
4	587	587	584	588	592	457	/	/	/	/	509	/	/	76	/	/	/	/	23	155	63	31	54	55	Ng
5	587	586	584	587	592	456	/	/	/	/	509	/	/	76	/	/	/	/	23	155	63	31	54	55	Ng
6	584	584	581	583	589	457	/	/	/	/	507	/	/	76	/	/	/	/	23	155	63	31	54	55	Ng
7	572	572	571	574	578	456	/	/	/	/	501	/	/	76	/	/	/	/	23	155	63	31	54	55	DP
8	572	572	570	573	577	456	/	/	/	/	501	/	/	76	/	/	/	/	23	155	63	31	54	55	DP
9	569	569	567	571	575	456	/	/	/	/	500	/	/	76	/	/	/	/	23	155	63	31	54	55	DP
10	564	564	563	566	570	454	/	/	/	/	496	/	/	76	/	/	/	/	23	155	63	31	54	55	DP
11	563	563	562	565	568	453	/	/	/	/	495	/	/	76	/	/	/	/	23	155	63	31	54	55	DP
12N	580	579	577	581	585	456	/	/	/	/	503	/	/	76	/	/	/	/	23	155	63	31	54	55	DP
1PM	579	579	578	581	585	457	/	/	/	/	505	/	/	76	/	/	/	/	23	155	63	31	54	55	DP
2	581	581	579	582	587	458	/	/	/	/	506	/	/	78	/	/	/	/	23	155	63	31	54	55	Ng
3	581	581	579	582	587	458	/	/	/	/	506	/	/	78	/	/	/	/	23	155	63	31	54	55	Ng
4	575	575	576	579	582	459	/	/	/	/	506	/	/	78	/	/	/	/	23	155	63	31	54	55	Ng
5	575	575	576	579	582	459	/	/	/	/	500	/	/	78	/	/	/	/	23	155	63	31	54	55	Ng
6	569	569	568	571	575	460	/	/	/	/	500	/	/	78	/	/	/	/	23	155	63	31	54	55	Ng
7	569	569	568	571	575	460	/	/	/	/	500	/	/	78	/	/	/	/	23	155	63	31	54	55	Ng
8	565	565	563	567	570	456	/	/	/	/	498	/	/	78	/	/	/	/	23	155	63	31	54	55	Ng
9	565	565	563	567	570	456	/	/	/	/	498	/	/	78	/	/	/	/	23	155	63	31	54	55	Ng
10	563	563	563	567	570	456	/	/	/	/	498	/	/	78	/	/	/	/	23	155	63	31	54	55	Ng
11	563	563	562	565	569	455	/	/	/	/	496	/	/	78	/	/	/	/	23	155	63	31	54	55	Ng

General Notes:



Side One

# Sewerage and Water Board of New Orleans



## #5 Turbine Log

Date: \_\_\_\_\_

Time	Run Hours	Speed / kpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Piston Brg. No. 1 Temp.	Piston Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (3)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (G)	Oil Tank Level	Oil Level Oil to Air, Oil Pump to No. 1 Brg. Add'l Feed	Incoming Gas Press.	Kilowatts	Reading Taken By:
12M		3600	72	106	136	156	116		136	150	158	174		N/A	1/2	Yes	178	3200	No	
1AM		3600	72	106	136	156	116		136	150	158	174		N/A	1/2	Yes	178	3200	No	
2		3600	72	106	136	156	116		136	150	158	174		N/A	1/2	Yes	178	3100	No	
3		3600	72	106	136	156	116		136	150	158	174		N/A	1/2	Yes	178	3100	No	
4		3600	72	106	136	156	116		136	150	158	174		N/A	1/2	Yes	178	3000	No	
5		3600	72	106	136	156	116		136	150	158	174		N/A	1/2	Yes	178	3000	No	
6		3600	72	106	136	156	116		136	150	158	174		N/A	1/2	Yes	178	3000	No	
7		3617	68	106	136	156	116		136	150	158	176		MA	1/2	Yes	178	3200	a LR	
8		3617	68	106	136	156	116		176	150	158	176		MA	1/2	Yes	178	2900	a LR	
9		3620	69	106	136	156	116		176	151	159	176		MA	1/2	Yes	177	2700	a LR	
10		3621	70	106	136	156	116		176	151	159	176		MA	1/2	Yes	178	2700	a LR	
11		3619	71	106	136	156	116		176	152	160	177		MA	1/2	Yes	178	3000	a LR	
12N		3619	72	106	136	156	116		176	153	160	177		MA	1/2	Yes	177	2900	a LR	
1PM		3619	74	106	136	156	116		176	153	160	177		MA	1/2	Yes	177	2900	a LR	
2		3619	76	106	136	156	116		176	153	160	177		MA	1/2	Yes	178	2900	a LR	
3		3619	78	106	136	158	116		176	155	160	178		MA	1/2	Yes	178	3000	a LR	
4		3619	78	106	136	158	116		176	155	159	180		MA	1/2	Yes	178	3000	a LR	
5		3619	78	106	136	158	116		176	155	158	180		MA	1/2	Yes	177	3000	a LR	
6		3620	77	106	136	158	116		176	155	158	180		MA	1/2	Yes	177	3200	a LR	
7		3618	76	106	136	158	116		176	155	158	180		MA	1/2	Yes	177	3000	a LR	
8		3618	74	106	136	158	116		176	154	158	180		MA	1/2	Yes	177	2900	a LR	
9		3620	72	106	136	158	118		176	153	159	179		MA	1/2	Yes	178	2900	a LR	
10		3620	72	106	136	158	118		176	153	159	178		MA	1/2	Yes	178	2900	a LR	
11		3600	72	106	136	156	116		138	152	158	176		N/A	1/2	Yes	178	3000	No	

General Notes: \_\_\_\_\_



Side Two

Sewerage and Water Board of New Orleans  
#5 Turbine Log



Date: 4-17-23

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disca. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M	563	563	562	565	569	495	/	/	/	/	496	/	/	78	/	/	/	/	23	155	63	31	54	55	JK
1AM	563	563	562	565	569	495	/	/	/	/	496	/	/	78	/	/	/	/	23	155	63	31	54	55	JK
2	563	563	562	565	569	495	/	/	/	/	490	/	/	78	/	/	/	/	23	155	63	31	54	55	JK
3	560	560	562	568	570	448	/	/	/	/	490	/	/	78	/	/	/	/	23	155	63	31	54	55	JK
4	560	560	562	568	570	458	/	/	/	/	482	/	/	78	/	/	/	/	23	155	63	31	54	55	JK
5	553	553	551	552	555	450	/	/	/	/	484	/	/	78	/	/	/	/	23	155	63	31	54	55	JK
6	553	553	551	552	555	450	/	/	/	/	488	/	/	78	/	/	/	/	23	155	63	31	54	55	JK
7	555	555	553	557	560	451	/	/	/	/	485	/	/	72	/	/	/	/	23	155	64	31	54	55	JK
8	551	551	550	554	556	451	/	/	/	/	487	/	/	72	/	/	/	/	23	155	64	31	54	55	JK
9	550	550	548	552	554	453	/	/	/	/	487	/	/	73	/	/	/	/	23	155	64	31	54	55	JK
10	551	551	550	552	556	455	/	/	/	/	488	/	/	74	/	/	/	/	23	155	64	31	54	55	JK
11	560	560	560	562	566	457	/	/	/	/	492	/	/	75	/	/	/	/	23	155	64	31	54	55	JK
12N	561	561	560	562	567	458	/	/	/	/	495	/	/	76	/	/	/	/	23	155	64	31	54	55	JK
IPM	562	562	561	564	567	459	/	/	/	/	496	/	/	77	/	/	/	/	23	155	64	31	54	55	JK
2	565	565	564	567	570	460	/	/	/	/	498	/	/	78	/	/	/	/	23	155	64	31	54	55	JK
3	570	570	568	572	575	463	/	/	/	/	501	/	/	79	/	/	/	/	23	155	63	31	53	54	JK
4	571	571	569	574	577	464	/	/	/	/	503	/	/	80	/	/	/	/	23	155	63	31	53	54	JK
5	572	572	571	575	578	465	/	/	/	/	505	/	/	80	/	/	/	/	23	155	63	31	53	54	JK
6	573	573	572	575	578	465	/	/	/	/	505	/	/	79	/	/	/	/	23	155	63	31	53	54	JK
7	579	579	572	576	579	462	/	/	/	/	505	/	/	78	/	/	/	/	23	155	63	31	53	54	JK
8	561	561	560	562	566	457	/	/	/	/	494	/	/	77	/	/	/	/	23	155	63	31	53	54	JK
9	554	554	553	557	559	454	/	/	/	/	491	/	/	76	/	/	/	/	23	155	63	31	53	54	JK
10	555	555	553	557	559	454	/	/	/	/	491	/	/	76	/	/	/	/	23	155	63	31	53	54	JK
11	554	554	553	556	559	452	/	/	/	/	490	/	/	76	/	/	/	/	23	155	63	31	53	54	JK

General Notes:



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 4-18-23



Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp. From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (T)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (G)	Oil Tank Level	Oil Level: Ok in A-Box Oil Pump Yes / No - Add If Needed	Incoming Gas Press.	Kilowatts	Reading Taken By:
12M		3600	72	106	136	156	116		138	152	168		176		N/A	1/2	Yes	179	3000	No
1AM		3600	72	106	136	156	116		138	150	158		176		N/A	1/2	Yes	178	2800	No
2		3600	68	104	136	156	114		138	150	158		176		N/A	1/2	Yes	178	2820	No
3		3600	68	106	136	156	116		138	150	158		176		N/A	1/2	Yes	178	2800	No
4		3600	68	106	136	156	116		138	150	158		176		N/A	1/2	Yes	178	2800	No
5		3600	68	106	136	156	116		138	160	158		176		N/A	1/2	Yes	178	3000	No
6		3600	68	106	136	156	116		138	160	158		176		N/A	1/2	Yes	188	3600	No
7		3613	62	106	136	156	116		138	150	158		174		N/A	1/2	Yes	177	3900	a h
8		3619	66	106	136	156	116		138	150	158		174		N/A	1/2	Yes	178	3000	a ll
9		3619	70	106	136	156	116		138	151	159		176		N/A	1/2	Yes	179	3000	a ll
10		3619	72	106	136	156	116		138	151	159		176		N/A	1/2	Yes	178	3000	a ll
11		3619	76	106	136	158	116		140	154	160		178		N/A	1/2	Yes	177	3000	a ll
12N		3621	78	106	136	158	116		140	155	160		178		N/A	1/2	Yes	179	2700	a ll
1PM		3622	80	106	136	158	116		140	155	160		180		N/A	1/2	Yes	178	2700	a h
2		3622	80	106	136	158	118		140	155	160		180		N/A	1/2	Yes	178	2600	a ll
3		3622	80	106	136	158	118		140	155	160		180		N/A	1/2	Yes	178	2600	Deters
4		3622	80	106	136	158	118		140	155	160		180		N/A	1/2	Yes	178	2600	Deters
5		3622	80	106	136	158	118		140	155	160		180		N/A	1/2	Yes	178	2600	Deters
6		3622	80	106	136	158	118		140	155	160		180		N/A	1/2	Yes	178	2600	Deters
7		3620	80	106	136	158	118		140	155	160		180		N/A	1/2	Yes	179	2800	Deters
8		3621	80	106	136	158	118		140	155	160		180		N/A	1/2	Yes	179	2800	Deters
9		3618	80	106	136	158	118		140	155	160		180		N/A	1/2	Yes	179	3100	Deters
10		3618	80	106	136	158	118		140	155	160		180		N/A	1/2	Yes	179	3100	Deters
11		3600	72	106	136	158	118		140	155	160		176		N/A	1/2	Yes	178	3200	No

General Notes:



Side Two

# Sewerage and Water Board of New Orleans

## #5 Turbine Log

Date: 4-18-23



Time	Point No. 1 Exhaust Temp	Point No. 2 Exhaust Temp	Point No. 4 Exhaust Temp	Point No. 5 Exhaust Temp	Point No. 6 Exhaust Temp	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd	Point No. 10 1st Stage Wheel-Fwd	Point No. 11 1st Stage Wheel-Fwd	Point No. 12 1st Stage Wheel-Fwd	Point No. 20 2nd Stage Wheel-Alt	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Temp	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Fuel Oil Motor Outlet	Lube Oil Brig. Header	Lube Oil Pump Disch.	Compress. Discharge	Temp. Relay Outlet	Exhaust Exhaust Left	Exhaust Exhaust Right	
12M	554	554	552	555	558	462					490			78					23	155	63	31	54	55	No
1AM	540	591	540	593	596	446					481			78					23	155	63	31	54	55	No
2	640	591	540	593	596	446					481			78					23	155	63	31	54	55	No
3	639	539	542	544	548	444					478			78					23	155	63	31	54	55	No
4	639	539	542	544	548	444					478			78					23	155	63	31	54	55	No
5	637	535	536	539	542	440					476			78					23	155	63	31	54	55	No
6	537	535	535	539	542	440					476			78					23	155	63	31	54	55	No
7	557	557	557	560	565	445					489			68					23	155	64	31	54	55	a d
8	555	555	555	557	560	452					487			69					23	155	64	31	54	55	a d
9	558	558	556	560	564	454					490			70					23	155	64	31	54	55	a d
10	564	564	563	566	570	460					494			73					23	155	63	31	54	54	a d
11	568	568	566	570	573	462					498			76					23	155	63	31	54	55	a d
12N	562	562	562	564	566	461					497			78					23	155	63	31	54	55	a d
1PM	563	563	562	565	567	462					497			80					23	155	63	31	54	55	a d
2	562	562	561	564	566	467					496			80					23	155	63	31	54	55	Deters
3	562	562	561	564	566	461					496			80					23	155	63	31	54	55	Deters
4	560	560	558	562	564	460					495			80					23	155	63	31	54	55	Deters
5	558	558	557	560	562	459					492			80					23	155	63	31	54	55	Deters
6	557	557	556	560	562	460					492			80					23	155	63	31	54	55	Deters
7	561	561	560	563	566	459					493			80					23	155	63	31	54	55	Deters
8	559	559	558	562	564	457					493			80					23	155	63	31	54	55	Deters
9	563	563	562	565	568	456					494			80					23	155	63	31	54	55	Deters
10	564	564	562	566	569	456					494			80					23	155	63	31	54	55	No
11	560	560	559	563	566	454					492			76					23	155	63	31	54	55	No

General Notes:



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

19

Date: 4-11-23



Time	Run Hours	Speed / rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (3T)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (C)	Oil Tank Level	Oil Level Ok. In Adv. Oil Pump Yes / No - add if needed	Incoming Gas Press.	Kilowatts	Reading Taken By:
12M		3600	72	106	136	156	178		138	156	160		178		N/A	1/2	Yes	179	3200	Ja
1AM		3600	72	106	136	156	178		138	156	160		178		N/A	1/2	Yes	179	3200	Ja
2		3600	72	106	136	156	178		138	156	160		178		N/A	1/2	Yes	179	3000	Ja
3		3600	72	106	136	156	178		138	156	160		178		N/A	1/2	Yes	179	3000	Ja
4		3600	72	106	136	156	178		138	156	160		178		N/A	1/2	Yes	179	3100	Ja
5		3600	72	106	136	156	178		138	156	160		178		N/A	1/2	Yes	179	3100	Ja
6		3600	72	106	136	156	178		138	156	160		178		N/A	1/2	Yes	179	3100	Ja
7		3621	70	106	136	156	118		138	155	160		176		NA	1/2	Yes	179	2600	a ll
8		3621	72	106	136	156	118		136	155	160		176		NA	1/2	Yes	179	2600	a ll
9		3621	74	106	136	156	116		136	153	160		176		NA	1/2	Yes	179	2600	a ll
10		3621	75	106	136	156	116		136	153	160		176		NA	1/2	Yes	179	2600	a ll
11		3620	77	106	136	156	116		136	155	160		176		NA	1/2	Yes	179	2600	a ll
12N		3619	78	106	136	156	116		136	155	160		176		NA	1/2	Yes	179	2800	a ll
1PM		3621	79	106	136	156	116		136	155	160		177		NA	1/2	Yes	179	2600	a ll
2		362	80	106	136	156	116		136	156	160		177		NA	2/2	Yes	179	2600	a ll
3		3620	80	106	136	156	116		136	155	160		177		N/A	1/2	Yes	179	2700	D. Peters
4		3615	80	106	136	156	116		136	155	160		177		N/A	1/2	Yes	179	3400	D. Peters
5		3621	80	106	136	156	116		136	155	160		177		N/A	1/2	Yes	179	2800	D. Peters
6		3621	80	106	136	156	116		136	155	160		177		N/A	1/2	Yes	179	2800	D. Peters
7		3616	80	106	136	156	116		136	155	160		177		N/A	1/2	Yes	179	3300	D. Peters
8		3617	80	106	136	156	116		136	155	160		177		N/A	1/2	Yes	179	3300	D. Peters
9		3617	80	106	136	156	116		136	155	160		177		N/A	1/2	Yes	179	3300	D. Peters
10		3616	80	106	136	156	116		136	155	160		177		N/A	1/2	Yes	179	3300	D. Peters
11		3600		106	136	156	116		136	156	160		178		N/A	1/2	Yes	178	3300	Ja

General Notes:



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log

19

Date: 4-23



Time	Point No. 1 Inlet Temp.	Point No. 2 Inlet Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel Fwd.	Point No. 10 1st Stage Wheel Fwd.	Point No. 11 1st Stage Wheel Fwd.	Point No. 12 1st Stage Wheel Fwd.	Point No. 20 2nd Stage Wheel-AT	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M	560	560	559	563	564	454	/	/	/	/	492	/	/	76	/	/	/	23	155	63	31	54	55	Ho
1AM	560	560	559	563	566	454	/	/	/	/	492	/	/	76	/	/	/	23	155	63	31	54	55	Ho
2	560	560	559	563	566	454	/	/	/	/	492	/	/	76	/	/	/	23	155	63	31	54	55	Ho
3	556	556	555	558	561	452	/	/	/	/	489	/	/	76	/	/	/	23	155	63	31	54	55	Ho
4	556	556	555	558	561	452	/	/	/	/	489	/	/	76	/	/	/	23	155	63	31	54	55	Ho
5	545	544	544	547	550	451	/	/	/	/	483	/	/	76	/	/	/	23	155	63	31	54	55	Ho
6	545	544	544	547	550	451	/	/	/	/	483	/	/	76	/	/	/	23	155	63	31	54	55	Ho
7	545	545	544	547	550	451	/	/	/	/	483	/	/	74	/	/	/	23	150	63	31	54	55	Ho
8	548	548	548	551	552	452	/	/	/	/	484	/	/	74	/	/	/	23	150	63	31	54	55	Ho
9	555	555	557	556	559	457	/	/	/	/	488	/	/	76	/	/	/	22	150	63	31	54	55	Ho
10	558	558	557	561	564	461	/	/	/	/	490	/	/	77	/	/	/	23	150	63	31	54	55	Ho
11	567	567	562	566	569	463	/	/	/	/	494	/	/	78	/	/	/	23	150	63	31	54	55	Ho
12N	570	570	569	577	578	465	/	/	/	/	499	/	/	79	/	/	/	23	150	63	31	54	55	Ho
1PM	568	568	567	569	572	465	/	/	/	/	498	/	/	80	/	/	/	23	150	63	31	54	55	Ho
2	567	567	566	570	572	465	/	/	/	/	498	/	/	80	/	/	/	23	150	63	31	54	55	Ho
3	572	572	571	578	577	467	/	/	/	/	500	/	/	80	/	/	/	23	150	63	31	54	55	DP
4	587	587	586	590	593	469	/	/	/	/	511	/	/	80	/	/	/	23	150	63	31	54	55	DP
5	569	569	568	571	574	465	/	/	/	/	500	/	/	80	/	/	/	23	150	63	31	54	55	DP
6	569	569	568	572	574	464	/	/	/	/	500	/	/	80	/	/	/	23	150	63	31	54	55	DP
7	574	573	572	578	578	463	/	/	/	/	502	/	/	80	/	/	/	23	150	63	31	54	55	DP
8	573	573	572	575	579	460	/	/	/	/	502	/	/	80	/	/	/	23	150	63	31	54	55	DP
9	573	573	572	575	579	460	/	/	/	/	501	/	/	80	/	/	/	23	150	63	31	54	55	DP
10	573	573	571	575	578	459	/	/	/	/	501	/	/	80	/	/	/	23	150	63	31	54	55	DP
11	571	571	569	572	576	467	/	/	/	/	500	/	/	80	/	/	/	23	150	63	31	54	55	Ho

General Notes:



Side One

# Sewerage and Water Board of New Orleans

## #5 Turbine Log

Date: 4-20-23



Time	Rur. Hours	Speed / RPM	Ambient Temp.	Oil Temp from Cooler	No. 1 Eng. Temp.	No. 2 Eng. Temp.	No. 2 Thrust Temp.	No. 3 Eng. Temp.	No. 4 Eng. Temp.	Pinion Eng. No. 1 Temp.	Pinion Eng. No. 2 Temp.	Gear Brz. No. 3 Temp.	Gear Brz. Thrust (21)	Gear Brz. No. 4 Temp.	Generator Big. Temp. (G)	Oil Tank Level	Oil Level OK In Aux. Oil Pump No. 1/No. 2/OK/Drained	Incoming Gas Press.	Kilowatts	Reading Taken By:
12M		3600	72	100	136	156	116		136	196	160	/	178		N/A	1/2	Yes	178	3300	St
1AM		3600	77	106	136	156	116		136	156	160	/	178		N/A	1/2	Yes	178	3200	St
2		3600	72	106	136	156	114		136	156	160	/	178		N/A	1/2	Yes	178	3000	St
3		3600	72	106	136	156	116		136	156	160	/	178		N/A	1/2	Yes	178	3000	St
4		3600	72	106	136	156	114		136	156	160	/	178		N/A	1/2	Yes	178	2800	St
5		3600	72	106	136	156	116		136	156	160	/	178		N/A	1/2	Yes	178	2800	St
6		3600	72	106	136	156	116		136	156	160	/	178		YA	1/2	Yes	179	2600	a ER
7		3622	73	106	136	156	116		138	155	160	/	178		YA	1/2	Yes	179	2600	a ER
8		3622	74	106	136	156	116		138	155	160	/	178		YA	1/2	Yes	178	2600	a ER
9		3622	76	106	136	156	116		138	155	160	/	178		YA	1/2	Yes	178	2600	a ER
10		3622	78	106	136	156	116		138	155	162	/	180		YA	1/2	Yes	178	1300	a ER
11		3631	80	106	136	156	116		138	155	162	/	180		YA	1/2	Yes	178	1700	a ER
12N		3631	83	106	136	156	116		138	155	162	/	180		YA	1/2	Yes	178	1400	a ER
1PM		3631	85	106	136	156	116		142	156	164	/	180		YA	1/2	Yes	178	1400	a ER
2		3631	80	106	136	156	118		142	156	164	/	180		N/A	1/2	Yes	178	2600	3631-3638
3		3632	80	106	136	156	118		142	156	164	/	180		N/A	1/2	Yes	178	2600	
4		3632	80	106	136	156	118		142	156	164	/	180		N/A	1/2	Yes	178	2700	
5		3631	83	106	135	158	118		142	157	163	/	180		N/A	1/2	Yes	178	2700	
6		3631	83	106	135	158	118		142	157	163	/	180		N/A	1/2	Yes	178	2700	
7		3631	83	106	135	158	118		142	157	163	/	180		N/A	1/2	Yes	178	2900	
8		3619	83	106	135	158	118		142	157	163	/	180		N/A	1/2	Yes	178	3100	
9		3619	83	106	135	158	118		142	157	163	/	180		N/A	1/2	Yes	178	3100	
10		3619	83	106	135	158	118		142	157	163	/	180		N/A	1/2	Yes	178	3100	
11		3618	83	106	135	158	118		142	157	163	/	180		N/A	1/2	Yes	178	3100	

General Notes:



Side Two

Sewerage and Water Board of New Orleans  
#5 Turbine Log



Date: 4-20-23

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Aft	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Reisy Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M	571	571	569	573	576	458	/	/	/	/	500	/	/	78	/	/	/	/	23	155	63	31	54	55	the
1AM	571	571	569	573	576	458	/	/	/	/	500	/	/	78	/	/	/	/	23	155	63	31	54	55	the
2	560	560	564	566	568	459	/	/	/	/	492	/	/	78	/	/	/	/	23	155	63	31	54	55	the
3	560	560	564	566	568	459	/	/	/	/	492	/	/	78	/	/	/	/	23	155	63	31	54	55	the
4	560	560	564	566	568	459	/	/	/	/	492	/	/	78	/	/	/	/	23	155	63	31	54	55	the
5	555	555	559	558	561	460	/	/	/	/	489	/	/	78	/	/	/	/	23	155	63	31	54	55	the
6	555	555	559	558	561	460	/	/	/	/	489	/	/	78	/	/	/	/	23	155	63	31	54	55	the
7	553	553	552	555	558	465	/	/	/	/	487	/	/	78	/	/	/	/	23	150	63	31	53	54	~ 22
8	554	555	554	557	560	456	/	/	/	/	488	/	/	78	/	/	/	/	23	150	63	31	53	54	~ 22
9	561	561	561	564	567	461	/	/	/	/	491	/	/	78	/	/	/	/	23	150	63	31	53	54	~ 22
10	562	563	562	566	568	462	/	/	/	/	494	/	/	79	/	/	/	/	23	150	63	31	53	54	~ 22
11	535	535	535	538	540	462	/	/	/	/	479	/	/	80	/	/	/	/	23	150	60	31	53	54	~ 22
12N	536	536	536	538	541	462	/	/	/	/	479	/	/	81	/	/	/	/	23	150	60	31	53	54	~ 22
1PM	541	541	540	543	545	467	/	/	/	/	461	/	/	82	/	/	/	/	23	153	60	31	53	54	~ 22
2	542	543	542	545	548	467	/	/	/	/	487	/	/	83	/	/	/	/	23	153	60	31	53	54	~ 22
3	573	573	573	576	579	469	/	/	/	/	501	/	/	83	/	/	/	/	23	153	60	31	53	54	O.P.
4	574	574	573	576	578	469	/	/	/	/	501	/	/	83	/	/	/	/	23	153	60	31	53	54	O.P.
5	574	575	574	577	580	467	/	/	/	/	502	/	/	83	/	/	/	/	23	153	60	31	53	54	O.P.
6	573	573	573	576	579	468	/	/	/	/	502	/	/	83	/	/	/	/	23	153	60	31	53	54	O.P.
7	571	571	570	574	576	465	/	/	/	/	501	/	/	83	/	/	/	/	23	153	60	31	53	54	O.P.
8	571	571	570	574	576	465	/	/	/	/	501	/	/	83	/	/	/	/	23	153	60	31	53	54	O.P.
9	573	573	572	575	578	461	/	/	/	/	501	/	/	83	/	/	/	/	23	153	60	31	53	54	O.P.
10	572	573	572	575	578	461	/	/	/	/	500	/	/	83	/	/	/	/	23	153	60	31	53	54	O.P.
11	572	573	572	575	578	462	/	/	/	/	500	/	/	83	/	/	/	/	23	153	60	31	53	54	O.P.

General Notes:



3620

# Sewerage and Water Board of New Orleans

## No. 1 Turbine Log

Date 4/11/23



Time	Ram Revolts	Speed Rpm	Amphibian Thrust	Oil Temp From Cooler	No. 1 Eng. Temp	No. 2 Eng. Temp	No. 2 Thrust Temp	No. 3 Eng. Temp	No. 4 Eng. Temp	Turbine No. 1 Temp	Piston No. 2 Temp	Crank No. 3 Temp	Gen. No. 4 Temp	Gen. No. 4 Temp	Superheating Eng. Temp	Oil Temp Level	Oil Level Ok to Aux. Oil Pump Yes/No	Abbr. No.	Incoming Gas Press.	Pressure	Reading Taken By
12M		3618	76	106	135	158	118		142	157	163	/	180		N/A	7/16	Yes	178	3200		DP
1AM		3618	76	106	135	158	118		142	157	163	/	180		N/A	7/16	Yes	178	3200		DP
2		3618	76	106	135	158	118		142	157	163	/	180		N/A	7/16	Yes	178	3200		DP
3		3618	76	106	135	158	118		142	157	163	/	180		N/A	7/16	Yes	178	3200		DP
4		3619	76	106	135	158	118		142	157	163	/	180		N/A	7/16	Yes	178	3200		DP
5		3619	76	106	135	158	118		142	157	163	/	180		N/A	7/16	Yes	178	3200		DP
6		3620	76	106	135	158	118		142	157	163	/	180		N/A	7/16	Yes	178	2900		DP
7		3622	74	106	136	156	116		140	155	160	/	178		4/1	1/2	Yes	178	2600		DP
8		3622	74	106	136	156	116		140	155	160	/	178		4/1	1/2	Yes	178	2700		DP
9		3620	74	106	136	156	116		140	155	160	/	178		4/1	1/2	Yes	178	3200		DP
10		3616	74	106	136	156	116		140	155	160	/	178		4/1	1/2	Yes	178	2700		DP
11		3619	74	106	136	156	116		140	155	160	/	178		4/1	1/2	Yes	178	2600		DP
12N		3621	75	106	136	156	116		140	155	160	/	178		4/1	1/2	Yes	179	3000		DP
1PM		3619	76	106	136	156	116		140	155	160	/	178		4/1	1/2	Yes	178	3000		DP
2		3620	80	106	136	156	116		140	155	160	/	178		4/1	7/16	Yes	178	3200		DP
3		3618	80	106	136	156	116		140	155	160	/	178		4/1	7/16	Yes	178	3200		DP
4		3618	80	106	136	156	116		140	155	160	/	178		4/1	7/16	Yes	178	3200		DP
5		3618	80	106	136	156	116		140	155	160	/	178		4/1	7/16	Yes	178	3200		DP
6		3620	80	106	136	156	116		140	155	160	/	178		4/1	7/16	Yes	178	3200		DP
7		3620	80	106	136	156	116		140	155	160	/	178		4/1	7/16	Yes	178	3200		DP
8		3620	80	106	136	156	116		140	155	160	/	178		4/1	7/16	Yes	178	3200		DP
9		3620	80	106	136	156	116		140	155	160	/	178		4/1	7/16	Yes	178	3200		DP
10		3620	80	106	136	156	116		140	155	160	/	178		4/1	1/2	Yes	178	3200		DP
11		3619	78	106	136	156	116		140	155	160	/	178		4/1	1/2	Yes	178	3200		DP

General Notes:



#5 Turbine Log

Date: 4/2/23



Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 6 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Fwd.	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brg. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Left	Exhaust Detector Right	
12M	573	573	572	575	579	460	/	/	/	/	501	/	/	83	/	/	/	/	23	153	60	31	53	54	DP
1AM	573	573	572	576	579	461	/	/	/	/	501	/	/	83	/	/	/	/	23	153	60	31	53	54	DP
2	574	574	573	576	579	461	/	/	/	/	501	/	/	83	/	/	/	/	23	153	60	31	53	54	DP
3	574	574	575	576	579	461	/	/	/	/	500	/	/	83	/	/	/	/	23	153	60	31	53	54	DP
4	562	562	563	565	568	456	/	/	/	/	493	/	/	83	/	/	/	/	23	153	60	31	53	54	DP
5	562	562	562	565	568	456	/	/	/	/	492	/	/	83	/	/	/	/	23	153	60	31	53	54	DP
6	562	563	562	565	568	457	/	/	/	/	494	/	/	83	/	/	/	/	23	153	60	31	53	54	DP
7	557	554	557	557	559	457	/	/	/	/	489	/	/	79	/	/	/	/	23	153	60	31	53	54	DP
8	556	557	557	560	563	458	/	/	/	/	490	/	/	79	/	/	/	/	27	152	60	31	53	54	DP
9	562	561	562	565	568	459	/	/	/	/	493	/	/	79	/	/	/	/	27	153	60	31	53	54	DP
10	574	574	573	576	579	461	/	/	/	/	492	/	/	79	/	/	/	/	27	153	60	31	53	54	DP
11	559	559	559	562	565	456	/	/	/	/	493	/	/	79	/	/	/	/	27	153	60	31	53	54	DP
12N	555	556	556	558	561	455	/	/	/	/	489	/	/	79	/	/	/	/	23	152	60	31	53	54	DP
1PM	564	564	567	567	570	457	/	/	/	/	493	/	/	80	/	/	/	/	27	157	60	31	53	54	DP
2	72	73	71	75	78	462	/	/	/	/	492	/	/	80	/	/	/	/	27	157	60	71	57	54	DP
3	581	581	580	584	587	467	/	/	/	/	505	/	/	80	/	/	/	/	23	153	60	31	53	54	DP
4	585	583	584	586	589	467	/	/	/	/	508	/	/	80	/	/	/	/	23	153	60	31	53	54	DP
5	585	583	584	588	591	469	/	/	/	/	510	/	/	80	/	/	/	/	23	153	60	31	53	54	DP
6	574	574	574	577	580	465	/	/	/	/	505	/	/	80	/	/	/	/	23	153	60	31	53	54	DP
7	573	573	573	576	579	465	/	/	/	/	503	/	/	80	/	/	/	/	23	153	60	31	53	54	DP
8	574	574	574	577	580	469	/	/	/	/	503	/	/	80	/	/	/	/	23	153	60	31	53	54	DP
9	573	572	572	575	578	463	/	/	/	/	501	/	/	80	/	/	/	/	23	153	60	31	53	54	DP
10	572	572	571	574	577	462	/	/	/	/	501	/	/	80	/	/	/	/	23	153	60	31	53	54	DP
11	566	566	565	569	572	457	/	/	/	/	496	/	/	80	/	/	/	/	23	153	60	31	53	54	DP

General Notes:



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 4-22-23



Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp. from Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 3 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Pinion Brg. No. 1 Temp.	Pinion Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust (3T)	Gear Brg. No. 4 Temp.	Generator Brg. Temp. (C)	Oil Tank Level	Oil Level Ok. In Adv. Oil Pump. Yes/No. duff/L/Normal	Incoming Gas Press.	Kilowatts	Reading Taken By:
12M		3620	74	106	136	156	116		140	155	160		178		0.41	1/2	Yes	178	3000	duff
1AM		3620	74	106	136	156	116		140	154	160		178		0.41	1/2	Yes	178	3000	duff
2		3620	74	106	136	156	116		140	154	160		178		0.41	1/2	Yes	177	3000	duff
3		3620	73	106	136	156	116		140	155	160		178		0.41	1/2	Yes	179	3000	duff
4		3620	72	106	136	156	116		140	155	160		178		0.41	1/2	Yes	179	3000	duff
5		3620	71	106	136	156	116		140	155	160		178		0.41	1/2	Yes	178	3000	duff
6		3620	70	106	136	156	116		140	155	160		178		0.41	1/2	Yes	178	2900	duff
7		3618	70	106	136	156	116		140	152	160		178		0.41	1/2	Yes	179	3200	duff
8		3618	72	106	136	156	116		140	153	160		178		0.41	1/2	Yes	177	3200	duff
9		3618	74	106	136	156	116		140	153	160		178		0.41	1/2	Yes	178	3200	duff
10		3619	76	106	136	156	116		140	154	160		178		0.41	1/2	Yes	178	3000	duff
11		3620	78	106	136	156	116		140	155	160		178		0.41	1/2	Yes	177	2900	duff
12N		3620	80	106	136	156	116		140	155	160		178		0.41	1/2	Yes	178	2900	duff
1PM		3621	80	106	136	156	116		140	155	160		178		0.41	1/2	Yes	177	2800	duff
2		3621	80	106	136	156	116		140	155	160		178		0.41	1/2	Yes	178	2800	duff
3		3621	80	106	136	156	116		140	155	160		178		0.41	2/16	Yes	178	2800	Duff Duff Duff Duff Duff Duff Duff Duff Duff Duff Duff
4		3621	80	106	136	156	116		140	155	160		178		0.41	2/16	Yes	178	2800	
5		3620	80	106	136	156	116		140	155	160		178		0.41	2/16	Yes	178	3000	
6		3620	80	106	136	156	116		140	155	160		178		0.41	2/16	Yes	178	3000	
7		3620	80	106	136	156	116		140	155	160		178		0.41	2/16	Yes	178	3000	
8		3622	80	106	136	156	116		140	155	160		178		0.41	2/16	Yes	178	2800	
9		3621	80	106	136	156	116		140	155	160		178		0.41	2/16	Yes	178	2800	
10		3622	80	106	136	156	116		140	155	160		178		0.41	2/16	Yes	178	2800	
11		3600	80	106	136	156	116		140	155	160		178		0.41	2/16	Yes	178	2800	

General Notes:



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log



Date: 4-22-27

Time	Point No. 1 Exhaust Temp.	Point No. 2 Exhaust Temp.	Point No. 4 Exhaust Temp.	Point No. 5 Exhaust Temp.	Point No. 9 Exhaust Temp.	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel-Fwd.	Point No. 10 1st Stage Wheel-Fwd.	Point No. 11 1st Stage Wheel-Fwd.	Point No. 12 1st Stage Wheel-Fwd.	Point No. 20 2nd Stage Wheel-Fwd.	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brig. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Exhaust Detector Lup	Exhaust Detector Right	
12M	564	564	563	567	570	456	/	/	/	/	495	/	/	78	/	/	/	/	23	153	60	31	53	54	a ll
1AM	562	562	561	565	568	455	/	/	/	/	493	/	/	78	/	/	/	/	23	153	60	31	53	54	a ll
2	564	564	563	566	570	457	/	/	/	/	494	/	/	78	/	/	/	/	23	153	60	31	53	54	a ll
3	561	562	561	564	567	456	/	/	/	/	493	/	/	78	/	/	/	/	23	153	60	31	53	54	a ll
4	558	558	557	561	564	453	/	/	/	/	492	/	/	78	/	/	/	/	23	153	60	31	53	54	a ll
5	557	557	556	560	563	454	/	/	/	/	492	/	/	78	/	/	/	/	23	153	60	31	53	54	a ll
6	554	555	554	557	560	454	/	/	/	/	490	/	/	77	/	/	/	/	23	153	60	31	53	54	a ll
7	561	561	560	564	567	453	/	/	/	/	494	/	/	77	/	/	/	/	23	153	60	31	53	54	a ll
8	561	561	560	563	567	455	/	/	/	/	494	/	/	77	/	/	/	/	23	153	60	31	53	54	a ll
9	566	567	566	569	572	454	/	/	/	/	493	/	/	78	/	/	/	/	23	153	60	31	53	54	a ll
10	566	567	565	569	571	460	/	/	/	/	492	/	/	78	/	/	/	/	23	153	60	31	53	54	a ll
11	565	566	565	568	572	461	/	/	/	/	492	/	/	79	/	/	/	/	23	153	60	31	53	54	a ll
12N	565	565	565	568	571	462	/	/	/	/	498	/	/	80	/	/	/	/	23	153	60	31	53	54	a ll
1PM	567	567	567	570	573	463	/	/	/	/	500	/	/	80	/	/	/	/	23	153	60	31	53	54	a ll
2	570	570	569	573	576	465	/	/	/	/	507	/	/	80	/	/	/	/	23	152	62	31	53	54	DP
3	570	570	570	573	576	466	/	/	/	/	502	/	/	80	/	/	/	/	23	152	62	31	53	54	DP
4	572	573	573	576	579	467	/	/	/	/	504	/	/	80	/	/	/	/	23	152	62	31	53	54	DP
5	577	577	576	580	583	469	/	/	/	/	506	/	/	80	/	/	/	/	23	152	62	31	53	54	DP
6	578	579	578	581	584	470	/	/	/	/	507	/	/	80	/	/	/	/	23	152	62	31	53	54	DP
7	576	577	576	579	582	467	/	/	/	/	507	/	/	80	/	/	/	/	23	152	62	31	53	54	DP
8	566	567	567	570	573	464	/	/	/	/	502	/	/	80	/	/	/	/	23	152	62	31	53	54	DP
9	562	562	562	565	568	462	/	/	/	/	498	/	/	80	/	/	/	/	23	152	62	31	53	54	DP
10	562	562	561	566	568	462	/	/	/	/	498	/	/	80	/	/	/	/	23	152	62	31	53	54	DP
11	553	553	553	556	559	455	/	/	/	/	491	/	/	80	/	/	/	/	23	152	62	31	53	54	DP

General Notes:



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 4/23/23



Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp from Cooler	No.1 Brg. Temp.	No.2 Brg. Temp.	No. 2 Thrust Temp.	No.3 Brg. Temp.	No.4 Brg. Temp.	Pinion Brg. No.1 Temp.	Pinion Brg. No.2 Temp.	Gear Brg. No.3 Temp.	Gear Brg. Thrust(3T)	Gear Brg. No.4 Temp.	Generator Brg. Temp.(G)	Oil Tank Level	Oil Level Ok In Aux. Oil Pump Yes/No - Add If Needed	Incoming Gas Press.	Kilowatts	Reading Taken By:
12M		3000	70	106	136	156	116	140	155	160	178	178	41%	7/16	Yes	178	2800			
1AM		3600	70	106	136	156	116	140	155	160	178	178	41	7/16	Yes	178	3100			
2		3600	76	106	136	156	116	140	155	160	178	178	41	7/16	Yes	178	3100			
3		3600	70	106	136	156	116	140	155	160	178	178	41	7/16	Yes	178	3100			
4		3600	70	106	136	156	116	140	155	160	178	178	41	7/16	Yes	178	3000			
5		3600	70	106	136	156	116	140	155	160	178	178	41	7/16	Yes	178	2800			
6		3600	70	106	136	156	116	140	155	160	178	178	41	7/16	Yes	178	2700			
7		3600	74	106	136	156	116	140	155	160	178	178	41	7/16	Yes	178	2800			
8		3600	74	106	136	156	116	140	155	160	178	178	41	7/16	Yes	178	2800			
9		3600	74	106	136	156	116	140	155	160	178	178	41	7/16	Yes	178	2800			
10		3600	74	106	136	156	116	140	155	160	178	178	41	7/16	Yes	178	2800			
11		3600	74	106	136	156	116	140	155	160	178	178	41	7/16	Yes	178	2800			
12N		3600	74	104	136	156	116	140	155	160	178	178	41	7/16	Yes	178	2800			
1PM		3600	74	106	136	156	116	140	155	160	178	178	41	7/16	Yes	178	2700			
2		3600	74	106	136	156	116	140	155	160	178	178	41	7/16	Yes	178	2700			
3		3600	74	106	136	156	116	140	155	160	178	178	41	7/16	Yes	178	2800			
4		3621	74	106	136	156	116	140	155	160	178	178	41	7/16	Yes	178	2800			
5		3621	74	106	136	156	116	140	155	160	178	178	41	7/16	Yes	178	2800			
6		3619	74	106	136	156	116	140	155	160	178	178	41	7/16	Yes	178	3000			
7		3616	75	106	136	156	116	140	155	160	178	178	41	7/16	Yes	178	3500			
8		3616	75	106	136	158	117	140	155	160	180	180	41	7/16	Yes	178	3500			
9		3617	75	106	136	158	117	140	155	160	180	180	41	7/16	Yes	178	3500			
10		3616	75	106	136	158	117	140	155	160	180	180	41	7/16	Yes	178	3500			
11		3610	71	100	130	158	117	140	155	160	180	180	41	7/16	Yes	178	3500		E.E.	

General Notes:



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log



Date: 4/23/23

Time	Point No. 1 Exhaust Temp	Point No. 2 Inhaust Temp	Point No. 4 Inhaust Temp	Point No. 5 Exhaust Temp	Point No. 6 Exhaust Temp	Point No. 8 Comp. Disch. Temp.	Point No. 9 1st Stage Wheel Fwd.	Point No. 10 1st Stage Wheel Fwd.	Point No. 11 1st Stage Wheel Fwd.	Point No. 17 1st Stage Wheel Fwd.	Point No. 20 2nd Stage Wheel - Air Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Brig. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Inhaust Disch. Left	Inhaust Disch. Right	
12M	552	552	552	556	558	494	/	/	/	/	490	/	76	/	/	/	/	23	153	60	31	53	54	No
1AM	552	552	552	556	558	494	/	/	/	/	490	/	76	/	/	/	/	23	153	60	31	53	54	No
2	559	559	559	562	560	494	/	/	/	/	494	/	76	/	/	/	/	23	153	60	31	53	54	No
3	559	559	559	562	560	494	/	/	/	/	494	/	76	/	/	/	/	23	153	60	31	53	54	No
4	559	559	559	562	560	494	/	/	/	/	494	/	76	/	/	/	/	23	153	60	31	53	54	No
5	578	579	578	581	589	484	/	/	/	/	484	/	76	/	/	/	/	23	153	60	31	53	54	No
6	578	579	578	581	589	484	/	/	/	/	484	/	76	/	/	/	/	23	153	60	31	53	54	No
7	557	558	557	560	563	491	/	/	/	/	491	/	76	/	/	/	/	23	153	60	31	53	54	No
8	557	558	557	560	563	491	/	/	/	/	491	/	76	/	/	/	/	23	153	60	31	53	54	No
9	562	563	562	565	568	496	/	/	/	/	496	/	76	/	/	/	/	23	153	60	31	53	54	No
10	562	563	562	565	568	496	/	/	/	/	496	/	76	/	/	/	/	23	153	60	31	53	54	No
11	564	564	566	568	570	498	/	/	/	/	498	/	76	/	/	/	/	23	153	60	31	53	54	No
12N	564	564	566	568	570	498	/	/	/	/	498	/	76	/	/	/	/	23	153	60	31	53	54	No
1PM	569	569	568	572	575	500	/	/	/	/	500	/	76	/	/	/	/	23	153	60	31	53	54	No
2	569	569	568	572	575	500	/	/	/	/	500	/	76	/	/	/	/	23	153	60	31	53	54	No
3	568	568	568	571	574	500	/	/	/	/	500	/	76	/	/	/	/	23	153	60	31	53	54	No
4	568	569	568	572	575	500	/	/	/	/	500	/	76	/	/	/	/	23	153	60	31	53	54	No
5	566	566	566	569	572	499	/	/	/	/	499	/	76	/	/	/	/	23	153	60	31	53	54	No
6	570	570	570	573	576	500	/	/	/	/	500	/	77	/	/	/	/	23	153	60	31	53	54	No
7	578	578	577	581	584	505	/	/	/	/	505	/	77	/	/	/	/	23	153	60	31	53	54	No
8	576	576	576	579	583	505	/	/	/	/	505	/	80	/	/	/	/	23	153	60	31	53	54	No
9	576	576	576	578	583	504	/	/	/	/	504	/	80	/	/	/	/	23	153	60	31	53	54	No
10	575	575	574	577	581	504	/	/	/	/	504	/	80	/	/	/	/	23	153	60	31	53	54	No
11	575	574	574	577	581	504	/	/	/	/	504	/	80	/	/	/	/	23	153	00	30 <sup>F</sup>	53	54	E.E.

General Notes:



Side One

Sewerage and Water Board of New Orleans

#5 Turbine Log

Date: 4-24-23



Time	Run Hours	Speed / Rpm	Ambient Temp.	Oil Temp From Cooler	No. 1 Brg. Temp.	No. 2 Brg. Temp.	No. 2 Thrust Temp.	No. 3 Brg. Temp.	No. 4 Brg. Temp.	Piston Brg. No. 1 Temp.	Piston Brg. No. 2 Temp.	Gear Brg. No. 3 Temp.	Gear Brg. Thrust(3T)	Gear Brg. No. 4 Temp.	Generator Brg. Temp.(G)	Oil Tank Level	Oil Level OK In A.x. Oil Pump Yes/No. Add/L/Standard	Incoming Gas Press.	Kilowatts	Reading Taken By:
12M	/	3020	70	100	130	158	117	/	140	155	100	/	180	/	41	7/10	yes	179	3000	E.E.
1AM	/	3021	69	100	135	158	118	/	140	155	100	/	180	/	41	7/10	yes	179	2900	E.E.
2	/	3021	69	100	135	157	117	/	140	154	100	/	179	/	41	7/10	yes	179	2900	E.E.
3	/	3020	69	105	135	157	117	/	139	154	100	/	180	/	41	7/10	yes	179	2900	E.E.
4	/	3020	69	106	135	157	117	/	139	154	100	/	180	/	41	7/10	yes	179	3000	E.E.
5	/	3021	70	100	135	156	117	/	139	153	158	/	179	/	41	7/10	yes	179	3100	E.E.
6	/	3021	68	106	134	156	117	/	138	153	158	/	179	/	41	7/10	yes	179	3100	E.E.
7	/	3000	68	106	136	158	116	/	138	152	159	/	176	/	41	7/16	Yes	179	2800	Jo
8	/	3000	68	106	136	158	116	/	138	152	159	/	176	/	41	7/16	Yes	179	2800	Jo
9	/	3000	68	106	136	158	116	/	138	152	159	/	176	/	41	7/16	Yes	178	2800	Jo
10	/	3000	68	106	136	158	116	/	138	152	159	/	176	/	41	7/16	Yes	179	2800	Jo
11	/	3000	70	106	136	158	116	/	138	152	159	/	176	/	41	7/16	Yes	179	2700	Jo
12N	/	3000	70	106	136	158	116	/	138	152	159	/	176	/	41	7/16	Yes	179	2700	Jo
1PM	/	3000	70	106	136	158	116	/	138	152	159	/	176	/	41	7/16	Yes	179	3200	Jo
2	/	3000	70	106	136	158	116	/	138	152	159	/	176	/	41	7/16	Yes	179	3200	Jo
3	/	3019	70	106	136	158	116	/	138	152	159	/	176	/	41	7/16	Yes	179	3000	Jo
4	/	3016	70	106	136	158	116	/	138	152	159	/	176	/	41	7/16	Yes	179	3200	Jo
5	/	3016	70	106	136	158	116	/	138	152	159	/	176	/	41	7/16	Yes	179	3000	Jo
6	/	3016	70	106	136	158	116	/	138	152	159	/	176	/	41	7/16	Yes	179	3000	Jo
7	/	3019	70	106	136	158	116	/	138	152	159	/	176	/	41	7/16	Yes	179	3100	Jo
8	/	3019	70	106	136	158	116	/	138	152	159	/	176	/	41	7/16	Yes	179	3000	Jo
9	/	3019	70	100	136	158	116	/	138	152	159	/	176	/	41	7/16	Yes	179	2900	Jo
10	/	3019	70	100	136	158	116	/	138	152	159	/	176	/	41	7/16	Yes	179	2900	Jo
11	/	3021	70	106	136	158	116	/	138	152	158	/	179	/	41	7/10	yes	178	2900	E.E.

General Notes:



Side Two

## Sewerage and Water Board of New Orleans #5 Turbine Log



Date: 4-24-23

Line	Point No. 1 Exhaust Temp	Point No. 2 Exhaust Temp	Point No. 4 Exhaust Temp	Point No. 5 Exhaust Temp	Point No. 6 Exhaust Temp	Point No. 8 Comp. Disch. Temp	Point No. 9 1st Stage Wheel-Feed	Point No. 10 1st Stage Wheel-Feed	Point No. 11 1st Stage Wheel-Feed	Point No. 12 1st Stage Wheel-Feed	Point No. 20 2nd Stage Wheel-Feed	Fuel Gas Before Stop Valve	Fuel Gas After Stop Valve	Fuel Oil Supply	Fuel Oil After Stop Valve	Fuel Oil After Filter	Hyd. Oil Motor Inlet	Hyd. Oil Motor Outlet	Lube Oil Ingr. Header	Lube Oil Pump Disch.	Compressor Discharge	Temp. Relay Outlet	Inlet Exhaust Left	Inlet Exhaust Right	
12M	575	576	574	576	580	400	/	/	/	/	503	/	79	/	/	/	/	/	23	152	00	31	53	54	EE
1AM	551	552	551	555	557	453	/	/	/	/	452	/	78	/	/	/	/	/	23	152	00	31	53	54	EE
2	551	551	551	556	557	451	/	/	/	/	487	/	78	/	/	/	/	/	23	152	00	30 <sup>F</sup>	53	54	EE
3	550	551	550	554	556	451	/	/	/	/	487	/	78	/	/	/	/	/	23	152	00	31	53	54	EE
4	550	551	550	554	556	451	/	/	/	/	486	/	76	/	/	/	/	/	23	152	00	31	53	54	EE
5	550	551	550	554	555	451	/	/	/	/	486	/	76	/	/	/	/	/	23	152	00	31	53	54	EE
6	545	546	545	548	551	450	/	/	/	/	484	/	74	/	/	/	/	/	23	152	59	31	53	55	EE
7	543	543	542	546	549	448	/	/	/	/	482	/	72	/	/	/	/	/	23	150	62	31	53	55	EE
8	543	543	542	546	549	448	/	/	/	/	482	/	72	/	/	/	/	/	23	156	62	31	53	55	EE
9	545	545	544	547	550	449	/	/	/	/	483	/	72	/	/	/	/	/	23	158	162	31	53	55	EE
10	545	545	544	547	550	449	/	/	/	/	483	/	72	/	/	/	/	/	23	156	162	31	53	55	EE
11	545	545	544	548	550	452	/	/	/	/	484	/	72	/	/	/	/	/	23	156	162	31	53	55	EE
12N	545	545	544	548	550	432	/	/	/	/	484	/	72	/	/	/	/	/	23	150	162	31	53	55	EE
1PM	563	563	562	566	570	457	/	/	/	/	484	/	72	/	/	/	/	/	23	150	162	31	53	55	EE
2	563	563	562	566	570	457	/	/	/	/	484	/	72	/	/	/	/	/	23	150	162	31	53	55	EE
3	564	565	564	568	571	459	/	/	/	/	497	/	72	/	/	/	/	/	23	150	162	31	53	55	DP
4	568	568	567	571	574	458	/	/	/	/	499	/	72	/	/	/	/	/	23	150	162	31	53	55	DP
5	562	561	561	565	567	457	/	/	/	/	495	/	72	/	/	/	/	/	23	150	162	31	53	55	DP
6	562	562	561	565	568	458	/	/	/	/	496	/	72	/	/	/	/	/	23	150	162	31	53	55	DP
7	563	564	563	566	569	458	/	/	/	/	495	/	72	/	/	/	/	/	23	150	162	31	53	55	DP
8	559	560	559	562	565	456	/	/	/	/	494	/	72	/	/	/	/	/	23	150	162	31	53	55	DP
9	557	557	556	560	563	455	/	/	/	/	493	/	72	/	/	/	/	/	23	150	162	31	53	55	DP
10	557	557	556	560	563	456	/	/	/	/	492	/	72	/	/	/	/	/	23	150	162	31	53	55	EE
11	557	557	556	560	563	455	/	/	/	/	490	/	72	/	/	/	/	/	23	150	162	31	53	55	EE

General Notes:



AI No.: 5673

AI Name: Sewerage & Water Board of New Orleans – Carrollton Water Purification Plant

Alt. ID/Permit No.: LAD981511850

Date of Inspection: 04/12/2023; 04/24/2023

## **ATTACHMENT 6**

### **Safety Data Sheet (MOBIL DTE 732)**



Product Name: MOBIL DTE 732  
Revision Date: 04 Aug 2020  
Page 1 of 10

## SAFETY DATA SHEET

### SECTION 1 PRODUCT AND COMPANY IDENTIFICATION

#### PRODUCT

**Product Name:** MOBIL DTE 732  
**Product Description:** Base Oil and Additives  
**Product Code:** 201560302015, 607200-00, 97AS85  
**Intended Use:** Turbine oil

#### COMPANY IDENTIFICATION

**Supplier:** EXXON MOBIL CORPORATION  
22777 Springwoods Village Parkway  
Spring, TX 77389 USA

**24 Hour Health Emergency** 609-737-4411  
**Transportation Emergency Phone** 800-424-9300 or 703-527-3887 CHEMTREC  
**Product Technical Information** 800-662-4525  
**MSDS Internet Address** [www.exxon.com](http://www.exxon.com), [www.mobil.com](http://www.mobil.com)

### SECTION 2 HAZARDS IDENTIFICATION

This material is not hazardous according to regulatory guidelines (see (M)SDS Section 15).

**Other hazard information:**

**HAZARD NOT OTHERWISE CLASSIFIED (HNOC):** None as defined under 29 CFR 1910.1200.

#### PHYSICAL / CHEMICAL HAZARDS

No significant hazards.

#### HEALTH HAZARDS

High-pressure injection under skin may cause serious damage. Excessive exposure may result in eye, skin, or respiratory irritation.

#### ENVIRONMENTAL HAZARDS

No significant hazards.

<b>NFPA Hazard ID:</b>	Health: 0	Flammability: 1	Reactivity: 0
<b>HMIS Hazard ID:</b>	Health: 0	Flammability: 1	Reactivity: 0

**NOTE:** This material should not be used for any other purpose than the intended use in Section 1 without expert advice. Health studies have shown that chemical exposure may cause potential human health risks which may vary from person to person.



Product Name: MOBIL DTE 732  
Revision Date: 04 Aug 2020  
Page 2 of 10

<b>SECTION 3</b>	<b>COMPOSITION / INFORMATION ON INGREDIENTS</b>
------------------	---

This material is defined as a mixture.

**Hazardous Substance(s) or Complex Substance(s) required for disclosure**

Name	CAS#	Concentration*	GHS Hazard Codes
2,6-DI-TERT-BUTYLPHENOL	128-39-2	0.1 - < 0.25%	H315, H400(M factor 1), H410(M factor 1)

\* All concentrations are percent by weight unless material is a gas. Gas concentrations are in percent by volume.

As per paragraph (i) of 29 CFR 1910.1200, formulation is considered a trade secret and specific chemical identity and exact percentage (concentration) of composition may have been withheld. Specific chemical identity and exact percentage composition will be provided to health professionals, employees, or designated representatives in accordance with applicable provisions of paragraph (i).

<b>SECTION 4</b>	<b>FIRST AID MEASURES</b>
------------------	---------------------------

**INHALATION**

Remove from further exposure. For those providing assistance, avoid exposure to yourself or others. Use adequate respiratory protection. If respiratory irritation, dizziness, nausea, or unconsciousness occurs, seek immediate medical assistance. If breathing has stopped, assist ventilation with a mechanical device or use mouth-to-mouth resuscitation.

**SKIN CONTACT**

Wash contact areas with soap and water. If product is injected into or under the skin, or into any part of the body, regardless of the appearance of the wound or its size, the individual should be evaluated immediately by a physician as a surgical emergency. Even though initial symptoms from high pressure injection may be minimal or absent, early surgical treatment within the first few hours may significantly reduce the ultimate extent of injury.

**EYE CONTACT**

Flush thoroughly with water. If irritation occurs, get medical assistance.

**INGESTION**

First aid is normally not required. Seek medical attention if discomfort occurs.

<b>SECTION 5</b>	<b>FIRE FIGHTING MEASURES</b>
------------------	-------------------------------

**EXTINGUISHING MEDIA**

**Appropriate Extinguishing Media:** Use water fog, foam, dry chemical or carbon dioxide (CO<sub>2</sub>) to extinguish flames.

**Inappropriate Extinguishing Media:** Straight Streams of Water

**FIRE FIGHTING**

**Fire Fighting Instructions:** Evacuate area. Prevent runoff from fire control or dilution from entering streams, sewers, or drinking water supply. Firefighters should use standard protective equipment and in enclosed spaces, self-contained breathing apparatus (SCBA). Use water spray to cool fire exposed surfaces and to protect personnel.



Product Name: MOBIL DTE 732  
Revision Date: 04 Aug 2020  
Page 3 of 10

**Hazardous Combustion Products:** Aldehydes, Incomplete combustion products, Oxides of carbon, Smoke, Fume, Sulfur oxides

## FLAMMABILITY PROPERTIES

**Flash Point [Method]:** >215°C (419°F) [ASTM D-92]  
**Flammable Limits (Approximate volume % in air):** LEL: 0.9 UEL: 7.0  
**Autoignition Temperature:** N/D

## SECTION 6 ACCIDENTAL RELEASE MEASURES

### NOTIFICATION PROCEDURES

In the event of a spill or accidental release, notify relevant authorities in accordance with all applicable regulations. US regulations require reporting releases of this material to the environment which exceed the applicable reportable quantity or oil spills which could reach any waterway including intermittent dry creeks. The National Response Center can be reached at (800)424-8802.

### PROTECTIVE MEASURES

Avoid contact with spilled material. See Section 5 for fire fighting information. See the Hazard Identification Section for Significant Hazards. See Section 4 for First Aid Advice. See Section 8 for advice on the minimum requirements for personal protective equipment. Additional protective measures may be necessary, depending on the specific circumstances and/or the expert judgment of the emergency responders.

For emergency responders: Respiratory protection: respiratory protection will be necessary only in special cases, e.g., formation of mists. Half-face or full-face respirator with filter(s) for dust/organic vapor or Self Contained Breathing Apparatus (SCBA) can be used depending on the size of spill and potential level of exposure. If the exposure cannot be completely characterized or an oxygen deficient atmosphere is possible or anticipated, SCBA is recommended. Work gloves that are resistant to hydrocarbons are recommended. Gloves made of polyvinyl acetate (PVA) are not water-resistant and are not suitable for emergency use. Chemical goggles are recommended if splashes or contact with eyes is possible. Small spills: normal antistatic work clothes are usually adequate. Large spills: full body suit of chemical resistant, antistatic material is recommended.

### SPILL MANAGEMENT

**Land Spill:** Stop leak if you can do it without risk. Recover by pumping or with suitable absorbent.

**Water Spill:** Stop leak if you can do it without risk. Confine the spill immediately with booms. Warn other shipping. Remove from the surface by skimming or with suitable absorbents. Seek the advice of a specialist before using dispersants.

Water spill and land spill recommendations are based on the most likely spill scenario for this material; however, geographic conditions, wind, temperature, (and in the case of a water spill) wave and current direction and speed may greatly influence the appropriate action to be taken. For this reason, local experts should be consulted. Note: Local regulations may prescribe or limit action to be taken.

### ENVIRONMENTAL PRECAUTIONS

**Large Spills:** Dike far ahead of liquid spill for later recovery and disposal. Prevent entry into waterways, sewers, basements or confined areas.

## SECTION 7 HANDLING AND STORAGE



## HANDLING

Prevent small spills and leakage to avoid slip hazard. Material can accumulate static charges which may cause an electrical spark (ignition source). When the material is handled in bulk, an electrical spark could ignite any flammable vapors from liquids or residues that may be present (e.g., during switch-loading operations). Use proper bonding and/or ground procedures. However, bonding and grounds may not eliminate the hazard from static accumulation. Consult local applicable standards for guidance. Additional references include American Petroleum Institute 2003 (Protection Against Ignitions Arising out of Static, Lightning and Stray Currents) or National Fire Protection Agency 77 (Recommended Practice on Static Electricity) or CENELEC CLC/TR 50404 (Electrostatics - Code of practice for the avoidance of hazards due to static electricity).

**Static Accumulator:** This material is a static accumulator.

## STORAGE

The type of container used to store the material may affect static accumulation and dissipation. Do not store in open or unlabelled containers. Keep away from incompatible materials.

## SECTION 8

## EXPOSURE CONTROLS / PERSONAL PROTECTION

**Exposure limits/standards for materials that can be formed when handling this product:** When mists/aerosols can occur the following are recommended: 5 mg/m<sup>3</sup> - ACGIH TLV (inhalable fraction), 5 mg/m<sup>3</sup> - OSHA PEL.

NOTE: Limits/standards shown for guidance only. Follow applicable regulations.

No biological limits allocated.

## ENGINEERING CONTROLS

The level of protection and types of controls necessary will vary depending upon potential exposure conditions. Control measures to consider:

No special requirements under ordinary conditions of use and with adequate ventilation.

## PERSONAL PROTECTION

Personal protective equipment selections vary based on potential exposure conditions such as applications, handling practices, concentration and ventilation. Information on the selection of protective equipment for use with this material, as provided below, is based upon intended, normal usage.

**Respiratory Protection:** If engineering controls do not maintain airborne contaminant concentrations at a level which is adequate to protect worker health, an approved respirator may be appropriate. Respirator selection, use, and maintenance must be in accordance with regulatory requirements, if applicable. Types of respirators to be considered for this material include:

No special requirements under ordinary conditions of use and with adequate ventilation.

For high airborne concentrations, use an approved supplied-air respirator, operated in positive pressure mode. Supplied air respirators with an escape bottle may be appropriate when oxygen levels are inadequate, gas/vapor warning properties are poor, or if air purifying filter capacity/rating may be exceeded.

**Hand Protection:** Any specific glove information provided is based on published literature and glove



Product Name: MOBIL DTE 732  
Revision Date: 04 Aug 2020  
Page 5 of 10

manufacturer data. Glove suitability and breakthrough time will differ depending on the specific use conditions. Contact the glove manufacturer for specific advice on glove selection and breakthrough times for your use conditions. Inspect and replace worn or damaged gloves. The types of gloves to be considered for this material include:

No protection is ordinarily required under normal conditions of use.

**Eye Protection:** If contact is likely, safety glasses with side shields are recommended.

**Skin and Body Protection:** Any specific clothing information provided is based on published literature or manufacturer data. The types of clothing to be considered for this material include:

No skin protection is ordinarily required under normal conditions of use. In accordance with good industrial hygiene practices, precautions should be taken to avoid skin contact.

**Specific Hygiene Measures:** Always observe good personal hygiene measures, such as washing after handling the material and before eating, drinking, and/or smoking. Routinely wash work clothing and protective equipment to remove contaminants. Discard contaminated clothing and footwear that cannot be cleaned. Practice good housekeeping.

## ENVIRONMENTAL CONTROLS

Comply with applicable environmental regulations limiting discharge to air, water and soil. Protect the environment by applying appropriate control measures to prevent or limit emissions.

## SECTION 9

## PHYSICAL AND CHEMICAL PROPERTIES

**Note:** Physical and chemical properties are provided for safety, health and environmental considerations only and may not fully represent product specifications. Contact the Supplier for additional information.

### GENERAL INFORMATION

**Physical State:** Liquid  
**Color:** Amber  
**Odor:** Characteristic  
**Odor Threshold:** N/D

### IMPORTANT HEALTH, SAFETY, AND ENVIRONMENTAL INFORMATION

**Relative Density (at 15 °C):** 0.86  
**Flammability (Solid, Gas):** N/A  
**Flash Point [Method]:** >215°C (419°F) [ASTM D-92]  
**Flammable Limits (Approximate volume % in air):** LEL: 0.9 UEL: 7.0  
**Autoignition Temperature:** N/D  
**Boiling Point / Range:** > 316°C (600°F)  
**Decomposition Temperature:** N/D  
**Vapor Density (Air = 1):** > 2 at 101 kPa  
**Vapor Pressure:** < 0.013 kPa (0.1 mm Hg) at 20 °C  
**Evaporation Rate (n-butyl acetate = 1):** N/D  
**pH:** N/A  
**Log Pow (n-Octanol/Water Partition Coefficient):** > 3.5  
**Solubility in Water:** Slight  
**Viscosity:** 31.5 cSt (31.5 mm<sup>2</sup>/sec) at 40 °C | 5.68 cSt (5.68 mm<sup>2</sup>/sec) at 100°C [ASTM D 445]  
**Oxidizing Properties:** See Hazards Identification Section.



Product Name: MOBIL DTE 732  
 Revision Date: 04 Aug 2020  
 Page 6 of 10

## OTHER INFORMATION

**Freezing Point:** N/D  
**Melting Point:** N/A  
**Pour Point:** -18°C (0°F)  
**DMSO Extract (mineral oil only), IP-346:** < 3 %wt

## SECTION 10 STABILITY AND REACTIVITY

**REACTIVITY:** See sub-sections below.

**STABILITY:** Material is stable under normal conditions.

**CONDITIONS TO AVOID:** Excessive heat. High energy sources of ignition.

**MATERIALS TO AVOID:** Strong oxidizers

**HAZARDOUS DECOMPOSITION PRODUCTS:** Material does not decompose at ambient temperatures.

**POSSIBILITY OF HAZARDOUS REACTIONS:** Hazardous polymerization will not occur.

## SECTION 11 TOXICOLOGICAL INFORMATION

### INFORMATION ON TOXICOLOGICAL EFFECTS

Hazard Class	Conclusion / Remarks
<b>Inhalation</b>	
Acute Toxicity: No end point data for material.	Minimally Toxic. Based on assessment of the components.
Irritation: No end point data for material.	Negligible hazard at ambient/normal handling temperatures.
<b>Ingestion</b>	
Acute Toxicity: No end point data for material.	Minimally Toxic. Based on assessment of the components.
<b>Skin</b>	
Acute Toxicity: No end point data for material.	Minimally Toxic. Based on assessment of the components.
Skin Corrosion/Irritation: No end point data for material.	Negligible irritation to skin at ambient temperatures. Based on assessment of the components.
<b>Eye</b>	
Serious Eye Damage/Irritation: No end point data for material.	May cause mild, short-lasting discomfort to eyes. Based on assessment of the components.
<b>Sensitization</b>	
Respiratory Sensitization: No end point data for material.	Not expected to be a respiratory sensitizer.
Skin Sensitization: No end point data for material.	Not expected to be a skin sensitizer. Based on assessment of the components.
<b>Aspiration:</b> Data available.	Not expected to be an aspiration hazard. Based on physico-chemical properties of the material.
<b>Germ Cell Mutagenicity:</b> No end point data for material.	Not expected to be a germ cell mutagen. Based on assessment of the components.
<b>Carcinogenicity:</b> No end point data for material.	Not expected to cause cancer. Based on assessment of the components.
<b>Reproductive Toxicity:</b> No end point data	Not expected to be a reproductive toxicant. Based on assessment



Product Name: MOBIL DTE 732  
 Revision Date: 04 Aug 2020  
 Page 7 of 10

for material.	of the components.
<b>Lactation:</b> No end point data for material.	Not expected to cause harm to breast-fed children.
<b>Specific Target Organ Toxicity (STOT)</b>	
Single Exposure: No end point data for material.	Not expected to cause organ damage from a single exposure.
Repeated Exposure: No end point data for material.	Not expected to cause organ damage from prolonged or repeated exposure. Based on assessment of the components.

## OTHER INFORMATION

### Contains:

Base oil severely refined: Not carcinogenic in animal studies. Representative material passes IP-346, Modified Ames test, and/or other screening tests. Dermal and inhalation studies showed minimal effects; lung non-specific infiltration of immune cells, oil deposition and minimal granuloma formation. Not sensitizing in test animals.

The following ingredients are cited on the lists below: None.

### --REGULATORY LISTS SEARCHED--

1 = NTP CARC  
 2 = NTP SUS

3 = IARC 1  
 4 = IARC 2A

5 = IARC 2B  
 6 = OSHA CARC

## SECTION 12 ECOLOGICAL INFORMATION

The information given is based on data for the material, components of the material, or for similar materials, through the application of bridging principals.

### ECOTOXICITY

Material -- Not expected to be harmful to aquatic organisms.

### MOBILITY

Base oil component -- Low solubility and floats and is expected to migrate from water to the land. Expected to partition to sediment and wastewater solids.

### PERSISTENCE AND DEGRADABILITY

#### Biodegradation:

Base oil component -- Expected to be inherently biodegradable

### BIOACCUMULATION POTENTIAL

Base oil component -- Has the potential to bioaccumulate, however metabolism or physical properties may reduce the bioconcentration or limit bioavailability.

## SECTION 13 DISPOSAL CONSIDERATIONS

Disposal recommendations based on material as supplied. Disposal must be in accordance with current applicable laws and regulations, and material characteristics at time of disposal.

### DISPOSAL RECOMMENDATIONS



Product Name: MOBIL DTE 732  
Revision Date: 04 Aug 2020  
Page 8 of 10

Product is suitable for burning in an enclosed controlled burner for fuel value or disposal by supervised incineration at very high temperatures to prevent formation of undesirable combustion products. Protect the environment. Dispose of used oil at designated sites. Minimize skin contact. Do not mix used oils with solvents, brake fluids or coolants.

#### REGULATORY DISPOSAL INFORMATION

RCRA Information: The unused product, in our opinion, is not specifically listed by the EPA as a hazardous waste (40 CFR, Part 261D), nor is it formulated to contain materials which are listed as hazardous wastes. It does not exhibit the hazardous characteristics of ignitability, corrosivity or reactivity and is not formulated with contaminants as determined by the Toxicity Characteristic Leaching Procedure (TCLP). However, used product may be regulated.

**Empty Container Warning** Empty Container Warning (where applicable): Empty containers may contain residue and can be dangerous. Do not attempt to refill or clean containers without proper instructions. Empty drums should be completely drained and safely stored until appropriately reconditioned or disposed. Empty containers should be taken for recycling, recovery, or disposal through suitably qualified or licensed contractor and in accordance with governmental regulations. DO NOT PRESSURISE, CUT, WELD, BRAZE, SOLDER, DRILL, GRIND, OR EXPOSE SUCH CONTAINERS TO HEAT, FLAME, SPARKS, STATIC ELECTRICITY, OR OTHER SOURCES OF IGNITION. THEY MAY EXPLODE AND CAUSE INJURY OR DEATH.

<b>SECTION 14</b>	<b>TRANSPORT INFORMATION</b>
-------------------	------------------------------

**LAND (DOT):** Not Regulated for Land Transport

**LAND (TDG):** Not Regulated for Land Transport

**SEA (IMDG):** Not Regulated for Sea Transport according to IMDG-Code

**Marine Pollutant:** No

**AIR (IATA):** Not Regulated for Air Transport

<b>SECTION 15</b>	<b>REGULATORY INFORMATION</b>
-------------------	-------------------------------

**OSHA HAZARD COMMUNICATION STANDARD:** This material is not considered hazardous in accordance with OSHA HazCom 2012, 29 CFR 1910.1200.

**Listed or exempt from listing/notification on the following chemical inventories:** AIIC, DSL, ENCS, IECSC, ISHL, KECI, PICCS, TCSI, TSCA

**SARA 302:** No chemicals in this material are subject to the reporting requirements of SARA Title III, Section 302

**SARA (311/312) REPORTABLE GHS HAZARD CLASSES:** None.

**SARA (313) TOXIC RELEASE INVENTORY:** This material contains no chemicals subject to the supplier notification requirements of the SARA 313 Toxic Release Program.



Product Name: MOBIL DTE 732  
 Revision Date: 04 Aug 2020  
 Page 9 of 10

The following ingredients are cited on the lists below:

Chemical Name	CAS Number	List Citations
2-METHYLNAPHTHALENE	91-57-6	18
SEVERELY HYDROTREATED HEAVY PARAFFINIC DISTILLATE	64742-54-7	17, 18, 19

--REGULATORY LISTS SEARCHED--

1 = ACGIH ALL	6 = TSCA 5a2	11 = CA P65 REPRO	16 = MN RTK
2 = ACGIH A1	7 = TSCA 5e	12 = CA RTK	17 = NJ RTK
3 = ACGIH A2	8 = TSCA 6	13 = IL RTK	18 = PA RTK
4 = OSHA Z	9 = TSCA 12b	14 = LA RTK	19 = RI RTK
5 = TSCA 4	10 = CA P65 CARC	15 = MI 293	

Code key: CARC=Carcinogen; REPRO=Reproductive

<b>SECTION 16</b>	<b>OTHER INFORMATION</b>
-------------------	--------------------------

N/D = Not determined, N/A = Not applicable

**KEY TO THE H-CODES CONTAINED IN SECTION 3 OF THIS DOCUMENT (for information only):**

H315: Causes skin irritation; Skin Corr/Irritation, Cat 2  
 H400: Very toxic to aquatic life; Acute Env Tox, Cat 1  
 H410: Very toxic to aquatic life with long lasting effects; Chronic Env Tox, Cat 1

**THIS SAFETY DATA SHEET CONTAINS THE FOLLOWING REVISIONS:**

Composition: Component Table information was modified.  
 Section 08: Exposure Limits Table information was deleted.  
 Section 15: National Chemical Inventory Listing information was modified.  
 Section 16: HCode Key information was modified.

The information and recommendations contained herein are, to the best of ExxonMobil's knowledge and belief, accurate and reliable as of the date issued. You can contact ExxonMobil to insure that this document is the most current available from ExxonMobil. The information and recommendations are offered for the user's consideration and examination. It is the user's responsibility to satisfy itself that the product is suitable for the intended use. If buyer repackages this product, it is the user's responsibility to insure proper health, safety and other necessary information is included with and/or on the container. Appropriate warnings and safe-handling procedures should be provided to handlers and users. Alteration of this document is strictly prohibited. Except to the extent required by law, republication or retransmission of this document, in whole or in part, is not permitted. The term, "ExxonMobil" is used for convenience, and may include any one or more of ExxonMobil Chemical Company, Exxon Mobil Corporation, or any affiliates in which they directly or indirectly hold any interest.

Internal Use Only

MHC: 0B, 0B, 0, 0, 0, 0

PPEC: A





Product Name: MOBIL DTE 732  
Revision Date: 04 Aug 2020  
Page 10 of 10

---

DGN: 7080560XUS (1012743)

---

Copyright 2002 Exxon Mobil Corporation, All rights reserved