



Harris County Fire Marshal

Occupancy: **Wright Waste Management**
Occupancy ID: **11294**
Address: **5410 Crawford Houston TX 77041**

Inspection Type: **233-OPI-Operational Permit Inspection**
Inspection Date: **7/7/2023** By: **Montagna, Matthew (95P61)**
Time In: **11:00** Time Out: **13:16**
Authorized Date: **07/07/2023** By: **Montagna, Matthew (95P61)**

Form: Operational Permit
Phase 1

Inspection Description:

General Operational Permit interdiction

Inspection Topics:

Harris County amendments

HC 105.6 Required operational permits (effective 01/01/2020)

The fire code official is authorized to issue operational permits for the operations set forth in Sections 105.6.1 through 105.6.50.

Status: FAIL

Notes: 105.6 Required operational permits. The fire code official is authorized to issue operational permits for the operations set forth in Sections 105.6.1 through 105.6.50. Each operation set forth requires a separate operational permit.

Operational permits required for your business are

- 1.--- 105.6.20 Hazardous materials.
- 2.---105.6. 16 Flammable and combustible liquids.
3. ---105.6.27 L.P gas
- 4.--- 105.6.29 Miscellaneous Combustible Storage

Initial inspection completed with outstanding hazards. Correct all listed hazards immediately. -

You will be required to submit for operational permits. Operational Permits shall be applied for within 30 days of this report. If you have, any questions please feel free to contact me. A follow up will be scheduled to be completed unless the application has been submitted prior to the 30 days

Please contact me once all corrections have been made so we can schedule your follow-up inspection.

Matt Montagna
Inspector 95P61
Harris County Fire Marshals Office
2318 Atascocita Road
Humble, Texas 77396
281-318-1226
Matthew.Montagna@fmo.hctx.net

HC 105.1.1 Permits required (construction)

A property owner or owner's authorized agent who intends to conduct an operation or business, or construct, substantially improve, enlarge, alter, repair, move, or change the occupancy of a building or structure, or to erect, install, enlarge, alter, repair, remove, convert, or replace the installation of which is regulated by this code, or to cause any such work to be performed, shall first make application to the County Engineer and obtain the required permit.

Status: FAIL

Notes: Permits will be required for your business,

Please contact Harris County engineering office for details on how to apply and the permits required.

Harris County Engineering Department (Permit Office)
Address: 1111 Fannin, 11th Floor / Houston, TX 77002
Phone: 713-274-3926 or compliance@hcpid.org
<http://www.eng.hctx.net/permits>

HC 105.3.3 Occupancy prohibited before approval

The building or structure shall not be occupied prior to the County Engineer issuing a permit and the fire code official conducting associated inspections indicating the applicable provisions of this code have been met.

Status: FAIL

Notes: Occupancy is not authorized prior to a passing fire marshal inspection.

1. Permits will need to be obtained and a passing fire marshal inspection prior to Occupancy.

Fire Protection

901.6 Inspection, testing and maintenance of fire protection systems

Fire detection, alarm, and extinguishing systems, mechanical smoke exhaust systems, and smoke and heat vents shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Nonrequired fire protection systems and equipment shall be inspected, tested and maintained or removed.

Status: N/A

Notes: No fire alarm installed at time of inspection.

903.5 Fire sprinkler/Inspection, testing and maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

Status: N/A

Notes: No fire sprinklers installed at time of inspection.

904.12.5 Kitchen hood fire extinguishing system/Inspection, testing, and maintenance

Operations and maintenance. Automatic fire extinguishing systems protecting commercial cooking systems shall be maintained in accordance with Sections 904.12.5.1 through 904.12.5.3.

Status: N/A

Notes: No kitchen hood installed at time of inspection.

906.1 Where required (portable fire extinguishers)

Portable fire extinguishers shall be installed in the following locations. 1. In new and existing Group A, B, E, F, H, I, M, R-1, R-2, R-4 and S occupancies. 2. Within 30 feet of commercial cooking equipment. 3. In areas where flammable or combustible liquids are stored, used or dispensed. 4. On each floor of structures under construction, except Group R-3 occupancies, in accordance with Section 1415.1. 5. Where required by the sections indicated in Table 906.1. 6. Special-hazard areas, including but not limited to laboratories, computer rooms and generator rooms, where required by the fire code official.

Status: FAIL

Notes: All fire extinguishers are required to be inspected by a licensed fire suppression company annually.

1. Observation that multiple fire extinguishers are out of day by over a year. Insect all extinguishers immediatly.

General

Meet with owner/owners representative

Meet with owner/owners representative

Status: PASS

Notes:

Provide insight on operational permit requirements

Provide insight on operational permit requirements

Status: PASS

Notes:

Provided insight on e-permits application process

provided insight on e-permits application process

Status: PASS

Notes:

Left a copy of the operational permit example packet

Left a copy of the operational permit example packet

Status: PASS

Notes:

Left a copy of the operational permit notice form

Left a copy of the operational permit notice form

Status: PASS

Notes:

Left inspector contact information for issue or concerns

Left inspector contact information for issue or concerns

Status: PASS

Notes:

Other

Not previous Listed

Not previous Listed

Status: FAIL

Notes:

1013.1 Where required (Exit Signs)

Exits and exit access doors shall be marked by an approved exit sign readily visible from any direction of egress travel. The path of egress travel to exits and within exits shall be marked by readily visible exit signs to clearly indicate the direction of egress travel in cases where the exit or the path of egress travel is not immediately visible to the occupants. Intervening means of egress doors within exits shall be marked by exit signs. Exit sign placement shall be such that any point in an exit access corridor or exit passageway is within 100 feet (30 480 mm) or the listed viewing distance of the sign, whichever is less, from the nearest visible exit sign. Exceptions: 1. Exit signs are not required in rooms or areas that require only one exit or exit access. 2. Main exterior exit doors or gates that are obviously and clearly identifiable as exits need not have exit signs where approved by the fire code official. 3. Exit signs are not required in occupancies in Group U and individual sleeping units or dwelling units in Group R-1, R-2 or R-3. 4. Exit signs are not required in dayrooms, sleeping rooms or dormitories in occupancies in Group I-3. 5. In occupancies in Groups A-4 and A-5, exit signs are not required on the seating side of dormitories or openings into seating areas here exit signs are provided in the concourse that are readily apparent from the dormitories. Egress lighting is provided to identify each vomitory or opening within the seating area in an emergency.

Emergency exit lights are required to operate under emergency power.

1. Repair or replace all exit signs that do not operate as intended.

Not previous Listed

Not previous Listed

Status: FAIL

Notes: 1008.1 Illumination required (means of egress)

Illumination shall be provided in the means of egress in accordance with Section 1008.2. Under emergency power, means of egress illumination shall comply with Section 1008.3.

1. Install egress lighting throughout office building

Not previous Listed

Not previous Listed

Status: N/A

Notes:

Not previous Listed

Not previous Listed

Status: N/A

Notes:

Not previous listed

Status: N/A

Notes:

Additional Time Spent on Inspection:

Category

Start Date / Time

End Date / Time

Notes: No Additional time recorded

Total Additional Time: 0 minutes

Inspection Time: 136 minutes

Total Time: 136 minutes

Summary:

Overall Result: First Correction Notice

Initial inspection completed with outstanding hazards

Please contact me once all corrections have been made so we can schedule your follow-up inspection.

Matt Montagna
Inspector 95P61

Inspector Notes: Harris County Fire Marshals Office

2318 Atascocita Road
Humble, Texas 77396
281-318-1226

Matthew.Montagna@fmo.hctx.net

Inspector:

Name: Montagna, Matthew
Rank: Inspector
Email(s): Matthew.Montagna@fmo.hctx.net
Montagna, Matthew:



Signed on: 07/07/2023 13:16

Signature

Date

Representative Signature:

Signature of: Stratton Wright on 07/07/2023 13:00



Signature

Date



Harris County Fire Marshal

Occupancy: **Wright Waste Management**
Occupancy ID: **11294**
Address: **5410 Crawford Houston TX 77041**

Inspection Type: **352-Complaint**

Inspection Date: **9/25/2023**

Time In: **14:00**

Authorized Date: **09/25/2023**

By: **Montagna, Matthew (95P61)**

Time Out: **15:05**

By: **Montagna, Matthew (95P61)**

Form: Operational Permit
Phase 1

Inspection Description:

General Operational Permit interdiction

Inspection Topics:

Harris County amendments

HC 105.6 Required operational permits (effective 01/01/2020)

The fire code official is authorized to issue operational permits for the operations set forth in Sections 105.6.1 through 105.6.50.

Status: FAIL

Notes: Hazard Remains 9-25-2023

105.6 Required operational permits. The fire code official is authorized to issue operational permits for the operations set forth in Sections 105.6.1 through 105.6.50. Each operation set forth requires a separate operational permit.

Operational permits required for your business are

- 1.--- 105.6.20 Hazardous materials.
- 2.---105.6. 16 Flammable and combustible liquids.
3. ---105.6.27 L.P gas
- 4.--- 105.6.29 Miscellaneous Combustible Storage

Initial inspection completed with outstanding hazards. Correct all listed hazards immediately. -

You will be required to submit for operational permits. Operational Permits shall be applied for within 30 days of this report. If you have, any questions please feel free to contact me. A follow up will be scheduled to be completed unless the application has been submitted prior to the 30 days

Please contact me once all corrections have been made so we can schedule your follow-up inspection.

Matt Montagna
Inspector 95P61
Harris County Fire Marshals Office
2318 Atascocita Road
Humble, Texas 77396
281-318-1226
Matthew.Montagna@fmo.hctx.net

HC 105.1.1 Permits required (construction)

A property owner or owner's authorized agent who intends to conduct an operation or business, or construct, substantially improve, enlarge, alter, repair, move, or change the occupancy of a building or structure, or to erect, install, enlarge, alter, repair, remove, convert, or replace the installation of which is regulated by this code, or to cause any such work to be performed, shall first make application to the County Engineer and obtain the required permit.

Status: FAIL

Notes: Violation Remains 9-25-2023

Permits will be required for your business,

Please contact Harris County engineering office for details on how to apply and the permits required.

Harris County Engineering Department (Permit Office)
Address: 1111 Fannin, 11th Floor / Houston, TX 77002
Phone: 713-274-3926 or compliance@hcpid.org
<http://www.eng.hctx.net/permits>

HC 105.3.3 Occupancy prohibited before approval

The building or structure shall not be occupied prior to the County Engineer issuing a permit and the fire code official conducting associated inspections indicating the applicable provisions of this code have been met.

Status: FAIL

Notes: Hazard Remains 9-25-2023

Occupancy is not authorized prior to a passing fire marshal inspection.

1. Permits will need to be obtained and a passing fire marshal inspection prior to Occupancy.

Fire Protection

901.6 Inspection, testing and maintenance of fire protection systems

Fire detection, alarm, and extinguishing systems, mechanical smoke exhaust systems, and smoke and heat vents shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Nonrequired fire protection systems and equipment shall be inspected, tested and maintained or removed.

Status: N/A

Notes: No fire alarm installed at time of inspection.

903.5 Fire sprinkler/Inspection, testing and maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

Status: N/A

Notes: No fire sprinklers installed at time of inspection.

904.12.5 Kitchen hood fire extinguishing system/Inspection, testing, and maintenance

Operations and maintenance. Automatic fire extinguishing systems protecting commercial cooking systems shall be maintained in accordance with Sections 904.12.5.1 through 904.12.5.3.

Status: N/A

Notes: No kitchen hood installed at time of inspection.

906.1 Where required (portable fire extinguishers)

Portable fire extinguishers shall be installed in the following locations. 1. In new and existing Group A, B, E, F, H, I, M, R-1, R-2, R-4 and S occupancies. 2. Within 30 feet of commercial cooking equipment. 3. In areas where flammable or combustible liquids are stored, used or dispensed. 4. On each floor of structures under construction, except Group R-3 occupancies, in accordance with Section 1415.1. 5. Where required by the sections indicated in Table 906.1. 6. Special-hazard areas, including but not limited to laboratories, computer rooms and generator rooms, where required by the fire code official.

Status: PASS

Notes: Hazard Corrected 9-25-2023

All fire extinguishers are required to be inspected by a licensed fire suppression company annually.

1. Observation that multiple fire extinguishers are out of day by over a year. Insect all extinguishers immediatly.

General

Meet with owner/owners representative
Meet with owner/owners representative
Status: PASS
Notes:

Provide insight on operational permit requirements
Provide insight on operational permit requirements
Status: PASS
Notes:

Provided insight on e-permits application process
provided insight on e-permits application process
Status: PASS
Notes:

Left a copy of the operational permit example packet
Left a copy of the operational permit example packet
Status: PASS
Notes:

Left a copy of the operational permit notice form
Left a copy of the operational permit notice form
Status: PASS
Notes:

Left inspector contact information for issue or concerns
Left inspector contact information for issue or concerns
Status: PASS
Notes:

Other

Not previous Listed
Not previous Listed
Status: FAIL
Notes:
Hazard Remains 9-25-2023

1013.1 Where required (Exit Signs)
Exits and exit access doors shall be marked by an approved exit sign readily visible from any direction of egress travel. The path of egress travel to exits and within exits shall be marked by readily visible exit signs to clearly indicate the direction of egress travel in cases where the exit or the path of egress travel is not immediately visible to the occupants. Intervening means of egress doors within exits shall be marked by exit signs. Exit sign placement shall be such that any point in an exit access corridor or exit passageway is within 100 feet (30 480 mm) or the listed viewing distance of the sign, whichever is less, from the nearest visible exit sign. Exceptions: 1. Exit signs are not required in rooms or areas that require only one exit or exit access. 2. Main exterior exit doors or gates that are obviously and clearly identifiable as exits need not have exit signs where approved by the fire code official. 3. Exit signs are not required in occupancies in Group U and individual sleeping units or dwelling units in Group R-1, R-2 or R-3. 4. Exit signs are not required in dayrooms, sleeping rooms or dormitories in occupancies in Group I-3. 5. In occupancies in Groups A-4 and A-5, exit signs are not required on the seating side of dormitories or openings into seating areas here exit signs are provided in the concourse that are readily apparent from the dormitories. Egress lighting is provided to identify each vomitory or opening within the seating area in an emergency.

Emergency exit lights are required to operate under emergency power.

1. Repair or replace all exit signs that do not operate as intended.

Not previous Listed

Not previous Listed

Status: FAIL

Notes: Hazard Remains 9-25-2023

1008.1 Illumination required (means of egress)

Illumination shall be provided in the means of egress in accordance with Section 1008.2. Under emergency power, means of egress illumination shall comply with Section 1008.3.

1. Install egress lighting throughout office building

Not previous Listed

Not previous Listed

Status: N/A

Notes:

Not previous Listed

Not previous Listed

Status: N/A

Notes:

Not previous listed

Status: N/A

Notes:

Additional Time Spent on Inspection:

Category	Start Date / Time	End Date / Time
----------	-------------------	-----------------

Notes: No Additional time recorded

Total Additional Time: 0 minutes

Inspection Time: 65 minutes

Total Time: 65 minutes

Summary:

Overall Result: Second Correction Notice

Second inspection completed and there are remaining hazards

Third Inspection may require re-application and additional fee.

Please contact me once all corrections have been made so we can schedule your follow-up inspection.

Inspector Notes:

Matt Montagna
 Inspector 95P61
 Harris County Fire Marshals Office
 2318 Atascocita Road
 Humble, Texas 77396
 281-318-1226
 Matthew.Montagna@fmo.hctx.net

How did I do? If you would like to leave feedback based on your experience with this inspection, please go to <https://www.surveymonkey.com/r/7PXR5LT>

Inspector:

Name: Montagna, Matthew
Rank: Inspector
Email(s): Matthew.Montagna@fmo.hctx.net
Montagna, Matthew:



Signed on: 09/25/2023 15:00

Signature

Date

Representative Signature:

Signature of: Stratton Wright on 09/25/2023 14:41



Signature

Date



Harris County Fire Marshal

Occupancy: **Wright Waste Management**
Occupancy ID: **11294**
Address: **5410 Crawford Houston TX 77041**

Inspection Type: **233-OP-Complaint Follow-up**

Inspection Date: **4/30/2024**

By: **Montagna, Matthew (95P61)**

Time In: **12:00**

Time Out: **13:45**

Authorized Date: **04/30/2024**

By: **Montagna, Matthew (95P61)**

Form: Operational Permit
Phase 1

Inspection Description:

General Operational Permit interdiction

Inspection Topics:

Harris County amendments

HC 105.6 Required operational permits (effective 01/01/2020)

The fire code official is authorized to issue operational permits for the operations set forth in Sections 105.6.1 through 105.6.50.

Status: FAIL

Notes: Hazard Remains 4-30-2024

Hazard Remains 9-25-2023

105.6 Required operational permits. The fire code official is authorized to issue operational permits for the operations set forth in Sections 105.6.1 through 105.6.50. Each operation set forth requires a separate operational permit.

Operational permits required for your business are

- 1.--- 105.6.20 Hazardous materials.
- 2.---105.6. 16 Flammable and combustible liquids.
3. ---105.6.27 L.P gas
- 4.--- 105.6.29 Miscellaneous Combustible Storage

Initial inspection completed with outstanding hazards. Correct all listed hazards immediately. -

You will be required to submit for operational permits. Operational Permits shall be applied for within 30 days of this report. If you have, any questions please feel free to contact me. A follow up will be scheduled to be completed unless the application has been submitted prior to the 30 days

Please contact me once all corrections have been made so we can schedule your follow-up inspection.

Matt Montagna
Inspector 95P61
Harris County Fire Marshals Office
2318 Atascocita Road
Humble, Texas 77396
281-318-1226
Matthew.Montagna@fmo.hctx.net

HC 105.1.1 Permits required (construction)

A property owner or owner's authorized agent who intends to conduct an operation or business, or construct, substantially improve, enlarge, alter, repair, move, or change the occupancy of a building or structure, or to erect, install, enlarge, alter, repair, remove, convert, or replace the installation of which is regulated by this code, or to cause any such work to be performed, shall first make application to the County Engineer and obtain the required permit.

Status: FAIL

Notes: Hazard remains 4-30-2024

Violation Remains 9-25-2023

Permits will be required for your business,

Please contact Harris County engineering office for details on how to apply and the permits required.

Harris County Engineering Department (Permit Office)
Address: 1111 Fannin, 11th Floor / Houston, TX 77002
Phone: 713-274-3926 or compliance@hcpid.org
<http://www.eng.hctx.net/permits>

HC 105.3.3 Occupancy prohibited before approval

The building or structure shall not be occupied prior to the County Engineer issuing a permit and the fire code official conducting associated inspections indicating the applicable provisions of this code have been met.

Status: FAIL

Notes: Hazard Remains 9-25-2023

Occupancy is not authorized prior to a passing fire marshal inspection.

1. Permits will need to be obtained and a passing fire marshal inspection prior to Occupancy.

Fire Protection

901.6 Inspection, testing and maintenance of fire protection systems

Fire detection, alarm, and extinguishing systems, mechanical smoke exhaust systems, and smoke and heat vents shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Nonrequired fire protection systems and equipment shall be inspected, tested and maintained or removed.

Status: N/A

Notes: No fire alarm installed at time of inspection.

903.5 Fire sprinkler/Inspection, testing and maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

Status: N/A

Notes: No fire sprinklers installed at time of inspection.

904.12.5 Kitchen hood fire extinguishing system/Inspection, testing, and maintenance

Operations and maintenance. Automatic fire extinguishing systems protecting commercial cooking systems shall be maintained in accordance with Sections 904.12.5.1 through 904.12.5.3.

Status: N/A

Notes: No kitchen hood installed at time of inspection.

906.1 Where required (portable fire extinguishers)

Portable fire extinguishers shall be installed in the following locations. 1. In new and existing Group A, B, E, F, H, I, M, R-1, R-2, R-4 and S occupancies. 2. Within 30 feet of commercial cooking equipment. 3. In areas where flammable or combustible liquids are stored, used or dispensed. 4. On each floor of structures under construction, except Group R-3 occupancies, in accordance with Section 1415.1. 5. Where required by the sections indicated in Table 906.1. 6. Special-hazard areas, including but not limited to laboratories, computer rooms and generator rooms, where required by the fire code official.

Status: PASS

Notes: Hazard Corrected 9-25-2023

All fire extinguishers are required to be inspected by a licensed fire suppression company annually.

1. Observation that multiple fire extinguishers are out of day by over a year. Insect all extinguishers immediatly.

General

Meet with owner/owners representative

Meet with owner/owners representative

Status: PASS

Notes:

Provide insight on operational permit requirements

Provide insight on operational permit requirements

Status: PASS

Notes:

Provided insight on e-permits application process

provided insight on e-permits application process

Status: PASS

Notes:

Left a copy of the operational permit example packet

Left a copy of the operational permit example packet

Status: PASS

Notes:

Left a copy of the operational permit notice form

Left a copy of the operational permit notice form

Status: PASS

Notes:

Left inspector contact information for issue or concerns

Left inspector contact information for issue or concerns

Status: PASS

Notes:

Other

Not previous Listed

Not previous Listed

Status: FAIL

Notes: Hazard Remains 4-30-2024

Hazard Remains 9-25-2023

1013.1 Where required (Exit Signs)

Exits and exit access doors shall be marked by an approved exit sign readily visible from any direction of egress travel. The path of egress travel to exits and within exits shall be marked by readily visible exit signs to clearly indicate the direction of egress travel in cases where the exit or the path of egress travel is not immediately visible to the occupants. Intervening means of egress doors within exits shall be marked by exit signs. Exit sign placement shall be such that any point in an exit access corridor or exit passageway is within 100 feet (30 480 mm) or the listed viewing distance of the sign, whichever is less, from the nearest visible exit sign. Exceptions: 1. Exit signs are not required in rooms or areas that require only one exit or exit access. 2. Main exterior exit doors or gates that are obviously and clearly identifiable as exits need not have exit signs where approved by the fire code official. 3. Exit signs are not required in occupancies in Group U and individual sleeping units or dwelling units in Group R-1, R-2 or R-3. 4. Exit signs are not required in dayrooms, sleeping rooms or dormitories in occupancies in Group I-3. 5. In occupancies in Groups A-4 and A-5, exit signs are not required on the seating side of dormitories or openings into seating areas here exit signs are provided in the concourse that are readily apparent from the dormitories. Egress lighting is provided to identify each vomitory or opening within the seating area in an emergency.

Emergency exit lights are required to operate under emergency power.

1. Repair or replace all exit signs that do not operate as intended.

Not previous Listed

Not previous Listed

Status: FAIL

Notes: Hazard remains 4-30-2024

Hazard Remains 9-25-2023

1008.1 Illumination required (means of egress)

Illumination shall be provided in the means of egress in accordance with Section 1008.2. Under emergency power, means of egress illumination shall comply with Section 1008.3.

1. Install egress lighting throughout office building

Not previous Listed

Not previous Listed

Status: FAIL

Notes: New Hazard 4-30-2024

During inspection it was shown that there was significantly more product and pallets stacked around the facility than prior. the facility has taken in more product and it is not being stored in the public road way.

1. No fire lanes or means of controlling a fire are present at the facility at time of inspection.
Create sufficient fire lanes throughout the facility and provide adequate fire protection equipment immediatly.
2. Pallets are stacked in a pile between 12-15 foot high in a continuous row roughly 100ft wide and 500ft long. Pallets are also stacked outside the fence line in the public right of way.
Create a plan to stack pallets in accordance with the code.

SECTION 2810

OUTDOOR STORAGE OF PALLETS AT PALLET MANUFACTURING AND RECYCLING FACILITIES

2810.1 General. The outside storage of wood pallets and wood composite pallets on the same site as a pallet manufacturing or recycling facility shall comply with Sections 2810.2 through 2810.11.

2810.2 Site plan. Each site shall maintain a current site plan that includes a general description of the property, the boundaries of the lot, the size and location of buildings, and all of the following:

1. Utilities.
2. Type of construction and presence of sprinkler protection for other buildings on the site.
3. Water supply sources for fire-fighting purposes.
4. Location of hazardous material storage areas.
5. Location of pallet storage.
6. Equipment protected with a dust collection system.
7. Fire apparatus access roads.
8. Designated smoking areas.
9. Location of fire alarm control panels.

2810.3 Fire prevention plan. The owner or owner's authorized representative shall prepare an approved fire prevention plan that includes all of the following:

1. Frequency of walk-through inspections to verify compliance with the plan.
2. Hot work permit program in accordance with Chapter 35.
3. Preventive maintenance program for equipment associated with pallet activities.
4. Inspection, testing and maintenance of fire protection systems in accordance with Chapter 9.

2810.4 Fire safety and emergency evacuation plan. The owner or owner's authorized representative shall prepare and train employees in an approved fire safety and emergency evacuation plan in accordance with Chapter 4.

2810.5 Security management plan. The owner or owner's authorized representative shall prepare a security management plan based on a security risk assessment and shall make the plan and assessment available to the fire code official upon request.

2810.6 Clearance to property line. Stacks of pallets shall not be stored within 0.75 times the stack height or 8 feet (2438 mm) of the property line, whichever is greater, or shall comply with Section 2810.11.

2810.7 Clearance to important buildings. Stacks of pallets shall not be stored within 0.75 times the stack height of any important building on site, or shall comply with Section 2810.11.

2810.8 Height. Pallet stacks shall not exceed 20 feet (6096 mm) in height.

2810.9 Fire flow. Fire-flow requirements for the site shall be determined by the fire code official.

2810.10 Portable fire extinguishers. Portable fire extinguishers shall be provided within 75 feet (22 860 mm) of any pallet stack.

2810.11 Alternative approach. Where approved by the fire code official, pallet stacks located closer to a property line or structure than as required by Sections 2810.6 and 2810.7 shall be provided with additional fire protection including, but not limited to, the following:

1. The storage yard areas and materials-handling equipment selection, design, and arrangement are based on an approved risk assessment.
2. Automatic fire detection that transmits an alarm to a supervising station in accordance with NFPA 72.
3. Fire apparatus access roads around all storage areas

Not previous Listed

Not previous Listed

Status: N/A

Notes:

Not previous listed

Status: N/A

Notes:

Additional Time Spent on Inspection:

Category	Start Date / Time	End Date / Time
----------	-------------------	-----------------

Notes: No Additional time recorded

Total Additional Time: 0 minutes

Inspection Time: 105 minutes

Total Time: 105 minutes

Summary:

Overall Result: Correction Notice

Utilized when completing any inspection and hazards continue to exist. A follow up inspection is required.

If you have any questions, please contact me direct for assistance.

Matt Montagna
 Inspector 95P61
 Harris County Fire Marshals Office
 2318 Atascocita Road
 Humble, Texas 77396
 713-274-2717
 Matthew.Montagna@fmo.hctx.net

Inspector Notes:

How did I do? If you would like to leave feedback based on your experience with this inspection, please go to <https://www.surveymonkey.com/r/7PXR5LT>

Inspector:

Name: Montagna, Matthew

Rank: Inspector

Email(s): Matthew.Montagna@fmo.hctx.net

Montagna, Matthew:



Signed on: 04/30/2024 13:32

Signature

Date

Representative Signature:

Signature of: Becky Wright on 04/30/2024 12:53

B. Wright

Signature

Date