

Summary of Residuals Management Unit PFAS Data

Summary of Sludge PFAS Data									
Facility	Location	PFBS in ng/g	PFOA in ng/g	PFOS in ng/g	PFBS in mg/kg	PFOA in mg/kg	PFOS in mg/kg	Comments	License #
Chapter 418 Screening Concentration PFBS in mg/kg		1.9							
Chapter 418 Screening Concentration PFOA in mg/kg		0.0025							
Chapter 418 Screening Concentration PFOS in mg/kg		0.0052							
Kennebunk Sewer District	Kennebunk	1.98	1.98	6.15	0.00198	0.00198	0.00615	Sampled 08/22/17	S-022033-SC-A-N
LAWPCA	Lewiston	2.99	1.5	13.8	0.00299	0.0015	0.0138		S-007681-SC-D-R
South Portland	South Portland	3.02	2.1	37.2	0.00302	0.0021	0.0372		S-022054-SC-A-N
Boothbay Harbor Sewer District	Boothbay Harbor	2.83	2.83	12.4	0.00283	0.00283	0.0124		S-022053-SC-A-N
NEFCO	Quincy, MA	0.00893	1.16	17.3	0.0000893	0.00116	0.0173	Sampled 03/25/19	S-022246-SC-A-N
Village Green	Brunswick	5.37	3.71	24	0.00537	0.00371	0.024		S-022466-SC-A-N
NEFCO	Quincy, MA	0.57	0.65	11	0.00057	0.00065	0.011	Sampled 04/05/19	S-022246-SC-A-N
Synagro	North Andover, MA	0.5	0.95	25.3	0.0005	0.00095	0.0253		S-022394-SC-A-N
Yarmouth WWTP	Yarmouth	2.65	4.78	23.4	0.00265	0.00478	0.0234	No PA; Sampled sludge not compost	S-007522-CH-B-R
Mechanic Falls Sanitary District	Mechanic Falls	1.89	1.41	17.8	0.00189	0.00141	0.0178		S-022043-SC-A-N
Richmond Utility District	Richmond	1.68	4.33	12	0.00168	0.00433	0.012		S-022063-SC-A-N
Limestone	Limestone	2.3	5.4	120	0.0023	0.0054	0.12		S-022027-SC-B-N
Farmington WWTF	Farmington	3.2	3.2	4.7	0.0032	0.0032	0.0047		S-022055-SC-A-N
Milorganite (MMSD)	Milwaukee, WI	0.21	1.4	3.7	0.00021	0.0014	0.0037	RL was 0.0053; have asked them to re-analyze	S-022036-SC-A-N
Falmouth	Falmouth	0.833	15.1	27.4	0.000833	0.0151	0.0274		S-022070-SC-A-N
Brunswick Sewer District	Brunswick	1.8	1.8	6	0.0018	0.0018	0.006		S-022059-SC-B-N
Madawaska Pollution Control	Madawaska	0.485	12	23.5	0.000485	0.012	0.0235		S-022071-SC-A-N
Old Town Pollution Control	Old Town	0.599	0.599	9.84	0.000599	0.000599	0.00984		S-007615-CH-C-N
Bucksport	Bucksport	0.723	9.95	57	0.000723	0.00995	0.057		S-022107-SC-A-N
Portland Water District (East End)	Portland	0.61	0.903	10.9	0.00061	0.000903	0.0109		S-000002-SC-D-R
Portland Water District (Westbrook)	Westbrook	0.682	1.24	22.9	0.000682	0.00124	0.0229		S-000002-SC-D-R
Kennebec Sanitary Treatment District	Waterville	2.9	5.6	77	0.0029	0.0056	0.077		S-020127-SC-D-R
McCain Foods USA, Inc.	Easton	18	18	9.4	0.018	0.018	0.0094	RL for PFOA was 18; planning to surrender license	S-022103-SC-B-N
Pat Jackson, Inc.	Belgrade	3	35	35	0.003	0.035	0.035		S-021943-SC-A-N
Data shaded in light blue indicates results reported as Non Detect by the laboratory and were recorded at the laboratory reporting limit									